

SZENTGOTTHARD FARKASFA, Hungary

WMO: 129100

Lat: 46.917N

Lon: 16.317E

Elev: 313

StdP: 97.62

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.7	-8.3	-14.4	1.1	-8.2	-12.1	1.4	-6.1	6.7	4.8	5.9	3.7	1.4	40	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	31.2	20.8	29.5	20.5	27.7	19.7	22.1	28.5	21.1	27.6	20.3	26.4	2.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	15.3	24.9	19.0	14.3	24.0	18.2	13.6	22.9	66.2	28.5	62.6	27.7	59.6	26.5	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.9	5.0	4.3	DB	-13.6	33.4	2.9	2.4	-15.7	35.2	-17.4	36.6	-19.1	37.9	-21.2	39.7	(4)
(5)			WB	-14.1	23.5	2.8	1.3	-16.1	24.4	-17.8	25.2	-19.4	25.9	-21.4	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.4	-0.2	1.8	5.8	10.7	14.9	18.5	20.3	20.0	15.3	10.5	5.6	0.6
	DBStd	8.21	4.37	4.67	4.36	3.91	3.46	3.52	3.13	3.16	3.32	4.04	4.31	4.04
	HDD10.0	1209	316	230	140	39	3	0	0	0	2	44	143	292
	HDD18.3	3120	574	462	387	230	115	40	17	18	102	242	383	549
	CDD10.0	1345	0	2	11	59	156	256	321	309	161	61	10	1
	CDD18.3	214	0	0	0	1	9	46	79	69	11	0	0	0
	CDH23.3	2025	0	0	0	12	112	439	739	639	80	3	0	0
	CDH26.7	599	0	0	0	1	14	121	236	218	9	0	0	0
Wind	WSAvg	1.9	1.7	1.9	2.2	2.2	2.1	1.9	1.9	1.7	1.7	1.7	1.7	1.6
Precipitation	PrecAvg	757	30	37	41	49	73	91	92	88	86	65	62	43
	PrecMax	1023	87	118	95	111	132	165	156	189	184	176	157	90
	PrecMin	550	6	7	4	3	26	29	12	5	24	0	4	1
	PrecStd	119	21	32	25	25	30	32	38	46	47	41	35	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	16.7	20.3	25.0	28.3	32.0	33.5	34.3	27.9	23.5	18.5	13.3
		MCWB	8.1	9.1	11.2	15.5	18.3	21.2	21.5	20.9	19.6	16.9	13.5	10.4
	2%	DB	10.2	13.2	17.8	22.4	26.2	29.9	31.1	31.2	25.6	20.9	15.7	10.3
		MCWB	6.7	7.8	10.5	13.6	17.7	20.8	21.0	20.5	18.7	15.9	12.1	7.8
	5%	DB	8.0	10.9	15.4	20.3	24.3	27.9	29.3	29.1	23.7	18.9	13.5	8.0
		MCWB	5.4	6.6	9.4	12.7	16.7	20.0	20.4	20.3	17.7	14.8	10.8	5.8
	10%	DB	5.9	8.8	13.1	18.3	22.3	25.9	27.6	27.0	21.6	16.8	11.7	6.0
		MCWB	3.7	5.2	8.1	11.5	15.5	18.9	19.6	19.6	16.5	13.7	9.7	4.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	9.7	12.1	16.2	19.7	22.9	23.6	23.2	20.8	17.7	14.0	10.5
		MCDB	11.7	15.4	18.2	23.3	26.1	28.9	30.1	29.5	26.6	22.4	17.4	12.9
	2%	WB	7.1	8.2	10.8	14.5	18.4	21.4	22.1	21.9	19.3	16.2	12.5	8.2
		MCDB	9.7	12.6	16.6	20.9	24.6	27.8	28.7	28.3	24.4	19.9	15.0	10.1
	5%	WB	5.6	6.9	9.7	13.2	17.2	20.4	21.1	20.9	18.2	15.2	11.2	6.1
		MCDB	7.6	10.3	14.8	18.8	22.9	26.8	27.6	27.4	22.5	18.2	13.4	7.5
	10%	WB	4.1	5.6	8.4	12.1	16.1	19.4	20.2	19.9	17.1	14.1	9.8	4.7
		MCDB	5.7	8.4	12.5	17.1	21.3	25.1	26.2	25.9	20.8	16.5	11.3	5.6
Mean Daily Temperature Range	5% DB	MDBR	6.4	8.3	9.8	10.8	11.0	11.1	11.4	11.2	9.8	9.1	6.5	5.8
		MCDBR	9.8	11.8	13.5	14.3	14.1	13.8	14.0	14.3	12.4	11.4	9.7	9.1
		MCWBR	6.5	7.1	7.4	7.1	6.8	6.1	5.5	5.4	6.0	6.6	6.3	6.5
	5% WB	MCDBR	9.2	11.0	12.6	12.9	12.9	13.0	13.0	13.1	11.7	10.7	8.9	8.5
		MCWBR	6.4	7.0	7.2	6.7	6.5	6.0	5.7	5.8	6.0	6.3	6.0	6.5
Clear-Sky Solar Irradiance	taub	0.317	0.341	0.378	0.424	0.419	0.424	0.427	0.431	0.405	0.378	0.347	0.317	
	taud	2.397	2.348	2.274	2.164	2.226	2.252	2.243	2.245	2.289	2.339	2.381	2.427	
	Ebn at Noon	766	819	838	829	848	843	835	814	800	763	716	722	
	Edh at Noon	71	91	114	139	136	133	132	127	111	91	72	62	
All-Sky Solar Radiation	RadAvg	1.17	1.97	3.16	4.47	5.39	5.89	5.82	5.16	3.66	2.39	1.28	0.90	
	RadStd	0.14	0.28	0.38	0.45	0.50	0.42	0.43	0.53	0.45	0.25	0.15	0.13	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.88	+0.92	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)		+0.54	N/A	N/A	+0.90	+0.51	+0.44	-110	-151	+94	+60

Nomenclature: See separate page