

ZALAEGERSZEG ANDRASHIDA, Hungary

WMO: 129150

Lat: **46.867N**Lon: **16.800E**Elev: **180**StdP: **99.18**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.7	-14.4	1.1	-8.6	-11.7	1.4	-5.7	11.1	0.5	10.0	-0.3	3.7	10	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.9	31.7	20.9	30.0	20.5	28.3	19.8	22.1	28.9	21.2	28.2	20.5	27.1	3.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.8	14.8	25.5	18.9	14.0	24.4	18.1	13.3	23.5	65.3	28.8	62.3	28.2	59.6	27.3	25.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.5	8.2	7.0	-11.9	34.6	2.7	2.0	-13.8	36.0	-15.4	37.2	-16.9	38.4	-18.9	39.9		
(5)			-12.6	23.6	2.6	1.0	-14.5	24.3	-16.0	25.0	-17.5	25.5	-19.4	26.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-0.1	1.7	6.2	11.6	15.6	19.2	21.0	20.7	16.0	11.3	6.0	1.4
	DBStd	8.39	4.51	4.67	4.69	3.99	3.53	3.56	3.23	3.19	3.34	3.98	4.34	3.97
	HDD10.0	1145	314	233	133	29	3	0	0	0	1	34	131	266
	HDD18.3	2967	572	466	376	203	97	32	13	12	84	218	369	523
	CDD10.0	1489	0	1	15	77	177	277	342	331	182	74	12	1
	CDD18.3	269	0	0	0	1	13	58	96	85	16	1	0	0
	CDH23.3	2421	0	0	0	13	130	513	874	772	113	5	0	0
	CDH26.7	746	0	0	0	1	17	141	296	274	18	0	0	0
Wind	WSAvg	3.0	3.0	3.5	3.6	3.5	3.2	2.8	2.7	2.5	2.7	2.7	2.8	2.9
Precipitation	PrecAvg	670	29	36	36	42	66	80	71	77	73	65	54	41
	PrecMax	964	68	104	83	92	102	133	137	167	171	143	145	104
	PrecMin	462	5	4	2	1	30	26	11	6	22	1	1	5
	PrecStd	137	18	29	24	22	23	27	34	45	40	38	35	26
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	15.1	20.2	25.1	28.6	32.2	33.7	34.4	28.7	24.0	18.6	13.8
		MCWB	8.3	8.8	11.3	15.8	18.2	21.2	21.2	20.8	19.1	17.1	13.4	10.5
	2%	DB	10.1	12.3	17.8	22.8	26.5	30.1	31.6	31.9	26.3	21.4	15.8	11.2
		MCWB	6.7	7.7	10.6	13.9	17.8	20.9	21.2	20.6	18.7	16.1	12.2	8.6
	5%	DB	8.1	10.2	15.6	20.9	24.6	28.3	29.8	29.8	24.3	19.5	13.7	8.6
		MCWB	5.6	6.4	9.6	13.1	16.9	20.2	20.6	20.4	17.7	15.0	10.9	6.4
	10%	DB	5.9	8.3	13.4	18.8	22.7	26.4	28.1	27.7	22.2	17.6	11.9	6.6
		MCWB	3.9	5.2	8.4	12.1	15.8	19.1	19.9	19.6	16.6	14.0	9.9	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	9.5	12.3	16.3	19.8	22.7	23.6	23.0	20.5	17.9	13.9	10.8
		MCDB	11.7	14.5	18.1	23.8	26.5	29.4	30.2	29.6	27.2	22.8	17.6	13.6
	2%	WB	7.2	8.0	11.1	14.8	18.5	21.5	22.1	21.8	19.3	16.5	12.5	8.8
		MCDB	9.6	11.6	16.6	21.3	24.8	28.2	28.9	28.8	25.0	20.5	15.3	11.1
	5%	WB	5.7	6.7	10.0	13.6	17.4	20.6	21.3	21.0	18.2	15.4	11.2	6.7
		MCDB	7.6	9.7	14.8	19.5	23.4	27.2	28.2	28.0	22.9	19.0	13.5	8.2
	10%	WB	4.2	5.5	8.8	12.5	16.4	19.7	20.5	20.1	17.1	14.3	9.9	5.1
		MCDB	5.6	7.9	12.9	17.9	21.8	25.7	27.1	26.6	21.3	17.2	11.7	6.3
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.7	8.4	9.7	10.1	10.4	10.9	10.9	9.3	8.7	5.9	4.9
		MCDBR	8.2	9.8	12.0	12.8	13.1	12.8	13.4	14.0	12.0	11.2	8.7	8.1
		MCWBR	5.6	6.4	6.7	6.3	6.2	5.6	5.2	5.1	5.5	6.2	5.7	5.9
	5% WB	MCDBR	7.7	9.2	11.0	11.6	12.0	12.2	12.4	12.6	11.1	10.3	8.3	7.6
		MCWBR	5.5	6.3	6.4	6.0	6.1	5.6	5.4	5.4	5.4	6.0	5.6	5.8
Clear-Sky Solar Irradiance	taub		0.325	0.350	0.386	0.432	0.426	0.430	0.434	0.437	0.414	0.385	0.354	0.326
	taud		2.381	2.330	2.255	2.140	2.211	2.241	2.231	2.230	2.265	2.323	2.362	2.404
	Ebn at Noon		754	808	829	821	841	839	829	808	790	754	706	708
	Edh at Noon		72	93	116	143	138	134	134	129	114	93	74	64
All-Sky Solar Radiation	RadAvg		1.16	1.95	3.16	4.53	5.48	5.98	5.90	5.23	3.69	2.41	1.28	0.88
	RadStd		0.14	0.28	0.38	0.44	0.50	0.43	0.42	0.53	0.45	0.25	0.14	0.12