

NAGYKANIZSA, Hungary

WMO: 129250

Lat: 46.450N

Lon: 16.967E

Elev: 463

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	16.7	5.9	7.6	13.1	10.9	9.8	19.4	18.8	33.8	16.8	32.6	3.1	10	0.464

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.4	90.6	71.0	87.5	70.0	84.5	68.8	72.8	85.8	71.4	84.4	70.0	82.1	5.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.8	107.5	78.4	67.1	101.5	76.8	65.7	96.5	75.2	36.7	85.9	35.4	84.6	34.2	82.4	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.9	13.3	11.2	4.2	94.4	6.7	3.8	-0.6	97.1	-4.5	99.3	-8.3	101.5	-13.2	104.2		
(5)			3.6	75.8	6.6	1.5	-1.2	76.9	-5.0	77.8	-8.7	78.7	-13.5	79.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.2	32.1	35.2	42.9	51.9	59.6	66.3	69.4	68.6	59.9	51.3	42.5	33.8
	DBStd	14.86	7.86	8.50	7.71	6.65	6.05	6.11	5.39	5.42	5.95	7.26	7.75	7.69
	HDD50	2096	554	415	240	57	4	0	0	0	2	74	245	505
	HDD65	5462	1019	833	685	393	185	58	21	27	173	425	675	968
	CDD50	2539	0	2	20	115	302	488	601	575	299	115	20	2
	CDD65	428	0	0	0	0	18	95	157	137	20	1	0	0
	CDH74	5425	0	0	0	43	369	1202	1872	1646	278	15	0	0
	CDH80	1873	0	0	0	4	65	394	715	642	53	0	0	0
Wind	WSAvg	4.2	4.4	4.9	5.4	5.0	4.5	4.0	3.7	3.4	3.6	3.6	4.0	4.2
Precipitation	PrecAvg	29.6	1.4	1.7	1.6	2.0	2.7	3.1	3.1	3.0	3.5	2.8	2.6	2.1
	PrecMax	42.8	3.5	5.6	4.2	4.6	5.6	5.7	5.6	6.1	7.9	6.9	5.9	4.8
	PrecMin	18.1	0.2	0.1	0.0	0.2	0.9	1.2	1.0	0.2	1.1	0.1	0.1	0.2
	PrecStd	5.8	0.9	1.3	1.1	1.2	1.2	1.3	1.2	1.8	2.0	1.7	1.4	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.2	61.0	69.9	78.8	85.5	91.9	94.4	95.6	86.0	76.1	67.1	58.1
		MCWB	49.0	49.6	54.2	61.3	66.3	71.4	72.3	70.9	68.0	63.8	57.3	51.6
	2%	DB	51.9	56.6	65.6	74.3	81.5	88.2	90.4	90.6	80.7	71.8	62.3	53.1
		MCWB	45.9	47.5	52.4	57.6	64.7	70.3	71.3	70.6	66.6	61.6	55.0	48.4
	5%	DB	47.6	52.7	61.4	70.4	78.3	84.7	87.3	87.0	77.1	68.4	58.3	48.3
		MCWB	43.2	45.6	50.5	56.0	63.4	69.1	70.3	69.8	65.0	60.1	52.9	44.8
	10%	DB	43.5	48.6	57.1	66.7	74.7	81.3	84.0	83.1	73.2	64.3	54.7	44.3
		MCWB	40.3	42.9	48.1	54.0	61.5	67.3	68.9	68.8	62.9	57.6	50.7	41.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	50.9	55.6	62.0	68.8	74.0	75.2	74.6	69.8	65.2	58.4	51.9
		MCDB	55.9	59.5	66.4	75.8	81.3	87.1	88.6	87.1	81.5	73.7	65.3	57.4
	2%	WB	46.5	48.2	53.2	59.2	66.4	71.7	72.9	72.6	67.7	62.6	55.8	48.6
		MCDB	51.2	55.6	63.4	70.8	78.6	84.6	86.2	85.2	78.1	70.3	61.3	52.8
	5%	WB	43.6	45.8	51.2	57.1	64.3	70.1	71.4	71.1	66.0	60.5	53.4	45.2
		MCDB	47.1	51.9	59.7	67.5	75.9	82.4	84.6	83.8	75.0	67.2	58.1	48.0
	10%	WB	40.8	43.4	48.9	55.2	62.4	68.3	70.0	69.6	63.9	58.4	50.9	42.2
		MCDB	43.1	48.0	56.3	65.0	72.8	79.2	81.8	81.5	71.3	63.6	54.4	44.0
Mean Daily Temperature Range	5% DB	MDBR	12.6	16.6	19.7	21.9	22.7	22.8	23.4	24.1	21.3	20.3	14.7	11.9
		MCDBR	19.9	24.1	28.1	30.5	30.2	28.8	29.7	31.4	28.1	25.2	21.6	18.1
		MCWBR	14.3	15.7	16.3	15.7	15.0	12.9	12.8	13.5	14.8	15.8	14.9	13.6
	5% WB	MCDBR	18.7	22.5	25.3	26.3	26.6	26.8	26.9	28.0	25.6	23.7	20.1	17.0
MCWBR		13.9	15.1	14.9	13.9	13.8	12.5	12.5	13.3	14.0	15.1	14.0	13.1	
Clear-Sky Solar Irradiance	taub	0.330	0.355	0.391	0.439	0.429	0.432	0.436	0.440	0.420	0.389	0.358	0.330	
	taud	2.377	2.318	2.247	2.125	2.207	2.239	2.228	2.229	2.253	2.318	2.361	2.393	
	Ebn at Noon	239	255	262	259	266	266	263	256	249	239	225	224	
	Edh at Noon	23	30	37	46	44	43	43	41	37	30	24	21	
All-Sky Solar Radiation	RadAvg	381	631	1012	1432	1754	1918	1904	1686	1181	784	421	289	
	RadStd	51	93	123	143	150	141	130	174	147	86	51	45	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.97	N/A	N/A	+2.30	+0.86	N/A	N/A	N/A	+173	+112
(47) Regional (68 neighbors)		+0.97	N/A	N/A	+1.58	+0.90	+0.81	-187	-261	+166	+104

Nomenclature: See separate page