

KAPOSVAR, Hungary

WMO: 129300

Lat: 46.383N

Lon: 17.833E

Elev: 476

StdP: 14.45

Time Zone: 1.00 (EUC)

Period: 95-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	17.9	7.2	8.1	12.4	12.9	10.8	20.6	19.7	37.4	16.7	37.6	4.1	330	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	92.3	71.0	88.9	69.9	85.7	68.7	73.3	86.4	71.5	85.1	70.0	82.7	5.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.9	108.0	79.6	67.1	101.4	77.5	65.6	96.1	75.4	37.1	86.6	35.5	85.3	34.2	83.0	79.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.7	13.9	11.7	DB	3.9	97.0	9.1	3.4	-2.6	99.5	-7.9	101.5	-13.0	103.4	-19.6	105.9	
			WB	3.4	76.3	9.0	2.0	-3.1	77.8	-8.4	79.0	-13.4	80.1	-20.0	81.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.4	33.5	35.9	44.0	53.0	60.5	67.5	70.9	69.3	61.2	52.3	43.9	35.5	(6)
	DBStd	14.90	8.86	9.27	7.25	6.31	5.96	5.67	5.77	5.47	6.14	7.27	7.63	8.46	(7)
	HDD50	1893	512	398	210	41	2	0	0	0	1	63	211	455	(8)
	HDD65	5128	975	815	650	362	162	38	16	20	146	396	633	915	(9)
	CDD50	2766	2	3	25	130	329	524	649	599	338	134	28	5	(10)
	CDD65	526	0	0	0	1	23	112	200	154	33	3	0	0	(11)
	CDH74	6475	0	0	0	43	366	1293	2414	1897	432	30	0	0	(12)
	CDH80	2442	0	0	0	5	66	415	1038	805	113	0	0	0	(13)
(14) Wind	WSAvg	4.6	4.6	5.2	5.7	4.9	5.1	4.5	4.3	3.8	3.9	3.8	4.3	4.6	(14)
(15) Precipitation	PrecAvg	26.9	1.4	1.7	1.5	1.5	2.9	3.1	2.5	2.5	2.8	2.8	2.3	2.0	(15)
	PrecMax	38.8	2.6	3.5	3.9	3.1	7.0	5.6	6.2	5.4	6.6	6.0	4.5	4.5	(16)
	PrecMin	20.1	0.2	0.2	0.1	0.1	0.6	1.3	0.7	0.2	0.7	0.2	0.1	0.2	(17)
	PrecStd	4.4	0.7	1.0	0.9	0.8	1.7	1.3	1.6	1.5	1.6	1.5	1.1	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.0	61.0	70.8	78.8	85.3	91.8	96.6	97.5	88.0	77.6	67.5	61.2	(19)
		MCWB	50.2	50.2	54.6	60.8	66.3	72.0	70.6	70.6	67.1	63.2	57.5	53.0	(20)
	2%	DB	54.1	56.2	66.1	74.4	81.5	88.0	92.5	92.7	83.2	73.5	63.6	56.5	(21)
		MCWB	47.8	48.2	52.3	57.1	65.0	70.5	71.1	70.8	66.1	62.1	55.4	49.7	(22)
	5%	DB	50.8	52.7	61.9	71.2	78.1	84.7	89.5	88.1	79.1	69.7	60.4	52.3	(23)
		MCWB	45.6	45.9	50.2	55.9	63.1	69.0	70.3	69.3	64.3	60.3	53.7	47.1	(24)
	10%	DB	46.2	49.3	57.7	67.6	74.6	81.8	86.1	84.1	74.9	65.7	56.5	47.8	(25)
		MCWB	42.3	44.3	48.2	54.6	61.8	67.5	69.1	67.9	62.8	58.1	51.0	44.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	50.9	55.6	61.6	68.4	74.6	75.3	75.5	69.4	64.6	58.5	53.6	(27)
		MCDB	56.9	58.5	68.2	76.3	81.6	87.9	88.8	90.6	82.6	74.8	65.6	60.9	(28)
	2%	WB	48.2	48.7	53.1	58.7	66.2	71.9	73.4	72.9	67.4	62.7	56.0	50.3	(29)
		MCDB	53.4	55.1	63.8	69.9	79.0	85.1	87.3	85.4	80.0	71.8	62.7	55.9	(30)
	5%	WB	46.1	46.8	51.1	57.0	64.3	70.3	71.7	71.0	65.7	60.8	53.7	47.4	(31)
		MCDB	50.5	51.8	60.2	68.0	75.8	82.4	85.7	84.2	76.6	69.0	59.6	52.1	(32)
	10%	WB	42.8	44.6	48.9	55.4	62.6	68.5	70.1	69.2	63.7	58.7	51.3	44.1	(33)
		MCDB	45.7	48.5	56.4	66.2	72.6	79.5	82.7	82.1	72.2	64.8	56.0	47.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.9	14.1	18.2	22.5	21.2	21.5	23.3	23.8	20.7	19.8	14.7	11.4	(35)
		MCDBR	18.5	20.3	26.9	30.1	28.1	26.8	30.0	32.3	28.9	25.5	21.4	17.9	(36)
	5% WB	MCWBR	12.5	13.3	15.2	15.6	13.6	12.0	11.2	12.7	13.1	15.1	14.1	12.6	(37)
		MCWBR	17.8	17.7	23.9	26.1	25.5	25.3	26.4	27.5	24.9	24.1	20.4	17.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.334	0.359	0.395	0.446	0.433	0.434	0.440	0.444	0.425	0.391	0.359	0.333	(40)
		taud	2.369	2.297	2.228	2.096	2.190	2.227	2.210	2.210	2.229	2.308	2.350	2.373	(41)
	Ebn at Noon		237	253	261	257	265	265	261	255	248	238	224	222	(42)
		Edh at Noon	24	31	38	48	45	43	43	42	38	30	24	21	(43)
(44) All-Sky Solar Radiation	RadAvg		375	627	1009	1441	1757	1920	1909	1698	1188	789	431	287	(44)
	RadStd		50	94	127	141	155	142	134	173	144	85	48	44	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)	+1.04	N/A	N/A	N/A	+0.85	+0.83	-198	-284	+164	+99	

Nomenclature: See separate page