

KAPOSVAR, Hungary

WMO: 129300

Lat: 46.383N

Lon: 17.833E

Elev: 145

StdP: 99.60

Time Zone: 1.00 (EUC)

Period: 95-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.9	-7.8	-13.8	1.2	-10.9	-10.6	1.5	-6.4	8.8	3.0	7.4	3.1	1.8	330	0.457

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	33.5	21.7	31.6	21.1	29.8	20.4	22.9	30.2	22.0	29.5	21.1	28.2	2.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.5	15.4	26.4	19.5	14.5	25.3	18.7	13.7	24.1	68.5	30.3	64.8	29.6	61.7	28.3	26.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.2	5.2	-15.6	36.1	5.0	1.9	-19.2	37.5	-22.2	38.6	-25.0	39.7	-28.6	41.1		
(5)			-15.9	24.6	5.0	1.1	-19.5	25.4	-22.4	26.1	-25.2	26.7	-28.9	27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	0.9	2.2	6.7	11.7	15.9	19.7	21.6	20.7	16.2	11.3	6.6	1.9
	DBStd	8.28	4.92	5.15	4.03	3.51	3.31	3.15	3.20	3.04	3.41	4.04	4.24	4.70
	HDD10.0	1052	284	221	117	23	1	0	0	0	1	35	117	253
	HDD18.3	2849	542	453	361	201	90	21	9	11	81	220	352	508
	CDD10.0	1537	1	2	14	72	183	291	361	333	188	74	16	3
	CDD18.3	292	0	0	0	1	13	62	111	86	18	2	0	0
	CDH23.3	3597	0	0	0	24	203	718	1341	1054	240	17	0	0
	CDH26.7	1357	0	0	0	3	37	231	577	447	63	0	0	0
Wind	WSAvg	2.0	2.1	2.3	2.5	2.2	2.3	2.0	1.9	1.7	1.7	1.7	1.9	2.1
Precipitation	PrecAvg	684	35	42	37	37	73	79	63	63	70	71	59	50
	PrecMax	985	65	88	100	79	179	143	158	138	167	152	114	114
	PrecMin	510	6	6	3	3	16	32	18	6	17	4	2	4
	PrecStd	111	19	26	24	20	42	32	40	39	40	38	29	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.4	16.1	21.5	26.0	29.6	33.2	35.9	36.4	31.1	25.3	19.7	16.2
		MCWB	10.1	10.1	12.5	16.0	19.0	22.2	21.4	21.5	19.5	17.3	14.2	11.7
	2%	DB	12.3	13.4	19.0	23.6	27.5	31.1	33.6	33.7	28.5	23.0	17.5	13.6
		MCWB	8.8	9.0	11.3	13.9	18.4	21.4	21.7	21.5	18.9	16.7	13.0	9.9
	5%	DB	10.4	11.5	16.6	21.8	25.6	29.3	32.0	31.2	26.2	21.0	15.8	11.3
		MCWB	7.6	7.7	10.1	13.3	17.3	20.5	21.3	20.7	17.9	15.7	12.0	8.4
	10%	DB	7.9	9.6	14.3	19.8	23.7	27.7	30.1	28.9	23.9	18.7	13.6	8.8
		MCWB	5.7	6.9	9.0	12.5	16.6	19.7	20.6	20.0	17.1	14.5	10.6	6.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.5	13.1	16.4	20.2	23.6	24.1	24.2	20.8	18.1	14.7	12.0
		MCDB	13.8	14.7	20.1	24.6	27.6	31.1	31.5	32.6	28.1	23.8	18.7	16.1
	2%	WB	9.0	9.3	11.7	14.8	19.0	22.2	23.0	22.7	19.7	17.0	13.3	10.2
		MCDB	11.9	12.8	17.7	21.0	26.1	29.5	30.7	29.7	26.7	22.1	17.1	13.3
	5%	WB	7.8	8.2	10.6	13.9	18.0	21.3	22.0	21.7	18.7	16.0	12.1	8.6
		MCDB	10.3	11.0	15.6	20.0	24.3	28.0	29.8	29.0	24.8	20.6	15.3	11.2
	10%	WB	6.0	7.0	9.4	13.0	17.0	20.3	21.2	20.7	17.6	14.9	10.7	6.7
		MCDB	7.6	9.2	13.6	19.0	22.6	26.4	28.2	27.8	22.3	18.2	13.3	8.6
Mean Daily Temperature Range	5% DB	MDBR	6.6	7.8	10.1	12.5	11.8	11.9	12.9	13.2	11.5	11.0	8.2	6.3
		MCDBR	10.3	11.3	14.9	16.7	15.6	14.9	16.6	17.9	16.1	14.2	11.9	9.9
		MCWBR	6.9	7.4	8.4	8.7	7.6	6.7	6.2	7.1	7.3	8.4	7.8	7.0
	5% WB	MCDBR	9.9	9.9	13.3	14.5	14.1	14.0	14.7	15.3	13.9	13.4	11.3	9.7
MCWBR		6.9	6.7	7.8	7.9	7.1	6.8	6.1	6.9	6.6	8.0	7.6	6.9	
Clear-Sky Solar Irradiance	taub	0.334	0.359	0.395	0.446	0.433	0.434	0.440	0.444	0.425	0.391	0.359	0.333	
	taud	2.369	2.297	2.228	2.096	2.190	2.227	2.210	2.210	2.229	2.308	2.350	2.373	
	Ebn at Noon	748	799	822	810	836	836	824	803	781	751	706	701	
	Edh at Noon	75	97	120	150	141	137	137	132	119	95	76	67	
All-Sky Solar Radiation	RadAvg	1.18	1.98	3.18	4.54	5.54	6.05	6.02	5.35	3.75	2.49	1.36	0.90	
	RadStd	0.16	0.29	0.40	0.44	0.49	0.45	0.42	0.55	0.45	0.27	0.15	0.14	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (52 neighbors)	+0.58	N/A	N/A	N/A	+0.47	+0.46	-110	-158	+91	+55

Nomenclature: See separate page