

TASZAR, Hungary

WMO: 129320

Lat: 46.393N

Lon: 17.917E

Elev: 538

StdP: 14.41

Time Zone: 1.00 (EUC)

Period: 96-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	15.6	6.4	7.8	15.9	10.3	9.5	18.9	26.3	30.6	22.8	31.0	2.9	60	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.6	89.7	69.8	86.8	68.9	83.9	67.6	72.2	84.4	70.5	82.6	69.1	80.6	7.6	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.2	105.7	78.0	66.5	99.5	75.6	65.0	94.4	73.7	36.2	84.6	34.7	82.3	33.5	80.9	79.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.9	18.3	15.4	DB	3.3	94.7	8.1	3.2	-2.5	97.0	-7.2	98.8	-11.8	100.6	-17.6	102.9
			WB	2.8	75.0	8.0	1.4	-3.0	76.1	-7.7	76.9	-12.2	77.7	-18.0	78.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	31.5	34.8	42.5	51.5	61.7	67.1	69.1	69.7	60.2	52.8	43.6	32.6
	DBStd	15.51	7.91	9.40	8.20	7.24	6.21	6.25	5.16	5.22	5.57	8.21	8.88	7.94
	HDD50	2173	574	429	258	68	2	0	0	0	1	68	233	540
	HDD65	5408	1039	845	699	407	139	47	20	18	164	382	643	1005
	CDD50	2721	0	4	24	112	363	515	593	609	306	155	40	0
	CDD65	480	0	0	0	1	35	112	148	163	18	3	0	0
	CDH74	5099	0	0	0	27	472	1243	1455	1661	221	20	0	0
	CDH80	1626	0	0	0	0	91	416	486	610	23	0	0	0
	WSAvg	6.1	6.0	6.9	7.6	7.5	6.5	5.9	6.1	5.0	5.3	5.4	6.1	5.6
	PrecAvg	26.9	1.4	1.7	1.5	1.5	2.9	3.1	2.5	2.5	2.8	2.8	2.3	2.0
(15) Precipitation	PrecMax	38.8	2.6	3.5	3.9	3.1	7.0	5.6	6.2	5.4	6.6	6.0	4.5	4.5
	PrecMin	20.1	0.2	0.2	0.1	0.1	0.6	1.3	0.7	0.2	0.7	0.2	0.1	0.2
	PrecStd	4.4	0.7	1.0	0.9	0.8	1.7	1.3	1.6	1.5	1.6	1.5	1.1	1.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.0	62.2	68.4	77.5	86.3	92.3	91.7	94.9	82.6	76.7	68.3	52.0
		MCWB	49.3	49.9	52.5	59.7	66.4	69.4	70.8	69.5	65.3	64.0	57.3	47.1
	2%	DB	50.2	57.7	64.6	73.0	82.4	88.7	88.6	89.8	79.6	73.1	64.0	49.1
		MCWB	45.0	48.3	52.1	57.7	64.5	69.6	70.9	68.7	65.5	62.0	55.0	45.1
	5%	DB	46.8	53.5	60.5	69.0	79.4	85.1	85.5	86.7	76.6	69.5	60.4	46.6
		MCWB	42.9	46.4	50.1	55.6	63.0	68.6	69.5	68.0	64.1	60.1	53.2	41.8
	10%	DB	43.1	48.6	56.7	65.1	75.9	81.3	82.3	82.8	72.7	65.6	56.5	44.6
		MCWB	40.2	42.8	47.9	53.0	61.5	66.8	67.6	66.8	62.1	58.4	51.3	42.7
	0.4%	WB	49.2	50.8	55.3	61.9	69.3	72.9	75.1	74.2	68.7	65.2	58.0	48.2
		MCDB	55.3	60.3	64.7	72.1	80.8	85.5	86.7	86.3	78.1	74.3	65.9	50.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.5	48.8	52.7	59.1	66.3	71.1	72.4	71.3	66.9	63.0	55.6	45.9
		MCDB	49.7	57.1	62.1	71.0	77.8	84.2	84.3	83.2	76.9	71.2	62.2	47.9
	5%	WB	43.0	46.3	50.9	56.9	64.4	69.5	70.7	69.6	65.1	60.8	53.8	44.2
		MCDB	46.4	52.6	59.2	66.7	76.1	83.2	82.4	81.3	74.1	67.8	60.0	46.0
	10%	WB	40.3	43.5	48.7	54.7	62.7	67.8	69.1	68.2	63.1	58.8	51.5	42.0
		MCDB	42.8	48.2	55.5	62.9	73.9	79.7	79.6	79.3	70.6	64.7	56.0	44.0
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	15.2	17.7	18.9	21.2	21.2	20.1	21.6	19.4	18.0	13.4	11.2
		MCDBR	17.4	21.0	24.0	25.5	27.1	26.8	25.3	28.2	25.1	21.9	18.2	16.3
		MCWBR	12.3	12.9	13.7	12.8	12.3	10.9	10.6	10.4	12.7	12.0	11.3	12.6
	5% WB	MCDBR	17.0	20.3	21.6	23.2	23.5	25.1	23.2	23.1	22.7	21.0	17.6	12.0
		MCWBR	12.2	12.8	12.7	12.4	11.9	11.0	10.7	10.3	12.3	12.0	11.2	9.9
(40) Clear-Sky Solar Irradiance	taub		0.333	0.358	0.393	0.444	0.432	0.432	0.438	0.442	0.423	0.389	0.358	0.332
	taud		2.372	2.301	2.232	2.101	2.194	2.230	2.212	2.212	2.232	2.312	2.354	2.376
	Ebn at Noon		238	254	261	257	266	266	262	255	248	239	224	223
	Edh at Noon		23	31	38	47	44	43	43	42	38	30	24	21
(44) All-Sky Solar Radiation	RadAvg		373	627	1009	1444	1757	1920	1908	1700	1190	790	433	286
	RadStd		50	94	128	141	156	142	135	173	143	85	47	44

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		+1.04	N/A	N/A	N/A	+0.86	+0.86	-200	-286	+164	+97

Nomenclature: See separate page