

TASZAR, Hungary

WMO: 129320

Lat: 46.393N

Lon: 17.917E

Elev: 164

StdP: 99.37

Time Zone: 1.00 (EUC)

Period: 96-05

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.1	-14.2	1.1	-8.9	-12.0	1.4	-7.3	11.7	-0.8	10.2	-0.6	1.3	60	0.495

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.0	32.1	21.0	30.5	20.5	28.8	19.8	22.3	29.1	21.4	28.1	20.6	27.0	3.4	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.1	15.1	25.6	19.2	14.2	24.2	18.3	13.5	23.2	66.2	29.2	62.8	27.9	60.0	27.1	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.2	6.9	-15.9	34.8	4.5	1.8	-19.2	36.1	-21.8	37.1	-24.3	38.1	-27.6	39.4		
(5)			-16.2	23.9	4.5	0.8	-19.4	24.5	-22.0	24.9	-24.5	25.4	-27.8	26.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	-0.3	1.6	5.8	10.8	16.5	19.5	20.6	20.9	15.6	11.5	6.4	0.3
	DBStd	8.62	4.40	5.22	4.56	4.02	3.45	3.47	2.87	2.90	3.09	4.56	4.93	4.41
	HDD10.0	1207	319	238	143	38	1	0	0	0	1	38	129	300
	HDD18.3	3004	577	469	388	226	77	26	11	10	91	212	357	558
	CDD10.0	1512	0	2	13	62	202	286	329	338	170	86	22	0
	CDD18.3	267	0	0	0	1	19	62	82	91	10	2	0	0
	CDH23.3	2833	0	0	0	15	262	691	808	923	123	11	0	0
CDH26.7	903	0	0	0	0	51	231	270	339	13	0	0	0	
Wind	WSAvg	2.7	2.7	3.1	3.4	3.4	2.9	2.6	2.7	2.2	2.4	2.4	2.7	2.5
Precipitation	PrecAvg	684	35	42	37	37	73	79	63	63	70	71	59	50
	PrecMax	985	65	88	100	79	179	143	158	138	167	152	114	114
	PrecMin	510	6	6	3	3	16	32	18	6	17	4	2	4
	PrecStd	111	19	26	24	20	42	32	40	39	40	38	29	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.4	16.8	20.2	25.3	30.2	33.5	33.2	34.9	28.1	24.8	20.1	11.1
		MCWB	9.6	9.9	11.4	15.4	19.1	20.8	21.6	20.8	18.5	17.8	14.1	8.4
	2%	DB	10.1	14.3	18.1	22.8	28.0	31.5	31.4	32.1	26.4	22.8	17.8	9.5
		MCWB	7.2	9.1	11.1	14.3	18.0	20.9	21.6	20.4	18.6	16.7	12.8	7.3
	5%	DB	8.2	12.0	15.8	20.6	26.3	29.5	29.7	30.4	24.8	20.8	15.8	8.1
		MCWB	6.0	8.0	10.1	13.1	17.2	20.3	20.8	20.0	17.8	15.6	11.8	5.4
	10%	DB	6.2	9.2	13.7	18.4	24.4	27.4	27.9	28.2	22.6	18.6	13.6	7.0
		MCWB	4.5	6.0	8.8	11.7	16.4	19.3	19.8	19.3	16.7	14.7	10.7	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	10.4	13.0	16.6	20.7	22.7	23.9	23.5	20.4	18.4	14.4	9.0
		MCDB	12.9	15.7	18.2	22.3	27.1	29.7	30.4	30.1	25.6	23.5	18.8	10.5
	2%	WB	7.5	9.3	11.5	15.1	19.0	21.7	22.4	21.8	19.4	17.2	13.1	7.7
		MCDB	9.9	14.0	16.7	21.6	25.5	29.0	29.1	28.5	25.0	21.8	16.8	8.8
	5%	WB	6.1	8.0	10.5	13.8	18.0	20.8	21.5	20.9	18.4	16.0	12.1	6.8
		MCDB	8.0	11.5	15.1	19.3	24.5	28.4	28.0	27.4	23.4	19.9	15.6	7.8
	10%	WB	4.6	6.4	9.3	12.6	17.0	19.9	20.6	20.1	17.3	14.9	10.8	5.6
		MCDB	6.0	9.0	13.1	17.2	23.3	26.5	26.4	26.3	21.4	18.2	13.3	6.7
Mean Daily Temperature Range	5% DB	MDBR	6.1	8.4	9.9	10.5	11.8	11.8	11.2	12.0	10.8	10.0	7.5	6.2
		MCDBR	9.6	11.7	13.3	14.1	15.1	14.9	14.1	15.6	13.9	12.2	10.1	9.1
		MCWBR	6.8	7.1	7.6	7.1	6.8	6.1	5.9	5.8	7.0	6.7	6.3	7.0
	5% WB	MCDBR	9.4	11.3	12.0	12.9	13.1	13.9	12.9	12.8	12.6	11.7	9.8	6.7
		MCWBR	6.8	7.1	7.0	6.9	6.6	6.1	6.0	5.7	6.8	6.7	6.2	5.5
Clear-Sky Solar Irradiance	taub	0.333	0.358	0.393	0.444	0.432	0.432	0.438	0.442	0.423	0.389	0.358	0.332	
	taud	2.372	2.301	2.232	2.101	2.194	2.230	2.212	2.212	2.232	2.312	2.354	2.376	
	Ebn at Noon	749	801	823	811	837	837	826	805	783	753	707	703	
	Edh at Noon	74	97	119	149	140	136	137	132	119	95	76	67	
All-Sky Solar Radiation	RadAvg	1.18	1.98	3.18	4.55	5.54	6.05	6.02	5.36	3.75	2.49	1.36	0.90	
	RadStd	0.16	0.29	0.40	0.44	0.49	0.45	0.43	0.54	0.45	0.27	0.15	0.14	

Historical Trends

		DBAvg	Heating		Cooling		Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		+0.58	N/A	N/A	N/A	+0.48	+0.48	-111	-159	+91

Nomenclature: See separate page