

SIOFOK, Hungary

WMO: 129350

Lat: 46.9106N

Lon: 18.0407E

Elev: 358

StdP: 14.51

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.7	19.2	8.9	8.8	17.2	13.1	10.8	20.8	32.8	34.1	29.4	33.9	5.6	70	0.497

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.2	89.4	73.1	86.4	72.0	83.7	70.7	75.3	85.8	73.4	83.9	71.7	82.0	6.6	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
71.7	118.5	83.5	69.6	110.3	81.0	67.9	103.8	78.8	38.9	85.9	37.2	84.1	35.6	82.3	81.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.9	24.9	21.4	10.3	95.0	7.2	3.1	5.1	97.2	0.9	99.0	-3.2	100.8	-8.4	103.0
			9.1	78.3	7.1	1.9	4.0	79.7	-0.1	80.8	-4.1	81.8	-9.3	83.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.4	32.2	35.3	43.6	54.3	63.2	69.9	73.3	72.4	63.2	53.7	43.8	34.5
	DBStd	15.97	6.98	7.91	7.20	6.74	5.90	6.03	5.36	5.17	5.77	6.86	6.99	7.20
	HDD50	1949	551	414	220	34	0	0	0	0	41	207	482	
	HDD65	5007	1016	833	664	323	105	22	4	5	101	352	636	946
	CDD50	3184	0	1	20	164	411	597	721	694	397	157	21	1
	CDD65	766	0	0	0	4	50	169	260	233	48	2	0	0
	CDH74	5432	0	0	0	33	303	1208	1980	1680	221	7	0	0
	CDH80	1599	0	0	0	4	47	340	643	531	34	0	0	0
(14) Wind	WSAvg	8.1	7.9	8.3	9.2	8.6	8.8	8.5	8.6	7.4	7.9	6.9	7.5	7.7
(15) Precipitation	PrecAvg	23.9	1.4	1.3	1.3	1.6	2.4	2.6	2.4	2.6	2.5	2.1	2.0	1.8
	PrecMax	37.2	3.2	3.3	3.7	4.1	7.0	6.3	5.7	8.3	7.0	5.2	4.1	4.9
	PrecMin	14.3	0.2	0.1	0.1	0.0	0.5	0.4	0.8	0.1	0.2	0.0	0.0	0.1
	PrecStd	5.4	0.9	1.0	0.9	1.1	1.3	1.3	1.2	1.8	1.7	1.4	1.0	1.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.8	56.7	65.8	78.3	84.6	91.4	93.6	93.3	83.7	74.7	65.9	56.4
		MCWB	46.6	48.1	52.6	61.5	66.3	72.9	73.6	73.4	68.5	63.0	56.4	50.2
	2%	DB	46.9	52.1	60.6	72.5	80.6	87.4	89.3	89.0	79.5	70.2	59.7	48.9
		MCWB	42.8	45.4	51.2	59.4	66.2	72.5	73.5	73.1	67.7	61.5	53.6	45.4
	5%	DB	43.7	48.6	57.2	68.5	77.3	83.9	86.2	85.5	76.1	66.8	56.1	45.2
		MCWB	40.5	43.6	49.1	57.1	65.2	71.1	72.3	71.9	65.8	60.2	51.7	42.6
	10%	DB	41.1	45.1	53.9	65.1	74.1	80.8	83.5	82.5	73.1	63.6	53.2	42.9
		MCWB	38.8	41.4	47.6	55.7	63.5	69.3	70.9	70.2	64.2	58.5	50.0	40.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.2	48.7	54.4	64.2	70.8	76.9	78.1	77.4	71.0	65.1	56.8	50.7
		MCDB	52.2	54.8	62.9	74.0	79.5	86.7	88.8	87.9	80.2	71.4	62.9	55.6
	2%	WB	43.2	46.0	51.8	60.7	68.2	73.9	75.3	75.1	68.7	62.9	54.5	45.8
		MCDB	46.1	51.2	59.1	70.6	77.4	84.4	85.8	85.7	77.5	68.3	59.1	48.3
	5%	WB	40.9	43.9	49.9	58.4	66.1	72.0	73.4	73.0	66.9	60.9	52.3	43.2
		MCDB	43.3	48.0	56.0	66.7	75.4	82.5	83.9	83.5	74.7	65.6	55.6	44.8
	10%	WB	38.9	41.7	48.0	56.3	64.2	70.1	71.6	71.0	65.0	58.8	50.3	41.1
		MCDB	40.8	44.9	53.3	63.9	72.8	79.8	82.0	80.9	71.9	63.2	53.0	42.7
(35) Mean Daily Temperature Range	5% DB	MDBR	7.9	10.4	12.4	14.6	15.3	15.1	15.2	15.8	13.7	13.2	9.1	7.2
		MCDBR	11.4	15.2	18.1	21.2	21.3	20.1	20.4	20.9	18.8	17.5	14.2	10.7
	5% WB	MCWBR	8.2	10.1	10.9	11.9	11.7	10.4	10.6	11.3	10.8	10.5	9.2	8.3
		MCWBR	11.2	13.7	16.8	19.0	18.9	18.9	19.0	19.4	17.3	15.7	13.3	10.5
(40) Clear-Sky Solar Irradiance	taub		0.332	0.357	0.394	0.443	0.433	0.433	0.442	0.445	0.423	0.390	0.360	0.332
		taud	2.362	2.305	2.233	2.112	2.200	2.235	2.211	2.214	2.241	2.315	2.348	2.372
	Ebn at Noon		236	253	260	257	265	265	260	254	247	237	221	220
		Edh at Noon	23	30	38	47	44	43	43	42	37	30	24	21
(44) All-Sky Solar Radiation	RadAvg		355	612	996	1448	1748	1902	1877	1675	1180	770	415	270
	RadStd		43	89	131	139	167	139	137	166	139	81	42	38

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.22	N/A	N/A	N/A	+1.22	+1.24	N/A	N/A	N/A	N/A
(47)	Regional (66 neighbors)	+1.03	N/A	N/A	N/A	+0.90	+0.86	-211	-297	+173	+99

Nomenclature: See separate page