

PECS POGANY, Hungary

WMO: 129420

Lat: 45.9950N

Lon: 18.2350E

Elev: 666

StdP: 14.35

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.5	18.5	7.9	8.5	17.7	12.0	10.4	21.1	23.8	32.7	21.1	34.2	6.2	70	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	90.2	69.8	87.5	69.1	84.6	68.0	72.2	85.4	70.7	83.7	69.3	81.8	6.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.8	104.8	79.1	66.2	98.9	77.2	64.7	93.7	75.6	36.3	85.4	34.9	83.9	33.7	82.1	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
19.8	16.9	14.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			9.8	94.1	4.6	2.9	6.5	96.2	3.8	97.9	1.2	99.5	-2.2	101.6
			8.9	75.2	4.5	1.4	5.7	76.2	3.0	77.1	0.5	77.8	-2.8	78.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.9	32.7	36.3	44.3	53.7	61.7	68.1	71.7	71.5	62.5	53.7	43.6	34.3	
	DBStd	15.65	8.18	8.91	8.03	7.17	6.65	6.55	5.75	5.98	6.55	7.63	7.99	7.97	
	HDD50	1944	536	387	211	45	3	0	0	0	1	51	221	489	
	HDD65	5073	1001	803	643	343	144	41	12	13	124	354	642	953	
	CDD50	3013	1	4	33	155	366	545	672	665	376	166	29	1	
	CDD65	664	0	0	0	3	41	136	219	213	49	3	0	0	
	CDH74	5850	0	0	0	34	330	1179	2016	1918	352	21	0	0	
	CDH80	1923	0	0	0	2	51	351	731	712	76	0	0	0	
Wind	WSAvg	6.6	6.7	7.4	8.0	7.6	7.0	6.2	6.2	5.7	6.0	6.0	6.5	6.5	
Precipitation	PrecAvg	25.9	1.4	1.5	1.4	2.0	2.7	3.3	2.6	2.5	2.4	1.8	2.2	1.8	
	PrecMax	38.6	4.2	5.4	4.2	5.8	8.9	6.7	8.6	5.8	7.9	5.4	6.1	4.6	
	PrecMin	15.7	0.2	0.1	0.0	0.2	0.2	0.8	0.3	0.1	0.0	0.0	0.0	0.0	
	PrecStd	5.4	0.9	1.0	0.9	1.2	1.6	1.6	1.6	1.5	1.7	1.3	1.3	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	61.1	69.3	78.4	84.5	91.0	94.3	95.1	86.7	77.0	66.4	56.5	
		MCWB	48.7	50.0	53.2	60.6	65.1	71.3	70.3	69.5	66.0	63.0	56.9	51.0	
	2%	DB	50.9	56.2	64.9	73.3	80.9	87.5	89.9	90.7	81.8	72.7	62.0	51.6	
		MCWB	45.7	47.5	51.5	57.2	64.3	70.4	69.8	69.5	64.8	61.1	54.8	47.3	
	5%	DB	47.5	52.1	60.7	69.8	77.8	84.2	87.2	87.4	78.0	69.4	58.1	48.1	
		MCWB	43.6	45.6	49.6	55.7	62.8	69.1	69.1	68.7	63.8	59.4	52.7	44.7	
	10%	DB	44.0	48.4	56.7	66.3	74.3	81.0	84.2	83.9	74.5	65.7	54.9	44.9	
		MCWB	40.7	43.1	47.6	53.9	61.1	67.2	68.0	67.4	62.3	57.7	50.5	42.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.3	50.9	55.0	61.9	67.8	74.0	74.1	74.0	68.4	64.6	58.0	51.2
			MCDB	54.4	58.7	65.8	75.6	80.5	87.0	86.8	87.1	80.4	74.2	64.6	55.8
2%		WB	46.2	48.3	52.5	59.0	65.6	71.8	72.0	71.7	66.5	62.2	55.4	47.7	
		MCDB	50.1	54.9	62.0	70.3	77.6	84.4	85.6	84.7	78.1	70.5	60.7	50.9	
5%		WB	43.8	46.0	50.6	56.8	64.0	70.1	70.6	70.1	64.9	60.2	53.1	45.0	
		MCDB	47.0	51.0	59.1	66.9	75.3	82.1	83.8	83.5	75.6	67.8	57.6	47.6	
10%		WB	41.2	43.7	48.4	54.9	62.0	68.2	69.1	68.6	63.4	58.3	50.8	42.5	
		MCDB	43.7	47.9	55.9	64.3	72.3	79.2	81.5	81.3	72.5	64.7	54.4	44.7	
Mean Daily Temperature Range	5% DB	MDBR	9.5	12.1	15.4	17.0	17.4	18.0	18.6	18.7	16.5	15.7	11.6	9.1	
		MCDBR	14.5	17.6	21.1	22.1	21.8	21.7	22.7	23.0	21.6	19.8	16.9	13.8	
		MCWBR	10.6	11.7	11.8	11.4	10.7	10.2	9.1	9.6	9.5	10.6	11.0	10.4	
	5% WB	MCDBR	14.1	16.4	19.3	19.9	20.5	20.8	20.9	20.9	19.5	18.8	16.0	13.3	
		MCWBR	10.5	11.3	11.3	10.8	10.8	10.3	9.4	9.7	9.3	10.4	10.7	10.3	
Clear-Sky Solar Irradiance	taub	0.332	0.356	0.390	0.441	0.429	0.428	0.434	0.437	0.420	0.386	0.355	0.332		
	taud	2.382	2.309	2.247	2.108	2.202	2.241	2.221	2.222	2.239	2.326	2.370	2.386		
	Ebn at Noon	240	256	263	259	267	267	264	257	250	241	228	226		
	Edh at Noon	23	30	37	47	44	43	43	42	37	30	24	21		
All-Sky Solar Radiation	RadAvg	376	630	1019	1452	1767	1935	1936	1727	1203	808	455	295		
	RadStd	54	94	131	139	156	149	140	174	141	85	45	45		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.22	N/A	N/A	N/A	N/A	N/A	-239	-335	+184	N/A
(47)	Regional (47 neighbors)	+1.12	N/A	N/A	N/A	+0.85	+0.90	-196	-290	+166	+97

Nomenclature: See separate page