

PECS POGANY, Hungary

WMO: 129420

Lat: 45.9950N

Lon: 18.2350E

Elev: 203

StdP: 98.91

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.7	-7.5	-13.4	1.2	-7.9	-11.1	1.5	-6.1	10.6	0.4	9.4	1.2	2.8	70	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	32.3	21.0	30.8	20.6	29.2	20.0	22.3	29.7	21.5	28.7	20.7	27.7	3.0	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	15.0	26.1	19.0	14.1	25.1	18.2	13.4	24.2	66.5	29.7	63.4	28.8	60.6	27.8	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.9	7.6	6.5	DB	-12.3	34.5	2.6	1.6	-14.2	35.7	-15.7	36.6	-17.1	37.5	-19.0	38.7	(4)
(5)			WB	-12.8	24.0	2.5	0.8	-14.6	24.6	-16.1	25.0	-17.5	25.5	-19.3	26.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	0.4	2.4	6.8	12.0	16.5	20.1	22.1	21.9	16.9	12.0	6.4	1.3	(6)	
	DBStd	8.69	4.54	4.95	4.46	3.98	3.70	3.64	3.19	3.32	3.64	4.24	4.44	4.43	(7)	
	HDD10.0	1080	298	215	117	25	2	0	0	0	1	28	123	272	(8)	
	HDD18.3	2818	556	446	357	191	80	23	7	7	69	197	357	529	(9)	
	CDD10.0	1674	1	2	18	86	203	303	373	369	209	92	16	1	(10)	
	CDD18.3	369	0	0	0	2	23	76	122	118	27	2	0	0	(11)	
	CDH23.3	3250	0	0	0	19	183	655	1120	1066	196	12	0	0	(12)	
	CDH26.7	1068	0	0	0	1	28	195	406	396	42	0	0	0	(13)	
(14) Wind	WSAvg	3.0	3.0	3.3	3.6	3.4	3.1	2.8	2.8	2.6	2.7	2.7	2.9	2.9	(14)	
(15) Precipitation	PrecAvg	658	36	37	36	51	69	84	65	63	61	46	57	46	(15)	
	PrecMax	981	106	136	106	147	227	169	219	148	201	137	155	117	(16)	
	PrecMin	399	4	2	1	6	6	20	7	3	1	0	1	1	(17)	
	PrecStd	136	22	25	22	31	41	40	41	37	42	32	34	28	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	16.2	20.7	25.8	29.2	32.8	34.6	35.1	30.4	25.0	19.1	13.6	(19)	
		MCWB	9.3	10.0	11.8	15.9	18.4	21.8	21.3	20.8	18.9	17.2	13.8	10.6	(20)	
	2%	DB	10.5	13.5	18.3	23.0	27.2	30.8	32.2	32.6	27.7	22.6	16.6	10.9	(21)	
		MCWB	7.6	8.6	10.8	14.0	17.9	21.4	21.0	20.8	18.2	16.2	12.7	8.5	(22)	
	5%	DB	8.6	11.1	16.0	21.0	25.4	29.0	30.7	30.8	25.6	20.8	14.5	8.9	(23)	
		MCWB	6.5	7.5	9.8	13.2	17.1	20.6	20.6	20.4	17.7	15.2	11.5	7.0	(24)	
	10%	DB	6.7	9.1	13.7	19.0	23.5	27.2	29.0	28.8	23.6	18.7	12.7	7.2	(25)	
		MCWB	4.8	6.2	8.6	12.2	16.2	19.6	20.0	19.7	16.8	14.3	10.3	5.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	10.5	12.8	16.6	19.9	23.3	23.4	23.3	20.2	18.1	14.4	10.7	(27)	
		MCDB	12.5	14.8	18.8	24.2	27.0	30.5	30.4	30.6	26.9	23.4	18.1	13.2	(28)	
	2%	WB	7.9	9.1	11.4	15.0	18.7	22.1	22.2	22.1	19.1	16.8	13.0	8.7	(29)	
		MCDB	10.1	12.7	16.7	21.3	25.4	29.1	29.8	29.3	25.6	21.4	15.9	10.5	(30)	
	5%	WB	6.5	7.8	10.3	13.8	17.8	21.2	21.4	21.2	18.3	15.7	11.7	7.2	(31)	
		MCDB	8.4	10.6	15.0	19.4	24.1	27.9	28.8	28.6	24.2	19.9	14.2	8.7	(32)	
	10%	WB	5.1	6.5	9.1	12.7	16.7	20.1	20.6	20.3	17.4	14.6	10.4	5.8	(33)	
		MCDB	6.5	8.8	13.3	18.0	22.4	26.2	27.5	27.4	22.5	18.2	12.5	7.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.3	6.7	8.5	9.5	9.7	10.0	10.3	10.4	9.2	8.7	6.4	5.0	(35)	
		MCDBR	8.1	9.8	11.7	12.3	12.1	12.0	12.6	12.8	12.0	11.0	9.4	7.7	(36)	
	5% WB	MCWBR	5.9	6.5	6.6	6.4	5.9	5.6	5.1	5.4	5.3	5.9	6.1	5.8	(37)	
		MCWBR	7.8	9.1	10.7	11.1	11.4	11.5	11.6	11.6	10.8	10.4	8.9	7.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.332	0.356	0.390	0.441	0.429	0.428	0.434	0.437	0.420	0.386	0.355	0.332	(40)	
		taud	2.382	2.309	2.247	2.108	2.202	2.241	2.221	2.222	2.239	2.326	2.370	2.386	(41)	
	Ebn at Noon		757	807	830	815	841	842	831	811	789	760	719	712	(42)	
		Edh at Noon	74	96	118	148	140	135	136	131	118	94	75	67	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.18	1.99	3.21	4.58	5.57	6.10	6.10	5.44	3.79	2.55	1.43	0.93	(44)	
	RadStd		0.17	0.29	0.41	0.44	0.49	0.47	0.44	0.55	0.44	0.27	0.14	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.68	N/A	N/A	N/A	N/A	N/A	-133	-186	+102	N/A	(46)
(47)	Regional (47 neighbors)	+0.62	N/A	N/A	N/A	+0.47	+0.50	-109	-161	+92	+54	(47)

Nomenclature: See separate page