

BAJA, Hungary

WMO: 129600

Lat: 46.183N

Lon: 19.017E

Elev: 371

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.3	15.5	5.8	7.5	12.2	11.0	9.8	18.7	14.5	37.4	13.2	36.0	2.4	110	0.452

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.0	93.6	70.4	90.5	70.0	87.4	68.9	73.2	87.1	71.8	86.0	70.3	83.9	4.8	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.0	108.2	78.6	67.4	102.0	76.8	65.9	96.7	75.2	37.0	87.2	35.7	85.7	34.4	84.0	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
12.7	11.0	9.5	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			0.6	98.0	7.7	3.3	-5.0	100.4	-9.5	102.3	-13.8	104.2	-19.4	106.5		
			0.3	76.1	7.9	1.9	-5.4	77.5	-10.1	78.6	-14.5	79.6	-20.2	81.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.3	31.8	34.9	43.1	53.2	61.6	67.9	71.0	70.5	61.8	53.4	43.2	34.0
	DBStd	15.74	8.49	9.24	8.12	6.82	6.48	6.41	5.68	5.66	6.26	7.51	7.92	8.25
	HDD50	2057	564	424	240	44	3	0	0	0	1	54	229	498
	HDD65	5236	1029	842	680	357	144	43	14	15	133	362	655	962
	CDD50	2894	0	2	25	140	362	536	652	637	355	160	24	1
	CDD65	596	0	0	0	2	37	129	200	187	38	3	0	0
	CDH74	7891	0	0	1	102	626	1681	2533	2326	560	62	0	0
	CDH80	3198	0	0	0	17	168	653	1138	1052	168	2	0	0
Wind	WSAvg	4.0	4.1	4.5	5.0	4.7	4.1	3.8	3.8	3.4	3.3	3.4	3.9	4.1
Precipitation	PrecAvg	24.6	1.3	1.5	1.3	1.7	2.6	3.0	2.6	2.2	2.4	2.2	2.0	1.9
	PrecMax	38.2	3.0	3.4	4.4	3.9	7.6	6.9	6.6	5.6	5.6	5.1	5.4	4.1
	PrecMin	12.6	0.2	0.1	0.1	0.0	0.6	0.7	0.8	0.2	0.7	0.3	0.1	0.1
	PrecStd	5.4	0.8	0.9	0.9	0.9	1.5	1.7	1.4	1.2	1.5	1.3	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.4	63.5	71.9	82.7	88.7	94.4	98.5	98.7	90.5	79.4	68.8	56.7
		MCWB	49.8	51.0	54.3	61.8	66.0	71.3	70.7	69.7	67.3	64.0	58.4	51.1
	2%	DB	51.4	57.7	67.2	76.6	84.5	90.7	93.4	93.9	84.8	75.3	63.3	51.4
		MCWB	46.2	48.8	52.6	58.6	65.8	70.8	70.5	70.3	65.7	61.9	55.4	47.8
	5%	DB	46.8	52.7	62.5	72.5	80.9	87.3	90.3	89.8	80.3	71.7	58.8	47.6
		MCWB	43.1	46.3	50.6	56.5	64.0	69.9	70.5	69.7	64.3	60.3	53.2	44.9
	10%	DB	43.3	48.3	57.9	68.6	77.0	83.8	86.9	86.0	76.3	67.4	55.3	44.6
		MCWB	40.7	43.6	48.6	54.9	62.3	68.0	69.0	68.5	63.0	58.4	50.9	42.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.2	52.0	56.5	62.9	69.1	74.8	74.8	75.3	70.1	65.6	59.2	51.9
		MCDB	55.4	60.7	67.9	78.4	83.5	87.7	88.5	88.5	84.3	77.0	67.3	56.1
	2%	WB	46.9	49.6	53.9	60.2	67.0	72.5	73.0	72.9	67.5	63.1	56.2	48.2
		MCDB	50.8	56.9	64.4	73.3	80.4	86.3	87.5	86.5	80.2	72.9	62.0	51.1
	5%	WB	43.7	46.8	51.6	58.1	65.2	70.9	71.7	71.3	65.9	61.0	53.7	45.1
		MCDB	46.3	51.5	60.7	69.5	77.7	84.5	85.8	85.5	76.9	69.8	58.2	47.3
	10%	WB	41.0	44.2	49.3	56.0	63.4	69.1	70.2	69.7	64.1	59.0	51.3	42.8
		MCDB	43.1	48.0	57.1	66.2	75.0	81.2	83.7	83.1	73.9	66.4	54.9	44.4
Mean Daily Temperature Range	5% DB	MDBR	12.7	16.0	20.5	23.6	23.9	24.1	25.0	25.5	23.1	21.9	15.7	11.4
		MCDBR	18.6	23.5	29.3	31.6	30.4	30.1	31.3	32.7	30.7	27.6	21.7	16.9
		MCWBR	13.5	15.8	16.7	15.8	13.8	12.6	11.6	12.2	13.8	15.1	14.3	12.9
	5% WB	MCDBR	17.5	21.0	26.2	27.7	27.4	27.4	27.1	28.2	26.1	26.0	20.4	15.9
		MCWBR	13.1	14.5	15.5	14.3	13.1	12.0	11.2	11.7	12.7	14.8	13.7	12.5
Clear-Sky Solar Irradiance	taub	0.337	0.360	0.395	0.448	0.435	0.433	0.442	0.445	0.426	0.390	0.360	0.336	
	taud	2.364	2.295	2.231	2.090	2.193	2.233	2.205	2.205	2.226	2.316	2.355	2.369	
	Ebn at Noon	237	253	261	256	265	266	261	255	248	239	225	222	
	Edh at Noon	24	31	38	48	45	43	44	42	38	30	24	22	
All-Sky Solar Radiation	RadAvg	368	627	1014	1464	1768	1928	1925	1724	1205	808	456	287	
	RadStd	50	93	134	136	162	148	144	170	137	83	41	43	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (46 neighbors)		+1.15	N/A	N/A	N/A	+0.77	+0.83	-205	-301	+176	+101	

Nomenclature: See separate page