

SZEGED, Hungary

WMO: 129820

Lat: 46.2561N

Lon: 20.0906E

Elev: 83

StdP: 100.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-8.8	-14.1	1.1	-10.3	-11.6	1.4	-7.3	11.3	4.0	10.0	1.9	2.1	10	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	34.1	21.2	32.4	20.9	30.7	20.3	22.8	30.4	21.9	29.6	21.1	28.7	3.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.3	25.9	19.5	14.4	24.8	18.6	13.6	23.9	67.8	30.5	64.3	29.6	61.3	28.7	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.1	7.0	-15.1	36.2	4.1	1.8	-18.1	37.5	-20.5	38.5	-22.8	39.5	-25.8	40.8		
(5)			-15.4	24.5	4.1	1.6	-18.4	25.7	-20.7	26.6	-23.0	27.5	-26.0	28.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	0.1	1.7	6.4	12.0	16.8	20.3	22.2	22.1	17.1	11.9	6.5	1.0	(6)
(7)		DBStd	8.90	4.50	5.15	4.38	3.83	3.60	3.52	3.10	3.24	3.73	4.24	4.44	4.62	(7)
(8)		HDD10.0	1123	308	233	126	23	1	0	0	0	31	123	279		(8)
(9)		HDD18.3	2859	567	466	370	191	73	20	5	6	67	202	357	537	(9)
(10)		CDD10.0	1689	0	1	14	84	211	309	377	374	213	88	17	1	(10)
(11)		CDD18.3	383	0	0	0	2	24	79	123	122	30	2	0	0	(11)
(12)		CDH23.3	4464	0	0	0	39	304	897	1422	1431	341	31	0	0	(12)
(13)		CDH26.7	1770	0	0	0	6	66	332	616	648	101	1	0	0	(13)
(14)	Wind	WSAvg	3.1	3.2	3.4	3.7	3.6	3.1	2.7	2.8	2.5	2.7	2.8	3.2	3.2	(14)
(15)	Precipitation	PrecAvg	516	29	28	29	39	53	73	55	51	42	36	40	40	(15)
(16)		PrecMax	841	88	79	98	94	157	199	169	123	148	113	106	114	(16)
(17)		PrecMin	305	2	0	1	2	5	7	10	2	1	1	0	0	(17)
(18)		PrecStd	114	19	21	19	21	33	44	35	31	30	29	26	26	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	16.7	21.5	27.3	30.6	34.4	36.1	37.0	32.4	26.1	20.0	13.0	(19)
(20)			MCWB	9.5	10.2	12.2	16.8	18.7	21.7	21.6	21.5	19.8	17.3	14.7	10.2	(20)
(21)		2%	DB	9.9	13.6	18.8	24.1	28.5	32.4	33.8	34.5	29.5	24.0	17.1	10.7	(21)
(22)			MCWB	7.7	9.2	11.3	14.8	18.4	21.1	21.6	20.9	18.5	16.2	13.0	8.5	(22)
(23)		5%	DB	7.9	11.1	16.3	21.9	26.8	30.4	32.1	32.5	27.1	21.8	15.0	8.6	(23)
(24)			MCWB	6.1	7.9	10.3	13.9	17.8	20.6	21.1	20.6	17.8	15.3	11.6	7.0	(24)
(25)		10%	DB	6.1	8.9	14.0	19.9	24.8	28.4	30.3	30.5	25.0	19.3	13.1	7.0	(25)
(26)			MCWB	4.9	6.5	9.0	12.8	16.8	19.7	20.5	20.1	17.0	14.2	10.5	5.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	11.0	13.5	17.4	20.4	23.8	24.1	23.8	20.9	18.3	14.7	10.6	(27)
(28)			MCD B	12.1	15.1	19.1	25.6	27.6	31.5	31.3	31.8	29.8	24.5	18.7	12.7	(28)
(29)		2%	WB	7.8	9.6	12.0	15.7	19.2	22.5	22.8	22.5	19.5	16.9	13.3	8.7	(29)
(30)			MCD B	9.5	13.1	17.5	22.5	26.4	29.3	30.5	30.7	26.7	22.4	16.5	10.5	(30)
(31)		5%	WB	6.3	8.1	10.8	14.5	18.3	21.4	21.9	21.5	18.5	15.8	12.0	7.2	(31)
(32)			MCD B	7.5	10.7	15.4	20.6	25.1	28.1	29.6	29.9	25.1	20.8	14.6	8.4	(32)
(33)		10%	WB	4.9	6.7	9.6	13.4	17.4	20.4	21.1	20.6	17.7	14.6	10.7	6.0	(33)
(34)			MCD B	6.0	8.7	13.7	18.7	23.7	26.9	28.6	28.6	23.5	18.7	12.9	6.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.1	8.1	10.4	11.6	11.8	12.2	12.9	13.4	11.9	11.0	8.0	5.7	(35)
(36)			MCDBR	8.9	11.9	14.4	15.3	15.0	15.1	16.0	16.7	15.5	14.4	11.0	8.0	(36)
(37)			MCWBR	6.7	8.1	8.4	7.7	6.6	5.9	5.8	5.8	6.5	7.6	7.0	6.2	(37)
(38)		5% WB	MCD BR	8.4	10.8	13.0	13.5	13.3	13.2	13.9	14.4	13.4	13.1	10.5	7.5	(38)
(39)			MCWBR	6.6	7.7	7.9	7.1	6.3	5.8	5.7	5.7	6.0	7.2	7.0	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.363	0.399	0.454	0.438	0.436	0.448	0.450	0.429	0.392	0.362	0.339	(40)	
(41)		taud	2.339	2.283	2.216	2.070	2.187	2.228	2.193	2.190	2.217	2.308	2.344	2.354	(41)	
(42)		Ebn at Noon	740	795	818	802	832	834	817	798	777	751	704	695	(42)	
(43)		Edh at Noon	77	99	122	154	142	137	140	135	121	96	77	69	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.14	1.97	3.22	4.63	5.60	6.12	6.07	5.45	3.81	2.55	1.46	0.88	(44)	
(45)		RadStd	0.14	0.29	0.43	0.43	0.52	0.47	0.46	0.52	0.42	0.27	0.13	0.13	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.77	N/A	N/A	+1.14	N/A	N/A	-156	-235	+123	+66
(47) Regional (51 neighbors)		+0.66	N/A	N/A	N/A	+0.40	N/A	-111	-168	+102	+55

Nomenclature: See separate page