

BEKESCSABA, Hungary

WMO: 129920

Lat: 46.683N

Lon: 21.163E

Elev: 295

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	14.9	5.8	7.5	11.6	10.3	9.4	16.6	22.3	33.0	19.3	34.6	4.4	10	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.6	92.7	69.9	89.7	69.6	86.7	68.4	73.1	85.9	71.6	84.4	70.1	82.5	7.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	107.9	78.7	67.5	102.1	76.6	66.0	97.0	74.8	36.8	86.0	35.4	84.3	34.2	82.6	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	16.1	13.9	4.0	97.2	7.7	3.1	-1.5	99.5	-6.0	101.3	-10.3	103.0	-15.9	105.3
			3.6	75.7	7.5	2.0	-1.8	77.2	-6.1	78.4	-10.3	79.5	-15.7	81.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	31.5	34.9	43.0	53.6	62.3	68.6	71.8	71.5	63.0	53.1	43.3	33.6
	DBStd	16.18	8.64	9.48	8.25	6.69	6.49	6.24	5.51	5.68	6.36	7.56	8.04	8.76
	HDD50	2076	574	423	242	40	2	0	0	0	0	57	229	509
	HDD65	5202	1039	842	682	345	130	35	9	10	111	374	652	973
	CDD50	3029	0	1	25	147	382	558	676	667	392	152	28	1
	CDD65	678	0	0	0	2	46	143	220	211	52	4	0	0
	CDH74	7615	0	0	0	52	568	1579	2392	2384	589	51	0	0
	CDH80	2921	0	0	0	5	123	567	1014	1038	172	2	0	0
	WSAvg	6.1	6.2	6.8	7.6	6.9	6.4	6.0	5.9	5.3	5.4	5.3	5.9	6.0
	PrecAvg	22.3	1.2	1.2	1.3	1.9	2.2	2.6	2.6	2.2	2.0	1.8	1.7	1.7
(15) Precipitation	PrecMax	32.0	3.0	3.8	4.6	3.6	4.9	6.1	5.6	6.0	4.4	5.2	4.7	4.3
	PrecMin	11.9	0.2	0.0	0.1	0.3	0.2	0.4	0.4	0.1	0.3	0.1	0.0	0.0
	PrecStd	5.0	0.6	0.8	1.0	0.9	1.2	1.4	1.4	1.5	1.0	1.2	1.0	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.1	61.1	69.9	79.5	86.4	93.2	97.2	97.3	90.1	78.9	68.2	56.2
		MCWB	48.9	50.4	53.8	62.3	65.3	70.8	70.0	70.7	67.3	63.6	57.8	50.4
	2%	DB	49.5	55.7	65.3	74.7	83.5	89.4	92.6	93.0	84.6	74.9	62.9	51.8
		MCWB	45.4	48.0	52.3	58.4	64.9	70.3	70.0	69.7	65.3	61.1	54.7	47.6
	5%	DB	46.2	51.6	60.9	71.1	80.4	86.4	89.4	89.7	80.7	70.8	59.1	48.1
		MCWB	42.9	46.0	49.9	56.6	63.9	68.9	69.8	69.4	63.9	59.5	52.8	45.4
	10%	DB	43.1	47.9	56.9	67.7	76.9	83.2	85.9	86.0	76.5	66.4	55.4	45.0
		MCWB	41.0	44.0	48.1	55.0	62.7	67.5	68.6	68.4	62.6	57.6	50.9	43.0
	0.4%	WB	49.2	51.3	56.0	63.3	68.5	75.2	74.6	75.4	69.3	65.3	58.4	51.2
		MCDB	53.2	58.2	66.5	76.6	80.5	88.0	86.8	90.5	84.0	75.4	65.7	55.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.8	49.0	53.3	60.3	66.6	72.7	72.7	72.8	67.0	62.3	55.8	48.1
		MCDB	48.7	54.8	62.6	72.1	79.2	84.5	85.7	86.2	80.2	71.9	61.5	51.2
	5%	WB	43.2	46.6	51.0	58.1	65.0	70.7	71.3	71.0	65.4	60.5	53.5	45.6
		MCDB	45.4	50.9	59.3	68.3	77.3	82.1	84.5	84.1	77.3	69.1	58.5	47.9
	10%	WB	40.9	44.3	48.9	56.0	63.4	68.9	70.0	69.4	63.8	58.4	51.1	43.1
		MCDB	42.7	47.6	56.2	65.2	74.8	80.1	82.6	82.0	74.2	65.4	55.1	44.9
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	14.1	18.2	20.8	21.7	21.7	22.6	23.5	21.2	20.1	14.6	9.8
		MCDBR	14.3	20.1	24.3	26.7	27.0	26.4	28.0	29.0	27.4	25.4	19.8	13.8
		MCWBR	11.0	13.5	13.9	13.6	11.9	10.7	9.5	10.2	11.1	13.3	12.7	10.5
	5% WB	MCDBR	13.4	17.9	21.6	23.6	24.0	23.9	24.2	25.0	23.8	22.9	18.3	12.6
		MCWBR	10.6	12.5	13.0	12.7	11.4	10.6	9.8	10.1	10.6	12.7	12.2	9.8
(40) Clear-Sky Solar Irradiance	taub		0.338	0.363	0.400	0.456	0.437	0.437	0.452	0.453	0.427	0.390	0.363	0.339
	taud		2.329	2.279	2.212	2.065	2.189	2.221	2.181	2.181	2.221	2.312	2.337	2.349
	Ebn at Noon		233	251	258	253	264	264	258	252	246	238	221	218
	Edh at Noon		24	31	39	49	45	43	45	43	38	30	24	22
(44) All-Sky Solar Radiation	RadAvg		344	613	1017	1470	1783	1941	1911	1727	1206	797	450	265
	RadStd		39	96	138	138	167	139	152	160	132	86	40	38

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (55 neighbors)		+1.21	N/A	N/A	+1.67	+0.76	+0.85	-216	-328	+198	+103

Nomenclature: See separate page