

BEKESCSABA, Hungary

WMO: 129920

Lat: 46.683N

Lon: 21.163E

Elev: 90

StdP: 100.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-12.3	-9.5	-14.5	1.1	-11.3	-12.0	1.3	-8.6	10.0	0.5	8.6	1.5	2.0	10	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	33.7	21.1	32.1	20.9	30.4	20.2	22.8	30.0	22.0	29.1	21.2	28.1	3.1	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.4	25.9	19.7	14.6	24.8	18.9	13.9	23.8	67.8	30.0	64.6	29.1	61.7	28.1	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.2	6.2	-15.6	36.2	4.3	1.7	-18.6	37.5	-21.1	38.5	-23.5	39.5	-26.6	40.7		
(5)			-15.8	24.3	4.1	1.1	-18.8	25.1	-21.2	25.8	-23.5	26.4	-26.5	27.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	-0.3	1.6	6.1	12.0	16.8	20.3	22.1	21.9	17.2	11.7	6.3	0.9
	DBStd	8.99	4.80	5.27	4.58	3.71	3.60	3.47	3.06	3.16	3.54	4.20	4.47	4.87
	HDD10.0	1153	319	235	134	22	1	0	0	0	0	32	127	283
	HDD18.3	2890	577	468	379	192	72	19	5	6	62	208	362	541
	CDD10.0	1683	0	1	14	82	212	310	376	371	218	84	16	1
	CDD18.3	377	0	0	0	1	26	79	122	117	29	2	0	0
	CDH23.3	4231	0	0	0	29	316	877	1329	1324	327	28	0	0
	CDH26.7	1623	0	0	0	3	68	315	563	577	96	1	0	0
Wind	WSAvg	2.7	2.8	3.0	3.4	3.1	2.9	2.7	2.6	2.4	2.4	2.4	2.6	2.7
Precipitation	PrecAvg	566	30	31	32	47	57	67	65	55	50	45	44	44
	PrecMax	813	76	96	116	91	124	154	142	153	113	131	119	108
	PrecMin	301	4	1	3	8	5	11	10	2	7	2	0	0
	PrecStd	128	16	20	25	23	31	36	36	39	26	30	25	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.3	16.2	21.1	26.4	30.2	34.0	36.2	36.3	32.3	26.0	20.1	13.5
		MCWB	9.4	10.2	12.1	16.8	18.5	21.6	21.1	21.5	19.6	17.5	14.4	10.2
	2%	DB	9.7	13.1	18.5	23.7	28.6	31.9	33.6	33.9	29.2	23.8	17.1	11.0
		MCWB	7.5	8.9	11.3	14.7	18.3	21.3	21.1	21.0	18.5	16.2	12.6	8.6
	5%	DB	7.9	10.9	16.1	21.7	26.9	30.2	31.9	32.1	27.1	21.6	15.1	9.0
		MCWB	6.0	7.8	10.0	13.7	17.7	20.5	21.0	20.8	17.7	15.3	11.5	7.4
	10%	DB	6.2	8.8	13.8	19.8	25.0	28.4	29.9	30.0	24.7	19.1	13.0	7.2
		MCWB	5.0	6.6	9.0	12.8	17.0	19.7	20.3	20.2	17.0	14.2	10.5	6.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	10.7	13.3	17.4	20.3	24.0	23.7	24.1	20.7	18.5	14.7	10.7
		MCDB	11.8	14.6	19.1	24.8	27.0	31.1	30.5	32.5	28.9	24.1	18.7	12.9
	2%	WB	7.7	9.4	11.8	15.7	19.2	22.6	22.6	22.7	19.4	16.8	13.2	8.9
		MCDB	9.3	12.6	17.0	22.3	26.2	29.2	29.8	30.1	26.8	22.2	16.4	10.7
	5%	WB	6.2	8.1	10.6	14.5	18.4	21.5	21.8	21.7	18.5	15.8	11.9	7.6
		MCDB	7.4	10.5	15.2	20.2	25.1	27.9	29.1	28.9	25.2	20.6	14.7	8.8
	10%	WB	4.9	6.8	9.4	13.3	17.4	20.5	21.1	20.8	17.7	14.7	10.6	6.2
		MCDB	6.0	8.7	13.4	18.4	23.8	26.7	28.1	27.8	23.4	18.6	12.8	7.2
Mean Daily Temperature Range	5% DB	MDBR	6.0	7.8	10.1	11.6	12.0	12.0	12.5	13.1	11.8	11.1	8.1	5.4
		MCDBR	7.9	11.2	13.5	14.9	15.0	14.7	15.5	16.1	15.2	14.1	11.0	7.6
		MCWBR	6.1	7.5	7.7	7.6	6.6	5.9	5.3	5.7	6.2	7.4	7.1	5.8
	5% WB	MCDBR	7.4	9.9	12.0	13.1	13.3	13.3	13.5	13.9	13.2	12.7	10.1	7.0
MCWBR		5.9	7.0	7.2	7.1	6.3	5.9	5.4	5.6	5.9	7.1	6.8	5.5	
Clear-Sky Solar Irradiance	taub	0.338	0.363	0.400	0.456	0.437	0.437	0.452	0.453	0.427	0.390	0.363	0.339	
	taud	2.329	2.279	2.212	2.065	2.189	2.221	2.181	2.181	2.221	2.312	2.337	2.349	
	Ebn at Noon	734	791	814	798	832	832	812	793	777	750	696	687	
	Edh at Noon	77	98	122	154	141	137	141	136	119	94	76	68	
All-Sky Solar Radiation	RadAvg	1.08	1.93	3.21	4.63	5.62	6.12	6.02	5.44	3.80	2.51	1.42	0.83	
	RadStd	0.12	0.30	0.43	0.44	0.53	0.44	0.48	0.50	0.42	0.27	0.13	0.12	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (55 neighbors)	+0.67	N/A	N/A	+0.93	+0.42	+0.47	-120	-182	+110	+57

Nomenclature: See separate page