

RIJEKA OMISALJ, Croatia

WMO: 131160

Lat: 45.217N

Lon: 14.570E

Elev: 278

StdP: 14.55

Time Zone: 1.00 (EUC)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.2	29.8	-0.6	5.4	28.8	3.6	6.7	32.7	31.8	30.9	28.3	31.7	11.6	50	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	90.0	69.2	87.8	68.4	85.8	67.7	72.8	83.1	71.5	82.1	70.2	80.8	6.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	111.0	76.8	68.1	104.4	76.0	66.4	98.2	75.4	36.5	82.8	35.4	82.6	34.3	80.0	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	20.7	16.4	DB	24.1	93.1	4.4	1.7	20.9	94.3	18.3	95.3	15.9	96.2	12.6	97.4
			WB	19.4	75.2	4.2	2.3	16.3	76.8	13.9	78.2	11.5	79.4	8.4	81.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.2	42.2	42.4	49.1	55.2	62.7	69.5	76.0	75.5	67.8	60.3	50.9	45.4	(6)
	DBStd	13.02	5.81	6.70	6.24	5.01	5.76	5.62	4.34	5.22	4.92	4.53	5.56	5.39	(7)
	HDD50	785	246	221	90	11	1	0	0	0	0	1	55	160	(8)
	HDD65	3480	708	634	494	295	114	20	0	1	27	156	423	608	(9)
	CDD50	3771	2	8	61	169	393	586	806	790	535	321	83	17	(10)
	CDD65	992	0	0	0	2	42	157	341	327	112	11	0	0	(11)
	CDH74	7654	0	0	0	14	172	1036	2981	2856	572	23	0	0	(12)
	CDH80	2373	0	0	0	0	10	236	1007	1028	92	0	0	0	(13)
(14) Wind	WSAvg	5.8	6.1	6.5	6.8	5.8	4.9	4.5	4.8	5.3	4.7	6.0	7.1	7.4	(14)
(15) Precipitation	PrecAvg	51.5	3.4	2.8	3.0	3.8	3.2	3.2	2.1	2.8	6.5	8.1	7.0	5.6	(15)
	PrecMax	60.1	8.5	7.0	7.2	6.3	7.8	6.0	3.9	7.0	13.0	15.9	13.5	9.2	(16)
	PrecMin	33.1	0.2	0.2	0.4	1.2	0.4	1.2	0.5	0.6	2.4	1.7	3.3	1.3	(17)
	PrecStd	7.1	2.4	1.8	2.0	1.5	2.1	1.5	1.2	1.9	2.9	4.9	2.6	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	63.0	70.1	75.5	81.0	89.4	92.9	94.8	86.0	76.9	65.9	61.1	(19)
		MCWB	48.9	48.2	52.0	59.0	65.7	69.5	69.0	72.2	67.3	61.8	57.3	54.7	(20)
	2%	DB	53.9	57.2	65.9	70.1	78.4	85.6	89.9	91.3	82.5	73.6	62.9	57.6	(21)
		MCWB	48.4	46.3	50.2	56.2	63.0	68.0	68.6	70.1	65.6	60.2	55.5	52.8	(22)
	5%	DB	51.9	53.8	61.0	67.1	75.4	82.6	87.9	88.2	80.2	70.3	61.0	55.8	(23)
		MCWB	47.1	45.9	48.4	54.2	61.1	67.1	68.3	68.6	65.1	58.7	54.9	50.9	(24)
	10%	DB	50.2	51.6	58.6	64.4	73.0	80.2	85.8	85.9	77.1	68.1	59.1	53.7	(25)
		MCWB	45.9	45.1	48.2	51.7	59.8	65.5	67.7	67.7	63.6	58.2	53.0	48.5	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.9	52.6	54.9	61.1	69.1	72.9	74.5	74.7	72.2	65.6	61.5	56.2	(27)
		MCDB	54.9	55.6	62.4	70.4	77.6	85.1	82.3	86.6	77.1	70.2	64.0	59.5	(28)
	2%	WB	50.9	50.4	53.0	58.3	66.0	70.8	72.8	72.8	70.0	63.8	58.9	54.7	(29)
		MCDB	52.5	53.4	59.9	67.6	74.0	81.1	82.7	83.7	76.4	68.3	61.1	57.8	(30)
	5%	WB	49.2	48.5	51.7	56.0	63.5	69.0	71.4	71.5	68.0	62.4	56.7	52.8	(31)
		MCDB	50.6	52.1	57.7	63.4	71.1	78.6	82.2	82.8	75.0	66.8	59.7	55.6	(32)
	10%	WB	47.5	46.3	50.1	54.5	61.5	67.3	70.0	70.1	66.5	61.1	55.0	50.5	(33)
		MCDB	49.0	49.9	56.0	61.2	69.6	76.4	81.0	81.7	73.8	65.9	58.2	52.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	10.7	12.3	13.2	13.6	14.8	16.3	16.2	15.2	13.5	11.0	10.3	(35)
		MCDBR	12.2	13.8	17.4	17.9	16.9	17.4	18.6	19.0	18.8	16.3	13.0	11.9	(36)
	5% WB	MCWBR	9.3	8.2	8.7	8.4	8.0	7.6	7.5	7.6	8.6	8.3	8.3	8.7	(37)
		MCWBR	7.7	10.7	13.8	15.1	14.9	16.3	17.5	17.2	16.3	13.2	9.5	8.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.349	0.377	0.423	0.469	0.464	0.468	0.460	0.454	0.442	0.418	0.380	0.347	(40)
		taud	2.362	2.270	2.165	2.067	2.135	2.182	2.208	2.236	2.229	2.262	2.309	2.382	(41)
	Ebn at Noon		236	250	253	251	257	256	257	253	245	232	220	223	(42)
		Edh at Noon	25	32	41	49	48	46	44	41	38	32	26	22	(43)
(44) All-Sky Solar Radiation	RadAvg		402	652	1039	1416	1769	2027	2058	1783	1231	779	438	349	(44)
	RadStd		60	116	151	169	174	126	121	180	142	84	55	51	(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (30 neighbors)	+0.77	N/A	N/A	N/A	+0.72	N/A	N/A	+160	+108	(47)

Nomenclature: See separate page