

NOVI SAD RIMSKI SANCEVI, Serbia

WMO: 131680

Lat: 45.333N

Lon: 19.850E

Elev: 285

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.0	17.2	8.2	8.4	13.5	13.0	10.8	18.3	21.7	33.9	19.1	34.7	4.3	290	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	92.8	71.5	89.8	71.1	86.8	69.9	74.3	87.5	72.5	85.9	71.1	84.0	5.7	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	112.0	81.0	68.3	104.9	78.4	66.8	99.6	76.8	37.9	87.5	36.3	85.9	35.1	84.3	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
19.1	16.5	13.9	4.5	97.0	8.9	3.4	-1.9	99.5	-7.1	101.5	-12.1	103.4	-18.6	105.9		
			4.0	76.6	8.7	2.1	-2.3	78.1	-7.4	79.3	-12.2	80.5	-18.5	82.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	33.4	36.6	45.0	54.9	63.1	69.2	72.3	72.4	63.8	54.5	45.0	35.4
	DBStd	15.90	8.92	9.92	8.68	7.24	6.69	6.49	5.65	5.83	6.75	7.98	8.47	8.71
	HDD50	1834	516	380	200	36	2	0	0	0	0	47	196	457
	HDD65	4821	979	795	620	308	117	32	8	9	102	333	600	918
	CDD50	3257	2	5	45	184	406	576	691	696	415	187	46	4
	CDD65	770	0	0	0	6	57	158	235	239	67	8	0	0
	CDH74	7851	0	0	1	88	536	1591	2465	2461	632	77	0	0
	CDH80	2970	0	0	0	14	110	565	1026	1067	185	3	0	0
Wind	WSAvg	5.7	6.0	6.6	7.0	6.7	5.6	5.0	4.9	4.6	4.9	5.5	6.2	6.0
Precipitation	PrecAvg	25.4	1.5	1.4	1.5	1.8	2.7	3.3	2.7	2.2	2.2	2.3	2.0	1.9
	PrecMax	38.9	2.8	2.6	3.1	5.4	7.6	8.2	7.6	5.6	6.3	5.5	5.2	5.0
	PrecMin	11.2	0.2	0.0	0.2	0.0	0.7	1.1	0.3	0.2	0.4	0.0	0.0	0.0
	PrecStd	6.6	0.7	0.7	0.8	1.2	1.6	1.7	1.7	1.6	1.3	1.5	1.1	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.3	63.9	72.0	82.0	86.8	93.3	96.6	98.1	90.6	79.9	70.0	59.8
		MCWB	50.8	51.8	55.7	63.0	66.6	71.8	73.0	72.0	69.2	64.5	58.8	52.7
	2%	DB	52.9	58.7	67.6	75.9	83.0	89.7	92.5	93.3	85.0	76.1	65.4	55.0
		MCWB	47.6	49.7	53.7	59.4	65.8	71.6	72.2	70.9	67.0	62.9	56.6	49.6
	5%	DB	48.6	54.5	63.5	71.7	79.9	86.4	89.2	89.9	80.9	72.0	61.4	50.8
		MCWB	44.8	47.7	51.9	57.2	64.8	70.6	71.7	70.5	65.0	60.8	54.2	46.8
	10%	DB	45.2	50.5	59.1	68.3	76.6	83.1	86.0	86.1	77.0	68.1	57.4	46.6
		MCWB	42.5	45.3	49.6	55.6	63.2	69.0	70.3	69.5	64.0	59.1	52.1	43.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	53.0	57.2	63.6	69.1	76.1	76.5	76.3	70.8	66.1	59.7	53.1
		MCDB	57.1	60.9	68.5	79.2	81.2	87.7	89.5	89.2	86.0	76.9	68.1	58.4
	2%	WB	48.0	50.4	54.5	60.8	67.3	73.1	74.4	73.7	68.3	63.7	56.9	49.9
		MCDB	52.6	57.7	65.3	73.7	79.7	85.5	87.8	87.8	81.3	74.3	64.2	54.0
	5%	WB	45.1	48.1	52.5	58.6	65.8	71.5	72.7	71.9	66.5	61.7	54.6	47.1
		MCDB	48.2	53.9	62.1	69.2	77.5	83.7	86.0	85.9	78.4	70.5	60.4	50.4
	10%	WB	42.7	45.6	50.4	56.7	64.1	69.8	71.2	70.4	64.8	59.5	52.4	44.1
		MCDB	45.2	49.9	58.2	66.1	74.7	81.3	83.9	83.4	74.6	67.0	57.2	46.6
Mean Daily Temperature Range	5% DB	MDBR	10.2	13.4	16.9	18.6	18.7	19.3	20.9	21.6	19.2	17.9	13.4	9.7
		MCDBR	16.2	20.7	24.0	25.1	24.0	24.6	26.3	27.6	25.5	23.8	19.6	16.0
		MCWBR	11.6	13.3	12.9	11.7	10.0	9.9	10.0	9.7	10.2	12.0	11.7	11.7
	5% WB	MCDBR	15.6	19.2	21.9	22.3	22.1	22.6	24.0	24.1	23.1	22.4	18.2	15.2
		MCWBR	11.4	12.8	12.1	10.8	10.0	9.8	9.9	9.6	9.8	11.9	11.2	11.4
Clear-Sky Solar Irradiance	taub	0.345	0.370	0.402	0.459	0.445	0.441	0.447	0.452	0.434	0.398	0.363	0.343	
	taud	2.346	2.269	2.218	2.069	2.172	2.219	2.195	2.183	2.203	2.299	2.355	2.357	
	Ebn at Noon	236	252	260	254	263	264	260	253	246	239	227	223	
	Edh at Noon	25	32	39	49	46	44	44	43	39	31	25	23	
All-Sky Solar Radiation	RadAvg	385	645	1044	1455	1774	1952	1970	1753	1220	836	493	313	
	RadStd	54	89	129	140	157	166	148	170	136	88	43	47	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.58	N/A	N/A	+1.93	+1.08	+1.26	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	+1.22	N/A	N/A	N/A	+0.68	N/A	-211	-331	+198	+104

Nomenclature: See separate page