

KIKINDA, Serbia

WMO: 131740

Lat: 45.850N

Lon: 20.467E

Elev: 269

StdP: 14.55

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	17.2	7.9	8.3	14.3	12.3	10.4	19.0	23.1	33.8	20.3	36.9	5.6	0	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.9	92.9	70.3	90.1	69.8	87.1	68.7	72.8	86.8	71.3	85.4	70.0	83.6	7.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.4	105.5	78.9	67.0	100.2	76.8	65.6	95.4	75.1	36.5	86.9	35.2	85.4	34.1	83.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	16.4	14.2	6.1	96.8	8.1	3.3	0.3	99.2	-4.5	101.1	-9.0	103.0	-14.9	105.4
			5.4	75.6	7.8	2.8	-0.2	77.6	-4.8	79.3	-9.2	80.9	-14.9	82.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	32.7	36.1	44.4	54.9	63.0	69.6	72.8	72.8	64.0	54.2	44.7	34.8
	DBStd	16.14	8.35	9.63	8.37	7.08	6.74	6.57	5.73	5.92	6.73	7.84	8.05	8.36
	HDD50	1893	536	392	211	35	1	0	0	0	48	198	472	
	HDD65	4906	1000	809	639	309	120	30	7	8	99	341	609	935
	CDD50	3262	0	3	37	180	403	587	706	707	420	178	39	2
	CDD65	801	0	0	0	5	57	167	248	249	69	6	0	0
	CDH74	8197	0	0	1	70	552	1711	2619	2569	617	58	0	0
	CDH80	3139	0	0	0	9	112	627	1099	1114	176	2	0	0
Wind	WSAvg	6.7	7.1	7.4	7.9	7.7	6.9	6.1	5.9	5.6	5.9	6.4	7.3	6.8
Precipitation	PrecAvg	22.4	1.3	1.2	1.3	1.6	2.4	2.8	2.4	1.9	2.1	1.9	1.7	1.8
	PrecMax	35.4	2.2	2.6	4.6	4.3	7.1	7.3	6.7	5.3	5.4	4.5	4.3	4.0
	PrecMin	9.6	0.2	0.1	0.0	0.1	0.3	0.6	0.6	0.2	0.2	0.1	0.0	0.0
	PrecStd	5.7	0.7	0.7	0.9	1.1	1.5	1.7	1.4	1.1	1.1	1.2	0.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.9	62.4	70.7	80.9	87.1	93.6	96.1	97.8	90.1	79.1	68.3	55.9
		MCWB	49.5	51.3	54.1	61.3	66.1	70.7	70.9	70.3	67.7	63.5	58.0	50.7
	2%	DB	50.1	57.1	66.2	75.2	83.2	90.2	92.5	93.6	84.6	75.3	63.4	52.2
		MCWB	46.2	48.9	52.4	58.3	64.9	70.2	70.9	69.8	65.5	61.1	55.5	48.3
	5%	DB	46.7	52.9	62.0	71.5	80.3	87.0	89.5	90.1	80.8	71.5	59.9	48.7
		MCWB	43.7	46.7	50.7	56.7	64.0	69.2	70.3	69.3	64.3	59.9	53.4	45.6
	10%	DB	44.0	49.0	57.7	67.9	76.9	83.6	86.3	86.4	77.0	67.5	56.6	45.6
		MCWB	41.7	44.4	48.6	54.9	62.6	67.7	68.7	68.5	63.0	58.0	51.3	43.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.0	52.1	56.6	62.2	68.4	74.5	74.7	75.1	69.6	65.3	58.9	51.5
		MCDB	54.3	60.0	67.6	78.1	82.1	88.2	88.8	88.3	86.3	76.1	66.5	54.6
	2%	WB	46.5	49.6	53.9	59.7	66.5	72.1	72.7	72.4	67.0	62.7	56.2	48.4
		MCDB	49.5	56.0	63.7	72.4	79.8	85.0	86.9	86.9	80.7	72.4	62.2	51.8
	5%	WB	44.0	47.3	51.7	57.9	65.0	70.3	71.4	70.8	65.4	60.7	53.9	45.9
		MCDB	46.3	52.2	60.6	68.9	77.3	83.2	85.7	85.2	77.4	69.3	59.1	48.3
	10%	WB	41.8	44.9	49.4	56.1	63.4	68.8	70.0	69.4	63.9	58.7	51.8	43.5
		MCDB	44.0	48.7	57.1	65.8	74.7	81.3	83.4	83.0	74.3	66.5	56.2	45.5
Mean Daily Temperature Range	5% DB	MDBR	9.5	12.9	16.7	18.5	19.2	19.7	20.9	21.6	19.0	17.7	13.2	9.0
		MCDBR	13.0	19.6	23.0	24.3	24.2	24.6	25.3	26.8	25.0	23.4	17.8	12.9
		MCWBR	9.9	12.7	12.3	11.0	9.9	9.0	8.7	8.8	9.8	11.5	10.8	9.7
	5% WB	MCDBR	12.6	17.9	20.7	21.3	21.8	21.9	22.8	23.2	22.0	21.1	16.7	12.2
		MCWBR	9.9	12.0	11.7	10.1	9.6	8.8	8.6	8.7	9.1	10.9	10.5	9.4
Clear-Sky Solar Irradiance	taub	0.342	0.367	0.401	0.457	0.442	0.437	0.448	0.453	0.432	0.394	0.362	0.341	
	taud	2.343	2.278	2.215	2.067	2.179	2.226	2.192	2.182	2.209	2.306	2.349	2.357	
	Ebn at Noon	235	252	259	254	263	265	259	253	246	239	225	221	
	Edh at Noon	25	32	39	49	45	43	44	43	39	30	24	22	
All-Sky Solar Radiation	RadAvg	367	636	1038	1469	1782	1960	1951	1744	1216	825	485	292	
	RadStd	41	90	134	140	162	159	149	163	134	86	40	43	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.12	N/A	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	N/A
(47)	Regional (48 neighbors)	+1.26	N/A	N/A	N/A	+0.70	N/A	-207	-322	+205	+108

Nomenclature: See separate page