

LOZNICA, Serbia

WMO: 132620

Lat: 44.550N

Lon: 19.233E

Elev: 400

StdP: 14.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	19.7	10.3	9.4	15.2	15.4	12.1	21.3	12.1	45.1	9.8	42.4	1.2	90	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.5	93.2	71.4	90.0	70.8	86.9	69.9	74.2	87.4	72.6	85.7	71.1	83.8	3.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	112.3	80.7	68.3	105.5	79.1	66.9	100.3	77.1	37.9	87.8	36.5	86.2	35.2	84.3	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.1	8.1	7.0	DB	8.0	98.1	6.2	4.1	3.6	101.0	0.0	103.4	-3.5	105.7	-8.0	108.6	
			WB	7.4	77.1	6.1	1.7	3.0	78.3	-0.5	79.3	-4.0	80.3	-8.4	81.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	54.7	35.2	38.3	46.0	55.0	63.1	69.5	72.8	72.8	64.1	55.3	46.2	37.2
	DBStd	15.32	8.82	9.34	8.58	7.10	6.49	6.49	5.47	5.60	6.71	7.76	8.50	8.32
	HDD50	1626	463	335	179	35	1	0	0	0	0	38	169	406
	HDD65	4556	925	746	589	306	114	30	7	7	97	308	564	863
	CDD50	3346	3	9	55	185	406	585	706	707	423	203	56	8
	CDD65	802	0	0	1	5	54	165	248	250	70	8	1	0
	CDH74	7878	0	0	8	96	563	1658	2467	2360	616	106	4	0
	CDH80	3040	0	0	1	16	130	628	1037	1026	193	9	0	0
Wind	WSAvg	2.2	1.9	2.2	2.8	2.6	2.6	2.5	2.4	2.1	2.0	1.7	1.9	2.0
Precipitation	PrecAvg	34.1	2.3	2.1	2.5	2.6	3.5	4.1	3.1	2.8	2.8	2.9	2.8	2.7
	PrecMax	48.5	4.0	3.7	6.1	6.8	11.9	8.8	7.8	8.3	9.5	7.9	4.6	6.9
	PrecMin	20.3	0.5	0.5	0.4	0.4	1.1	1.5	0.3	0.2	0.1	0.0	0.5	0.1
	PrecStd	6.5	0.9	0.8	1.4	1.3	2.3	1.9	1.9	1.9	1.9	1.9	1.2	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.1	67.1	74.1	82.3	87.7	93.6	97.1	98.8	91.5	81.1	73.7	66.5
		MCWB	51.3	52.4	55.6	61.2	67.4	72.3	71.9	71.6	68.5	64.5	58.7	53.8
	2%	DB	56.0	61.6	69.3	76.2	83.7	90.1	92.9	93.5	85.2	77.2	68.7	59.0
		MCWB	48.0	50.0	53.4	59.0	65.8	71.4	71.7	70.9	66.5	62.6	56.6	50.3
	5%	DB	51.1	57.1	65.1	72.4	80.3	87.1	89.5	89.5	80.7	73.0	63.9	53.0
		MCWB	45.4	48.0	52.1	57.1	64.8	70.7	71.4	70.3	65.3	61.2	54.3	46.8
	10%	DB	46.8	52.1	60.6	68.6	76.9	83.6	85.9	85.8	76.6	68.6	59.3	48.1
		MCWB	43.0	45.7	50.2	55.6	63.3	68.7	70.1	69.5	63.9	59.4	52.5	44.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.7	53.3	57.2	63.1	69.8	75.9	75.9	76.4	70.8	66.6	59.8	54.8
		MCDB	61.1	63.4	69.8	78.4	82.3	88.4	89.1	89.8	84.7	77.0	70.6	64.9
	2%	WB	48.7	50.6	54.5	60.5	67.6	73.5	73.8	73.9	68.5	64.1	57.6	50.3
		MCDB	55.0	60.1	66.1	72.9	80.3	86.1	88.0	86.3	80.8	73.5	66.8	57.6
	5%	WB	45.8	48.4	52.8	58.5	65.8	71.7	72.5	72.2	66.7	62.0	55.2	47.2
		MCDB	50.3	55.9	63.4	68.9	78.1	84.4	86.3	84.7	77.2	70.5	62.3	52.1
	10%	WB	43.3	46.2	50.7	56.7	64.0	69.7	71.0	70.5	65.1	60.0	52.9	44.6
		MCDB	46.6	51.6	59.9	66.2	74.6	81.1	83.8	82.7	74.2	67.5	59.0	47.9
Mean Daily Temperature Range	5% DB	MDBR	11.5	14.6	17.3	18.9	19.4	19.3	20.5	21.1	18.9	18.3	14.8	11.1
		MCDBR	20.0	24.9	26.1	27.0	26.2	26.1	27.5	28.5	26.2	25.8	23.0	20.5
		MCWBR	12.7	14.5	13.2	12.0	10.9	10.1	10.0	9.8	10.0	12.6	12.7	12.6
	5% WB	MCDBR	18.8	22.4	23.4	23.3	23.6	23.9	24.5	24.2	23.0	23.2	20.8	18.6
		MCWBR	12.2	13.5	12.6	11.1	10.8	10.1	9.9	10.0	9.8	12.1	12.1	11.8
Clear-Sky Solar Irradiance	taub	0.340	0.369	0.405	0.462	0.453	0.448	0.449	0.454	0.435	0.396	0.355	0.337	
	taud	2.352	2.247	2.199	2.062	2.143	2.204	2.200	2.186	2.209	2.311	2.376	2.363	
	Ebn at Noon	242	254	260	254	261	262	260	254	248	241	234	229	
	Edh at Noon	25	33	40	50	47	45	44	43	39	31	25	23	
All-Sky Solar Radiation	RadAvg	408	647	1030	1384	1708	1890	1946	1737	1207	837	507	340	
	RadStd	58	88	127	159	162	179	153	180	139	98	47	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (41 neighbors)	+1.21	N/A	N/A	N/A	+0.72	+0.86	-211	-331	+209	N/A

Nomenclature: See separate page