

SREMSKA MITROVICA, Serbia

WMO: 132660

Lat: 45.100N

Lon: 19.550E

Elev: 272

StdP: 14.55

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	17.5	8.7	8.7	14.3	13.8	11.2	18.9	18.9	32.2	16.7	32.1	3.7	90	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.3	92.7	71.2	89.7	70.5	86.8	69.1	73.8	86.9	72.3	85.2	70.9	83.0	5.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.9	111.2	79.3	68.3	105.2	77.2	67.0	100.4	75.7	37.5	86.8	36.1	85.5	34.9	83.2	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.8	14.1	12.1	4.9	97.0	8.7	3.2	-1.4	99.3	-6.5	101.2	-11.3	103.0	-17.6	105.3		
			4.5	76.4	8.5	2.3	-1.6	78.1	-6.6	79.4	-11.4	80.7	-17.6	82.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	33.0	36.8	45.0	54.8	63.2	69.0	72.0	72.2	63.6	54.5	45.1	35.1	
	DBStd	15.71	8.53	9.19	8.07	7.21	6.56	6.45	5.43	5.64	6.71	7.77	8.04	8.04	
	HDD50	1824	526	372	193	37	1	0	0	0	0	45	188	462	
	HDD65	4832	991	789	619	311	112	34	9	9	105	332	596	925	
	CDD50	3212	0	3	39	181	411	571	682	687	409	185	42	2	
	CDD65	746	0	0	0	6	57	155	226	231	64	7	0	0	
	CDH74	7798	0	0	3	96	595	1621	2412	2371	625	75	0	0	
	CDH80	2947	0	0	0	15	132	600	989	1022	186	3	0	0	
Wind	WSAvg	5.4	5.5	5.8	6.3	6.3	5.6	4.9	4.6	4.4	4.7	5.2	5.6	5.4	
Precipitation	PrecAvg	25.3	1.5	1.4	1.6	1.8	2.7	3.1	2.5	2.0	2.3	2.4	2.1	1.8	
	PrecMax	35.6	3.0	2.7	3.1	4.9	7.8	8.7	6.9	5.8	6.3	5.4	4.8	4.6	
	PrecMin	12.0	0.2	0.0	0.2	0.0	0.7	0.9	0.5	0.1	0.3	0.0	0.2	0.1	
	PrecStd	5.7	0.7	0.7	0.8	1.1	1.6	1.5	1.5	1.4	1.4	1.5	1.0	1.1	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	64.9	72.7	82.1	87.4	93.1	96.2	97.8	90.8	79.9	70.0	57.5	
		MCWB	50.8	51.4	55.7	61.5	66.0	72.0	72.1	71.5	68.3	63.9	59.2	51.5	
	2%	DB	51.3	58.9	68.1	76.5	83.5	89.9	92.4	93.0	85.1	76.1	65.1	52.4	
		MCWB	47.1	49.8	53.6	59.3	65.0	71.0	72.0	70.5	66.0	62.1	56.5	48.8	
	5%	DB	47.3	54.0	63.6	72.2	80.4	86.8	89.0	89.6	80.9	72.1	60.7	48.9	
		MCWB	44.5	47.3	51.8	56.9	64.0	69.8	70.8	70.1	65.0	60.5	54.2	46.3	
	10%	DB	43.9	49.5	58.9	68.5	77.1	83.5	85.8	85.9	77.0	67.8	57.1	45.5	
		MCWB	42.0	45.3	49.5	55.5	62.7	68.3	69.5	68.8	63.8	58.7	52.7	43.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	53.3	57.5	63.3	69.0	75.4	76.2	75.8	70.1	65.8	59.9	52.5
			MCDB	55.9	60.8	69.3	77.4	80.5	88.0	89.3	88.0	84.5	76.1	67.8	56.4
2%		WB	47.6	50.3	54.8	60.5	67.0	72.9	73.9	73.4	68.0	63.5	57.2	49.2	
		MCDB	50.9	56.9	65.2	73.4	78.9	85.3	87.3	86.6	80.3	72.9	63.8	52.2	
5%		WB	44.8	47.9	52.7	58.6	65.5	71.3	72.3	71.8	66.3	61.5	54.9	46.3	
		MCDB	47.0	53.3	61.8	69.2	77.1	83.4	85.3	84.8	77.5	69.8	59.8	48.5	
10%		WB	42.2	45.6	50.3	56.8	64.0	69.7	70.9	70.3	64.7	59.5	52.6	43.7	
		MCDB	43.9	49.6	57.9	65.9	74.5	80.4	82.7	82.5	74.4	66.6	56.8	45.4	
Mean Daily Temperature Range	5% DB	MDBR	10.6	14.7	18.6	20.0	19.8	20.6	22.3	22.9	20.5	18.7	14.0	9.8	
		MCDBR	16.2	24.2	27.6	27.0	25.8	26.3	28.3	29.3	27.1	24.8	19.9	15.6	
		MCWBR	12.4	15.0	14.9	12.5	9.7	10.0	10.4	10.0	10.8	12.3	12.0	11.9	
	5% WB	MCDBR	15.7	21.3	24.2	23.6	22.8	23.5	25.0	24.8	23.8	22.9	18.9	14.7	
		MCWBR	12.3	13.8	13.6	11.6	9.8	9.9	10.5	10.1	10.2	12.2	11.8	11.7	
Clear-Sky Solar Irradiance	taub	0.344	0.370	0.402	0.459	0.446	0.442	0.446	0.451	0.433	0.398	0.361	0.342		
	taud	2.351	2.267	2.219	2.073	2.169	2.219	2.202	2.190	2.209	2.305	2.365	2.360		
	Ebn at Noon	238	252	260	254	262	264	261	254	247	239	229	225		
	Edh at Noon	25	32	39	49	46	44	44	43	39	31	25	23		
All-Sky Solar Radiation	RadAvg	392	646	1040	1436	1758	1934	1965	1750	1218	837	495	322		
	RadStd	57	90	128	144	157	169	148	175	137	91	45	49		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.21	N/A	N/A	N/A	+1.06	N/A	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	+1.21	N/A	N/A	N/A	+0.72	+0.81	-227	-337	+209	+110

Nomenclature: See separate page