

SREMSKA MITROVICA, Serbia

WMO: 132660

Lat: 45.100N

Lon: 19.550E

Elev: 83

StdP: 100.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.0	-13.0	1.2	-9.8	-10.1	1.6	-7.3	8.5	0.1	7.5	0.1	1.7	90	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	33.7	21.8	32.1	21.4	30.4	20.6	23.2	30.5	22.4	29.5	21.6	28.4	2.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.1	15.9	26.3	20.2	15.0	25.1	19.5	14.3	24.3	69.2	30.5	66.1	29.7	63.3	28.4	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.5	6.3	5.4	-15.1	36.1	4.8	1.8	-18.5	37.4	-21.4	38.4	-24.1	39.4	-27.6	40.7		
			-15.3	24.7	4.7	1.3	-18.7	25.6	-21.5	26.3	-24.1	27.0	-27.5	28.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	0.6	2.7	7.2	12.7	17.3	20.6	22.2	22.3	17.6	12.5	7.3	1.7	(6)
(7)		DBStd	8.73	4.74	5.10	4.48	4.01	3.64	3.59	3.02	3.13	3.73	4.32	4.47	4.46	(7)
(8)		HDD10.0	1013	292	207	107	21	1	0	0	0	25	104	257		(8)
(9)		HDD18.3	2684	551	438	344	173	62	19	5	5	58	184	331	514	(9)
(10)		CDD10.0	1784	0	2	22	101	228	317	379	382	227	103	23	1	(10)
(11)		CDD18.3	414	0	0	0	3	32	86	126	128	36	4	0	0	(11)
(12)		CDH23.3	4332	0	0	2	53	331	901	1340	1317	347	42	0	0	(12)
(13)		CDH26.7	1637	0	0	0	8	73	333	549	568	103	2	0	0	(13)
(14)	Wind	WSAvg	2.4	2.4	2.6	2.8	2.8	2.5	2.2	2.1	2.0	2.1	2.3	2.5	2.4	(14)
(15)	Precipitation	PrecAvg	642	38	35	40	46	68	79	64	52	59	61	53	46	(15)
(16)		PrecMax	905	77	69	80	124	197	221	175	147	159	136	121	116	(16)
(17)		PrecMin	305	5	1	6	1	18	24	13	2	8	1	5	2	(17)
(18)		PrecStd	146	19	18	21	27	40	39	39	36	35	39	26	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	18.3	22.6	27.8	30.8	33.9	35.7	36.5	32.7	26.6	21.1	14.1	(19)
(20)		MCWB	10.4	10.8	13.1	16.4	18.9	22.2	22.3	21.9	20.2	17.7	15.1	10.8		(20)
(21)		2%	DB	10.7	14.9	20.1	24.7	28.6	32.2	33.6	33.9	29.5	24.5	18.4	11.3	(21)
(22)		MCWB	8.4	9.9	12.0	15.2	18.3	21.7	22.2	21.4	18.9	16.7	13.6	9.3		(22)
(23)		5%	DB	8.5	12.2	17.5	22.3	26.9	30.4	31.7	32.0	27.2	22.3	16.0	9.4	(23)
(24)		MCWB	7.0	8.5	11.0	13.8	17.8	21.0	21.6	21.1	18.3	15.8	12.3	8.0		(24)
(25)		10%	DB	6.6	9.7	15.0	20.3	25.1	28.6	29.9	29.9	25.0	19.9	14.0	7.5	(25)
(26)		MCWB	5.6	7.4	9.7	13.1	17.1	20.1	20.8	20.5	17.7	14.9	11.5	6.5		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	11.8	14.2	17.4	20.6	24.1	24.6	24.3	21.2	18.8	15.5	11.4	(27)
(28)		MCDWB	13.3	16.0	20.7	25.2	26.9	31.1	31.8	31.1	29.2	24.5	19.9	13.6		(28)
(29)		2%	WB	8.6	10.2	12.7	15.8	19.4	22.7	23.3	23.0	20.0	17.5	14.0	9.5	(29)
(30)		MCDWB	10.5	13.8	18.5	23.0	26.1	29.6	30.7	30.3	26.8	22.7	17.6	11.2		(30)
(31)		5%	WB	7.1	8.8	11.5	14.8	18.6	21.8	22.4	22.1	19.1	16.4	12.7	8.0	(31)
(32)		MCDWB	8.3	11.8	16.5	20.7	25.1	28.6	29.6	29.3	25.3	21.0	15.4	9.2		(32)
(33)		10%	WB	5.7	7.5	10.2	13.8	17.8	21.0	21.6	21.3	18.2	15.3	11.4	6.5	(33)
(34)		MCDWB	6.6	9.8	14.4	18.8	23.6	26.9	28.1	28.0	23.6	19.2	13.8	7.4		(34)
(35)	Mean Daily Temperature Range	MDBR	5.9	8.1	10.4	11.1	11.0	11.4	12.4	12.7	11.4	10.4	7.8	5.4	(35)	
(36)		5% DB	MCDBR	9.0	13.4	15.3	15.0	14.3	14.6	15.7	16.3	15.0	13.8	11.1	8.6	(36)
(37)		MCWBR	6.9	8.4	8.3	6.9	5.4	5.6	5.8	5.6	6.0	6.8	6.7	6.6	(37)	
(38)		5% WB	MCDBR	8.7	11.8	13.4	13.1	12.7	13.0	13.9	13.8	13.2	12.7	10.5	8.2	(38)
(39)		MCWBR	6.8	7.7	7.5	6.4	5.4	5.5	5.8	5.6	5.7	6.8	6.5	6.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.370	0.402	0.459	0.446	0.442	0.446	0.451	0.433	0.398	0.361	0.342	(40)	
(41)		taud	2.351	2.267	2.219	2.073	2.169	2.219	2.202	2.190	2.209	2.305	2.365	2.360	(41)	
(42)		Ebn at Noon	750	795	821	802	827	831	822	801	779	754	722	709	(42)	
(43)		Edh at Noon	79	102	123	154	145	139	139	136	123	98	78	71	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.24	2.04	3.28	4.53	5.54	6.10	6.20	5.52	3.84	2.64	1.56	1.01	(44)	
(45)		RadStd	0.18	0.28	0.40	0.46	0.50	0.53	0.47	0.55	0.43	0.29	0.14	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.67	N/A	N/A	N/A	+0.59	N/A	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	+0.67	N/A	N/A	N/A	+0.40	+0.45	-126	-187	+116	+61

Nomenclature: See separate page