

BEOGRAD BATAJNICA, Serbia

WMO: 132725

Lat: 44.935N

Lon: 20.258E

Elev: 265

StdP: 14.56

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	17.4	7.1	8.0	14.3	12.6	10.6	19.0	23.2	33.8	21.1	36.0	6.4	320	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	24.9	95.2	70.5	91.7	70.4	89.3	69.7	74.1	87.0	72.5	86.2	71.0	84.6	7.4	100

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	111.7	79.2	68.2	104.8	77.3	66.6	98.7	75.3	37.8	86.9	36.2	86.5	35.0	85.3	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
21.0	18.2	15.7	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			2.0	98.6	9.1	3.8	-4.6	101.4	-9.9	103.6	-15.0	105.8	-21.7	108.5		
			1.5	77.1	9.0	1.7	-5.0	78.3	-10.3	79.3	-15.3	80.3	-21.9	81.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.5	32.9	37.2	45.6	55.6	62.8	70.0	73.2	73.5	65.0	54.8	46.8	36.1	(6)
	DBStd	15.88	9.14	9.25	7.89	6.54	6.35	5.93	5.37	5.63	7.15	7.33	8.05	8.53	(7)
	HDD50	1719	532	362	176	22	1	0	0	0	1	38	152	435	(8)
	HDD65	4661	995	778	600	288	118	22	5	6	87	320	546	896	(9)
	CDD50	3379	2	4	41	191	397	600	720	728	450	187	55	4	(10)
	CDD65	846	0	0	0	6	49	171	260	268	87	5	0	0	(11)
	CDH74	9935	0	0	4	154	567	1898	3018	3200	976	117	1	0	(12)
	CDH80	4190	0	0	0	29	117	755	1382	1554	343	10	0	0	(13)
(14) Wind	WSAvg	6.4	6.6	7.6	7.6	7.4	6.3	5.7	5.4	5.1	5.6	6.1	6.9	6.5	(14)
(15) Precipitation	PrecAvg	26.3	1.7	1.5	1.8	2.0	2.6	3.3	2.6	2.1	2.5	2.1	1.9	2.0	(15)
	PrecMax	39.8	3.3	3.5	4.6	5.8	9.6	6.9	9.3	5.0	7.4	4.5	5.3	5.5	(16)
	PrecMin	13.9	0.3	0.0	0.2	0.1	0.7	0.7	0.4	0.1	0.4	0.0	0.1	0.2	(17)
	PrecStd	6.3	0.8	0.8	1.3	1.1	1.7	1.8	2.2	1.4	1.4	1.3	1.1	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.8	66.3	73.6	84.0	87.5	93.6	98.6	100.3	93.2	80.8	71.9	60.9	(19)
		MCWB	51.5	52.6	55.7	63.4	67.4	71.2	71.5	70.2	68.7	63.3	59.7	53.5	(20)
	2%	DB	53.3	59.4	69.6	78.8	82.7	91.2	95.1	96.6	88.1	77.3	67.8	55.8	(21)
		MCWB	48.0	50.1	53.3	60.7	65.3	72.2	71.0	69.8	66.6	61.7	57.4	50.2	(22)
	5%	DB	48.5	55.0	64.7	73.7	80.4	87.8	91.4	92.8	83.9	73.5	62.8	51.8	(23)
		MCWB	45.9	47.6	51.6	57.6	64.6	70.3	70.8	69.5	65.4	60.0	55.1	47.2	(24)
	10%	DB	44.9	50.2	60.5	69.9	77.0	84.4	87.8	89.2	79.2	68.4	59.0	47.8	(25)
		MCWB	42.9	45.4	49.2	56.4	63.1	68.8	70.0	69.3	63.7	58.6	53.1	45.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.6	53.8	57.6	64.6	69.1	76.9	75.8	75.3	70.5	65.7	60.6	54.9	(27)
		MCDB	56.9	64.5	71.4	80.4	83.1	89.0	89.2	85.7	88.5	76.8	70.1	58.3	(28)
	2%	WB	48.8	50.9	54.5	61.5	67.1	73.8	74.1	73.0	68.5	63.2	57.9	50.9	(29)
		MCDB	51.9	58.2	65.6	75.0	80.1	85.5	87.4	87.6	82.8	74.2	66.0	55.6	(30)
	5%	WB	46.0	48.4	52.4	59.4	65.5	71.7	72.5	71.7	66.8	61.1	55.6	47.9	(31)
		MCDB	48.4	53.7	62.7	70.8	77.6	83.0	86.4	86.9	79.6	71.1	61.7	51.6	(32)
	10%	WB	43.0	45.8	50.3	57.4	63.9	70.0	70.9	70.3	65.2	59.2	53.5	44.7	(33)
		MCDB	44.7	49.5	58.4	67.4	74.7	81.4	84.5	84.9	76.6	67.7	58.5	46.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	15.3	19.7	21.7	20.7	21.3	23.4	24.9	21.9	20.6	16.7	12.5	(35)
		MCDBR	19.2	24.9	29.6	29.8	26.1	27.1	29.5	31.8	29.2	28.5	22.8	20.0	(36)
	5% WB	MCWBR	14.8	15.8	16.0	14.5	11.6	10.8	10.2	10.7	11.1	14.6	13.7	14.7	(37)
		MCWBR	18.0	22.4	25.8	25.0	23.9	23.9	25.3	26.1	24.4	26.5	21.6	19.2	(38)
(40) Clear-Sky Solar Irradiance	taub		0.348	0.374	0.406	0.463	0.450	0.445	0.449	0.457	0.437	0.401	0.363	0.345	(40)
		taud	2.332	2.247	2.206	2.056	2.158	2.208	2.194	2.171	2.196	2.292	2.353	2.350	(41)
	Ebn at Noon		236	251	259	253	261	263	260	252	246	239	228	224	(42)
		Edh at Noon	26	33	40	50	47	44	45	44	40	31	25	23	(43)
(44) All-Sky Solar Radiation	RadAvg		391	652	1044	1440	1756	1945	1969	1748	1223	841	508	325	(44)
	RadStd		53	87	126	145	165	178	149	167	134	92	43	48	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (51 neighbors)		+1.21	N/A	N/A	N/A	+0.65	N/A	-209	-322	+212	+110	

Nomenclature: See separate page