

CRNI VRH, Serbia

WMO: 132890

Lat: 44.1297N

Lon: 21.9642E

Elev: 1039

StdP: 89.45

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.5	-12.6	-17.6	0.9	-14.5	-14.6	1.2	-11.2	14.4	-16.2	12.7	-8.3	8.1	300	0.613

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	27.3	17.4	25.6	17.0	24.1	16.7	19.2	24.1	18.2	23.3	17.5	22.4	3.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.4	14.2	21.6	16.5	13.3	20.7	15.6	12.6	19.7	59.2	24.3	56.1	23.3	53.4	22.5	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
11.4	10.1	8.9	DB	-17.7	29.8	2.7	2.8	-19.6	31.8	-21.2	33.4	-22.7	35.0	-24.6	37.1	
			WB	-18.1	20.7	2.6	1.0	-20.0	21.5	-21.5	22.1	-23.0	22.7	-24.9	23.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-3.2	-2.0	1.7	7.3	12.1	15.6	17.9	18.2	13.0	7.8	3.1	-1.7
	DBStd	8.94	5.69	5.81	5.34	4.76	4.10	3.98	3.75	3.85	4.33	5.19	5.20	5.25
	HDD10.0	1843	408	337	259	106	26	4	1	1	19	106	215	362
	HDD18.3	4054	667	571	514	333	195	98	54	50	168	326	458	619
	CDD10.0	946	0	1	3	23	92	173	245	255	108	38	7	1
	CDD18.3	114	0	0	0	1	3	17	41	46	7	1	0	0
	CDH23.3	498	0	0	0	1	8	52	199	218	20	0	0	0
	CDH26.7	82	0	0	0	0	0	3	37	40	1	0	0	0
Wind	WSAvg	4.7	5.6	5.6	5.2	4.8	4.3	3.9	4.0	3.9	4.2	4.8	5.2	5.7
Precipitation	PrecAvg	752	49	46	49	69	79	83	66	53	71	70	58	59
	PrecMax	1073	100	95	91	142	161	216	169	163	156	144	135	156
	PrecMin	496	12	7	12	13	27	18	10	2	10	14	7	4
	PrecStd	144	25	23	24	28	38	46	44	39	44	39	31	34
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	13.3	16.2	21.7	24.3	26.9	30.4	30.5	25.8	21.0	17.2	12.6
		MCWB	5.1	7.0	8.5	12.1	15.1	18.3	16.7	17.5	16.5	13.9	9.8	6.2
	2%	DB	8.3	10.1	13.4	18.5	21.4	24.8	27.3	27.6	22.9	18.7	14.0	9.2
		MCWB	4.0	5.0	6.9	10.8	14.1	17.8	17.3	17.5	14.9	12.8	8.5	5.2
	5%	DB	6.5	7.7	11.3	16.0	19.7	23.2	25.4	25.8	21.0	16.7	11.9	7.4
		MCWB	3.5	4.0	5.8	9.6	13.6	17.1	17.1	16.8	14.5	11.9	7.9	4.3
	10%	DB	4.7	5.7	9.2	13.9	18.2	21.8	23.8	24.1	19.1	14.9	10.1	5.6
		MCWB	2.6	3.0	5.1	8.5	12.9	16.3	16.8	16.5	13.7	10.9	7.2	3.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	6.1	7.5	9.1	13.1	16.5	20.2	19.7	20.5	17.5	15.0	10.9	7.8
		MCDB	9.4	12.2	14.8	19.0	21.8	24.3	24.9	25.9	23.4	20.0	14.8	10.3
	2%	WB	4.8	5.7	7.6	11.4	15.2	18.9	18.9	19.0	15.9	13.4	9.6	5.8
		MCDB	7.3	9.1	12.1	16.9	19.7	22.9	24.1	24.6	21.6	17.2	12.6	8.5
	5%	WB	3.8	4.4	6.4	10.2	14.3	17.8	18.1	18.0	15.0	12.4	8.5	4.7
		MCDB	6.0	7.0	10.3	15.0	18.5	21.9	23.2	23.5	19.5	15.8	10.8	7.0
	10%	WB	2.7	3.1	5.3	9.1	13.3	16.8	17.4	17.1	14.1	11.3	7.5	3.5
		MCDB	4.6	5.5	8.7	13.0	17.2	20.9	22.3	22.5	18.1	14.3	9.6	5.5
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.1	5.9	6.8	6.6	6.7	7.3	7.2	6.2	5.6	4.9	4.6
		MCDBR	7.1	7.9	8.7	9.4	8.0	8.0	9.0	8.6	8.2	8.0	7.6	6.9
	5% WB	MCWBR	4.4	4.7	5.0	4.9	4.8	4.9	4.4	4.2	4.3	4.5	4.3	4.4
		MCWBR	6.6	7.1	8.0	8.1	7.4	7.3	7.9	8.0	7.4	7.2	6.6	6.5
Clear-Sky Solar Irradiance	taub	taub	0.297	0.320	0.351	0.398	0.386	0.380	0.386	0.398	0.377	0.345	0.319	0.296
		taud	2.385	2.315	2.322	2.202	2.278	2.321	2.300	2.268	2.311	2.409	2.440	2.420
	Ebn at Noon	Ebn at Noon	825	865	883	863	884	889	878	854	843	827	793	790
		Edh at Noon	76	98	111	136	130	125	127	126	112	89	73	68
All-Sky Solar Radiation	RadAvg	RadAvg	1.33	2.14	3.33	4.51	5.47	6.17	6.25	5.58	3.94	2.62	1.57	1.14
	RadStd	RadStd	0.19	0.30	0.44	0.52	0.53	0.58	0.46	0.53	0.38	0.36	0.20	0.17

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
Station Only	+0.56	N/A	N/A	N/A	+0.44	+0.65	N/A	N/A	N/A	N/A
Regional (56 neighbors)	+0.65	N/A	N/A	N/A	+0.36	N/A	N/A	-167	+107	N/A

Nomenclature: See separate page