

NEGOTIN, Serbia

WMO: 132950

Lat: 44.233N

Lon: 22.550E

Elev: 44

StdP: 100.80

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.9	-8.6	-14.4	1.1	-11.3	-11.2	1.4	-7.7	8.3	-1.1	7.4	1.2	1.1	110	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	34.2	21.7	32.7	21.3	31.1	20.9	23.1	31.0	22.3	30.2	21.6	29.3	1.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.5	15.2	26.9	19.7	14.5	26.1	18.9	13.8	25.2	68.5	30.9	65.6	30.5	62.9	29.3	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	6.2	5.3	-16.0	36.5	4.8	1.9	-19.4	37.9	-22.2	39.0	-24.9	40.1	-28.3	41.5		
(5)			-16.3	24.6	4.6	0.7	-19.7	25.1	-22.4	25.6	-25.0	26.0	-28.4	26.5	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.6	0.3	2.6	7.4	13.1	17.8	21.8	23.9	23.7	18.6	12.4	6.7	1.7	(6)
(7)		DBStd	9.21	4.86	5.40	4.68	3.47	3.15	3.12	2.54	2.76	3.49	4.00	3.91	4.41	(7)
(8)		HDD10.0	1024	303	210	106	11	0	0	0	0	22	114	258		(8)
(9)		HDD18.3	2651	561	440	339	159	49	7	1	2	39	188	351	516	(9)
(10)		CDD10.0	1956	1	3	24	105	241	354	432	426	259	96	13	1	(10)
(11)		CDD18.3	541	0	0	0	3	32	111	174	169	48	3	0	0	(11)
(12)		CDH23.3	5359	0	0	2	46	301	1107	1779	1671	419	36	0	0	(12)
(13)		CDH26.7	2104	0	0	0	7	56	413	764	732	128	5	0	0	(13)
(14)	Wind	WSAvg	1.7	1.7	1.8	2.0	1.8	1.7	1.8	1.6	1.6	1.4	1.4	1.6	(14)	
(15)	Precipitation	PrecAvg	602	42	41	41	51	55	63	53	41	55	53	50	58	(15)
(16)		PrecMax	1100	84	129	86	122	130	260	114	166	216	157	109	149	(16)
(17)		PrecMin	320	8	1	5	0	20	10	6	1	4	4	1	1	(17)
(18)		PrecStd	159	22	31	26	25	28	50	34	38	46	40	31	44	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	18.2	22.6	27.6	30.1	34.8	36.7	36.5	32.8	27.2	20.5	14.8	(19)
(20)			MCWB	9.3	10.9	12.6	16.9	19.5	22.2	21.6	21.9	20.1	18.0	13.8	9.8	(20)
(21)		2%	DB	11.8	15.1	19.9	24.3	28.2	32.6	34.1	34.3	29.9	23.8	16.8	11.4	(21)
(22)			MCWB	7.6	9.4	11.9	15.2	18.8	21.8	21.8	21.6	19.1	16.3	12.1	7.8	(22)
(23)		5%	DB	8.9	12.5	17.2	21.9	26.8	30.8	32.5	32.6	27.8	21.4	14.4	8.9	(23)
(24)			MCWB	5.9	8.1	10.4	14.0	18.1	21.1	21.4	21.0	18.4	15.5	11.3	6.1	(24)
(25)		10%	DB	6.7	9.9	15.0	20.0	25.0	29.1	30.9	30.8	25.6	19.1	12.5	7.2	(25)
(26)			MCWB	4.5	6.5	9.3	13.1	17.3	20.5	21.0	20.6	17.6	14.5	10.4	5.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	11.7	13.7	17.7	21.1	24.1	23.6	24.2	21.2	19.0	14.4	9.9	(27)
(28)			MCD B	14.8	16.4	20.4	25.3	28.8	31.4	32.1	32.3	29.3	25.3	18.5	13.9	(28)
(29)		2%	WB	7.8	9.9	12.2	16.2	19.7	23.0	22.9	22.8	20.0	17.2	13.1	8.1	(29)
(30)			MCD B	11.2	14.1	18.6	22.2	26.5	30.0	31.3	30.8	27.1	22.1	15.6	10.9	(30)
(31)		5%	WB	6.2	8.3	11.0	15.0	18.8	21.9	22.2	21.9	19.1	16.0	11.9	6.7	(31)
(32)			MCD B	8.4	11.8	16.3	20.5	25.1	29.3	30.3	30.1	25.9	20.7	13.7	8.5	(32)
(33)		10%	WB	4.8	7.0	9.7	13.8	17.8	21.0	21.5	21.1	18.2	14.8	10.6	5.4	(33)
(34)			MCD B	6.7	9.6	14.3	18.8	23.8	28.0	29.3	29.1	24.2	18.7	12.5	6.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	7.2	9.1	10.3	10.7	11.3	11.8	12.1	10.8	9.2	6.4	5.6	(35)
(36)			MCD BR	10.9	12.3	14.0	14.6	14.3	14.6	15.2	15.6	14.7	13.7	10.9	9.1	(36)
(37)			MCWBR	7.5	8.1	7.5	7.0	6.3	5.7	5.5	5.4	5.9	7.4	6.8	6.2	(37)
(38)		5% WB	MCD BR	9.6	11.4	13.0	12.8	12.8	13.3	13.3	13.7	12.8	12.6	8.8	8.3	(38)
(39)			MCWBR	6.9	7.7	7.4	6.6	6.2	5.6	5.1	5.2	5.7	7.1	5.8	5.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.348	0.378	0.417	0.479	0.459	0.451	0.463	0.482	0.451	0.408	0.376	0.347	(40)	
(41)		taud	2.267	2.177	2.155	2.006	2.126	2.193	2.164	2.108	2.155	2.263	2.296	2.299	(41)	
(42)		Ebn at Noon	746	788	809	786	818	825	808	776	765	748	708	707	(42)	
(43)		Edh at Noon	87	113	132	166	152	143	145	148	131	103	85	77	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.37	2.17	3.37	4.56	5.55	6.27	6.29	5.59	3.97	2.58	1.49	1.17	(44)	
(45)		RadStd	0.20	0.31	0.45	0.52	0.49	0.55	0.43	0.52	0.36	0.36	0.21	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	+0.82	N/A	N/A	+0.84	+0.50	+0.54	N/A	N/A	N/A	N/A	
(47) Regional (58 neighbors)	+0.62	N/A	N/A	N/A	+0.35	N/A	N/A	-160	+111	+57	

Nomenclature: See separate page