

MOSTAR GNOJNICE, Bosnia and Herzegovina

WMO: 133480

Lat: **43.283N**Lon: **17.846E**Elev: **156**StdP: **14.61**Time Zone: **1.00 (EUC)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	26.5	6.7	7.8	36.6	11.8	10.1	37.3	43.3	37.5	32.6	41.0	4.0	130	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.0	99.5	70.1	96.8	69.3	93.6	68.5	72.8	91.9	71.5	90.0	70.3	88.3	7.7	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.7	102.3	77.3	66.2	97.0	76.4	64.6	91.6	75.7	36.5	91.6	35.4	90.2	34.3	88.3	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	24.7	19.2	15.5	18.5	104.3	3.9	3.6	15.7	106.9	13.4	109.0	11.3	111.0	8.5	113.6	
(5)				16.6	75.5	3.8	1.8	13.9	76.8	11.7	77.8	9.6	78.8	6.9	80.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.0	41.5	45.6	50.9	58.6	65.5	74.2	79.1	79.3	69.7	60.5	51.4	43.2
	DBStd	14.31	6.52	5.97	5.58	4.87	5.63	6.01	4.94	4.68	5.80	5.61	6.39	6.52
	HDD50	768	272	145	56	3	0	0	0	0	0	3	59	230
	HDD65	3241	728	544	436	197	64	7	0	0	22	157	409	677
	CDD50	4428	9	21	84	262	480	726	901	909	590	328	100	18
	CDD65	1428	0	0	0	6	79	283	436	444	162	17	1	0
	CDH74	17122	0	0	11	179	919	3258	5464	5415	1658	217	1	0
	CDH80	8559	0	0	0	29	260	1572	3008	3015	650	25	0	0
Wind	WSAvg	5.0	4.9	5.5	6.2	5.1	4.9	4.8	5.3	5.0	4.7	4.2	4.0	4.9
Precipitation	PrecAvg	59.6	5.7	5.2	5.1	5.2	3.6	3.1	2.2	2.7	5.3	6.6	7.7	7.2
	PrecMax	95.6	11.6	13.3	13.8	9.6	6.9	8.1	5.6	7.2	12.8	14.0	14.4	16.3
	PrecMin	39.0	0.7	0.7	0.8	1.2	1.5	0.8	0.6	0.4	0.9	0.9	3.0	0.7
	PrecStd	12.9	3.4	3.0	2.9	2.0	1.5	1.5	1.4	1.9	3.1	3.3	3.0	4.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	61.0	67.7	75.4	83.9	91.1	98.9	104.1	104.1	95.4	82.7	71.9	62.8
		MCWB	52.0	52.7	55.1	62.0	66.9	71.1	70.0	71.3	67.3	62.5	61.0	56.6
	2%	DB	57.5	62.8	70.2	78.9	86.0	95.4	100.2	100.1	91.4	79.1	68.2	59.4
		MCWB	50.6	51.2	53.0	59.0	65.7	70.2	70.3	70.1	67.0	62.0	58.3	52.8
	5%	DB	55.1	59.3	66.4	75.2	82.5	91.8	96.8	96.8	87.7	76.6	66.0	57.2
		MCWB	48.8	49.9	52.0	56.8	63.8	69.3	69.2	69.1	65.3	61.5	57.1	50.3
	10%	DB	51.9	57.0	62.6	71.6	79.1	89.2	93.5	93.6	83.8	73.1	62.8	54.0
		MCWB	46.2	48.5	50.2	55.3	62.6	68.1	68.5	68.4	64.2	60.1	55.6	47.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.7	56.1	57.5	62.9	68.9	74.1	74.0	74.3	70.3	66.6	62.6	57.6
		MCDB	58.7	62.2	68.2	80.7	85.3	92.5	93.6	94.6	84.8	74.3	68.3	61.8
	2%	WB	52.3	53.8	55.5	60.5	66.7	72.1	72.6	72.7	68.8	64.8	60.5	54.9
		MCDB	56.5	61.0	64.8	74.0	82.6	91.6	91.5	91.8	83.4	73.3	66.3	58.7
	5%	WB	50.0	51.7	53.8	58.7	65.2	70.4	71.2	71.3	67.4	63.3	58.4	52.3
		MCDB	53.2	57.5	63.4	70.8	79.9	88.1	89.6	89.7	81.8	71.3	64.5	56.0
	10%	WB	47.6	49.7	51.7	57.1	63.5	69.0	70.1	70.1	66.1	61.7	56.4	49.7
		MCDB	50.7	54.8	60.3	67.6	76.5	85.2	88.4	88.4	79.5	69.8	61.5	52.9
Mean Daily Temperature Range	5% DB	MDBR	16.4	17.8	19.1	22.0	22.2	23.8	26.0	27.1	24.2	22.5	19.0	17.4
		MCDBR	19.5	23.6	27.6	30.8	28.0	29.3	31.5	31.9	30.4	28.7	22.8	18.5
		MCWBR	12.6	13.6	13.9	13.9	11.6	10.0	9.3	9.2	10.5	13.6	13.1	11.7
	5% WB	MCDBR	14.3	17.1	23.2	25.3	26.2	27.2	27.5	28.4	24.9	21.6	17.8	12.0
		MCWBR	10.4	10.6	12.7	12.0	11.4	10.0	8.7	9.0	9.9	11.4	11.0	8.7
Clear-Sky Solar Irradiance	taub	0.330	0.357	0.405	0.455	0.449	0.440	0.436	0.442	0.416	0.389	0.357	0.329	
	taud	2.399	2.305	2.204	2.099	2.173	2.252	2.258	2.238	2.297	2.355	2.390	2.416	
	Ebn at Noon	252	262	262	258	263	265	265	259	256	248	238	240	
	Edh at Noon	25	32	40	48	46	43	42	42	36	30	25	23	
All-Sky Solar Radiation	RadAvg	489	718	1100	1443	1800	2063	2132	1898	1356	921	556	434	
	RadStd	57	92	149	169	146	141	138	150	98	91	69	76	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (23 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	-171	+194	N/A