

MOSTAR GNOJNICE, Bosnia and Herzegovina

WMO: 133480

Lat: **43.283N**Lon: **17.846E**Elev: **48**StdP: **100.76**Time Zone: **1.00 (EUC)**Period: **99-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.8	-3.1	-14.1	1.1	2.6	-11.2	1.4	2.9	19.4	3.1	14.6	5.0	1.8	130	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	37.5	21.2	36.0	20.7	34.2	20.3	22.6	33.3	22.0	32.2	21.3	31.3	3.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.8	14.6	25.2	19.0	13.9	24.6	18.1	13.1	24.3	67.0	33.1	64.4	32.3	61.9	31.3	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.0	8.6	6.9	-7.5	40.2	2.2	2.0	-9.0	41.6	-10.3	42.8	-11.5	43.9	-13.1	45.3		
(5)			-8.6	24.2	2.1	1.0	-10.1	24.9	-11.3	25.4	-12.4	26.0	-14.0	26.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	5.3	7.5	10.5	14.8	18.6	23.5	26.2	26.3	20.9	15.8	10.8	6.2
	DBStd	7.95	3.62	3.31	3.10	2.71	3.13	3.34	2.74	2.60	3.22	3.12	3.55	3.62
	HDD10.0	427	151	81	31	2	0	0	0	0	0	2	33	128
	HDD18.3	1801	404	302	242	109	36	4	0	0	12	87	227	376
	CDD10.0	2460	5	12	47	146	267	403	501	505	328	182	56	10
	CDD18.3	793	0	0	0	3	44	157	242	247	90	9	1	0
	CDH23.3	9512	0	0	6	99	511	1810	3036	3008	921	121	1	0
	CDH26.7	4755	0	0	0	16	144	873	1671	1675	361	14	0	0
Wind	WSAvg	2.2	2.2	2.5	2.8	2.3	2.2	2.2	2.4	2.2	2.1	1.9	1.8	2.2
Precipitation	PrecAvg	1515	146	133	129	133	92	79	56	68	134	168	196	182
	PrecMax	2427	294	338	351	244	175	207	142	184	324	355	366	415
	PrecMin	990	17	19	20	30	38	20	16	10	24	23	76	18
	PrecStd	327	87	75	74	50	38	39	36	49	80	83	77	104
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.1	19.8	24.1	28.9	32.8	37.2	40.1	40.1	35.2	28.2	22.2	17.1
		MCWB	11.1	11.5	12.9	16.6	19.4	21.7	21.1	21.8	19.6	16.9	16.1	13.7
	2%	DB	14.2	17.1	21.2	26.0	30.0	35.2	37.9	37.8	33.0	26.2	20.1	15.2
		MCWB	10.3	10.7	11.7	15.0	18.7	21.2	21.3	21.2	19.4	16.6	14.6	11.6
	5%	DB	12.9	15.2	19.1	24.0	28.1	33.2	36.0	36.0	31.0	24.8	18.9	14.0
		MCWB	9.3	9.9	11.1	13.8	17.7	20.7	20.7	20.6	18.5	16.4	13.9	10.2
	10%	DB	11.1	13.9	17.0	22.0	26.1	31.8	34.1	34.2	28.8	22.8	17.1	12.2
		MCWB	7.9	9.2	10.1	12.9	17.0	20.0	20.3	20.2	17.9	15.6	13.1	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.6	13.4	14.1	17.2	20.5	23.4	23.3	23.5	21.3	19.2	17.0	14.2
		MCDB	14.9	16.8	20.1	27.1	29.6	33.6	34.2	34.8	29.3	23.5	20.2	16.6
	2%	WB	11.3	12.1	13.0	15.8	19.3	22.3	22.6	22.6	20.4	18.2	15.8	12.7
		MCDB	13.6	16.1	18.2	23.4	28.1	33.1	33.1	33.2	28.6	23.0	19.0	14.8
	5%	WB	10.0	10.9	12.1	14.8	18.4	21.4	21.8	21.8	19.7	17.4	14.7	11.3
		MCDB	11.8	14.1	17.5	21.6	26.6	31.2	32.0	32.0	27.7	21.9	18.0	13.3
	10%	WB	8.7	9.8	11.0	13.9	17.5	20.6	21.2	21.1	19.0	16.5	13.6	9.8
		MCDB	10.4	12.7	15.7	19.8	24.7	29.6	31.4	31.4	26.4	21.0	16.4	11.6
Mean Daily Temperature Range	5% DB	MDBR	9.1	9.9	10.6	12.2	12.3	13.2	14.4	15.1	13.4	12.5	10.5	9.6
		MCDBR	10.8	13.1	15.3	17.1	15.5	16.3	17.5	17.7	16.9	15.9	12.7	10.3
		MCWBR	7.0	7.5	7.7	7.7	6.4	5.6	5.2	5.1	5.8	7.6	7.3	6.5
	5% WB	MCDBR	7.9	9.5	12.9	14.1	14.5	15.1	15.3	15.8	13.8	12.0	9.9	6.7
		MCWBR	5.8	5.9	7.1	6.7	6.3	5.6	4.8	5.0	5.5	6.3	6.1	4.8
Clear-Sky Solar Irradiance	taub	0.330	0.357	0.405	0.455	0.449	0.440	0.436	0.442	0.416	0.389	0.357	0.329	
	taud	2.399	2.305	2.204	2.099	2.173	2.252	2.258	2.238	2.297	2.355	2.390	2.416	
	Ebn at Noon	793	827	827	812	829	836	834	816	808	781	751	757	
	Edh at Noon	78	101	127	152	145	135	133	131	115	96	79	71	
All-Sky Solar Radiation	RadAvg	1.54	2.26	3.47	4.55	5.67	6.50	6.72	5.98	4.28	2.90	1.75	1.37	
	RadStd	0.18	0.29	0.47	0.53	0.46	0.45	0.43	0.47	0.31	0.29	0.22	0.24	