

POZEGA UZICKA, Serbia

WMO: 133700

Lat: 43.833N

Lon: 20.033E

Elev: 312

StdP: 97.63

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.5	-10.2	-15.3	1.0	-12.7	-11.8	1.4	-9.4	5.5	4.0	4.5	4.3	0.3	260	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.1	33.0	20.9	31.2	20.5	29.5	20.1	22.8	29.3	21.9	28.3	21.0	27.3	1.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.9	16.2	25.4	19.9	15.1	24.4	19.0	14.4	23.4	68.9	29.5	65.3	28.3	62.2	27.2	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.3	3.4	2.9	-19.0	35.5	4.1	1.7	-21.9	36.7	-24.3	37.7	-26.7	38.7	-29.6	39.9		
(5)			-18.5	25.0	4.6	1.0	-21.8	25.7	-24.5	26.2	-27.1	26.8	-30.4	27.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	-1.0	1.8	6.5	11.4	15.7	19.6	21.1	21.2	16.8	11.3	5.9	0.5
	DBStd	8.61	4.75	4.90	4.12	3.25	3.36	3.36	2.68	2.64	3.53	3.87	4.05	4.05
	HDD10.0	1176	340	229	121	21	2	0	0	0	1	33	133	295
	HDD18.3	2979	598	462	367	208	93	26	7	7	68	219	372	552
	CDD10.0	1525	0	1	13	64	179	287	345	347	206	73	11	1
	CDD18.3	287	0	0	0	1	11	63	94	96	23	1	0	0
	CDH23.3	3155	0	0	2	37	199	698	972	965	269	13	0	0
	CDH26.7	1142	0	0	0	6	38	241	370	400	87	1	0	0
Wind	WSAvg	0.9	0.7	0.9	1.1	1.1	1.1	1.0	1.0	1.0	0.8	0.7	0.6	0.8
Precipitation	PrecAvg	773	45	48	57	64	83	91	75	60	74	63	59	56
	PrecMax	1199	102	100	163	177	211	198	224	159	164	153	112	123
	PrecMin	542	13	16	5	23	30	38	14	2	16	2	5	7
	PrecStd	153	25	21	35	34	37	39	44	40	40	38	27	27
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	18.1	22.5	27.5	30.1	33.1	34.5	36.1	32.5	25.1	21.5	15.6
		MCWB	8.9	10.7	12.3	15.7	17.8	21.7	21.3	20.8	18.9	16.6	14.1	10.6
	2%	DB	9.4	14.6	19.6	23.7	27.6	31.4	32.6	33.3	29.2	22.9	18.1	11.7
		MCWB	6.6	9.0	10.9	14.0	17.7	21.2	21.3	20.6	18.4	16.0	12.5	8.5
	5%	DB	6.6	11.3	17.4	21.4	25.8	29.6	30.7	30.9	26.3	20.2	14.7	7.4
		MCWB	5.2	7.4	10.2	12.8	17.0	20.6	20.9	20.3	17.9	14.6	11.1	5.8
	10%	DB	4.3	8.3	14.6	19.1	23.7	27.7	28.6	28.7	23.8	17.7	11.9	5.6
		MCWB	3.4	6.1	9.0	11.8	16.4	19.9	20.4	20.1	17.2	13.7	9.6	4.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.1	11.1	13.2	16.7	19.9	23.7	24.0	23.8	20.7	18.1	15.1	10.6
		MCDB	13.4	17.0	19.8	23.9	26.2	29.5	30.0	29.1	26.2	23.1	20.0	14.9
	2%	WB	7.0	9.4	11.8	15.0	18.7	22.4	22.8	22.5	19.6	16.6	13.1	8.4
		MCDB	9.2	13.4	17.9	22.2	24.6	28.9	29.2	29.0	25.7	20.7	17.2	11.0
	5%	WB	5.2	7.7	10.5	13.7	18.0	21.4	21.8	21.5	18.6	15.2	11.4	6.2
		MCDB	6.6	10.8	16.1	19.2	23.9	27.7	28.2	28.0	24.1	19.0	14.3	7.2
	10%	WB	3.5	6.2	9.3	12.7	17.0	20.5	20.9	20.7	17.8	14.1	9.9	4.8
		MCDB	4.3	8.3	14.2	17.7	22.5	26.5	27.1	26.8	22.7	17.4	11.8	5.5
Mean Daily Temperature Range	5% DB	MDBR	7.4	9.5	11.7	13.1	12.3	12.2	13.1	13.8	12.1	10.8	8.9	5.9
		MCDBR	10.7	15.9	18.0	18.9	16.9	16.2	17.6	19.1	17.2	15.9	14.1	10.1
		MCWBR	7.7	10.1	9.6	9.3	7.6	6.9	7.2	7.3	7.1	8.8	9.0	7.3
	5% WB	MCDBR	10.1	14.3	15.9	15.3	14.4	14.9	15.0	14.9	14.1	14.0	12.8	9.1
		MCWBR	7.4	9.3	8.8	7.9	7.2	6.8	7.0	6.6	6.3	8.1	8.3	6.9
Clear-Sky Solar Irradiance	taub	0.326	0.354	0.394	0.451	0.446	0.438	0.440	0.448	0.424	0.383	0.344	0.323	
	taud	2.368	2.260	2.210	2.085	2.155	2.224	2.220	2.193	2.235	2.345	2.399	2.388	
	Ebn at Noon	789	824	835	814	830	837	830	808	795	783	761	754	
	Edh at Noon	79	105	125	154	148	138	137	137	121	96	77	71	
All-Sky Solar Radiation	RadAvg	1.40	2.20	3.35	4.31	5.27	5.95	6.13	5.54	3.87	2.71	1.70	1.20	
	RadStd	0.20	0.26	0.40	0.52	0.51	0.58	0.48	0.52	0.41	0.33	0.18	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)	+0.64	N/A	N/A	N/A	+0.36	N/A	N/A	-135	+106	N/A

Nomenclature: See separate page