

UZICE-PONIKVE, Serbia

WMO: 133766

Lat: 43.900N

Lon: 19.700E

Elev: 2966

StdP: 13.19

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.9	12.5	2.9	7.1	9.4	8.6	9.5	16.9	19.6	32.3	17.6	31.2	5.8	310	0.501

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	19.3	85.6	63.8	82.5	63.9	79.1	63.3	68.3	77.5	66.5	75.8	65.2	74.9	6.4	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	102.6	71.4	64.0	99.5	71.0	62.2	93.5	69.5	34.4	77.1	33.1	75.8	31.9	74.8	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.8	14.5	12.7	DB	2.5	88.9	4.7	3.9	-0.9	91.7	-3.6	94.0	-6.2	96.2	-9.6	99.0	(4)
(5)			WB	1.8	71.0	4.7	1.2	-1.6	71.9	-4.3	72.6	-6.9	73.3	-10.3	74.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	48.4	29.8	31.9	38.8	48.6	54.9	61.7	65.2	66.8	58.0	49.2	43.1	32.1
	DBStd	15.18	10.10	10.94	8.83	7.78	7.09	6.89	6.33	6.19	8.27	8.26	8.74	9.34
	HDD50	2574	626	508	355	112	35	2	0	0	25	119	236	556
	HDD65	6314	1091	925	811	493	318	141	76	53	238	491	658	1019
	CDD50	2003	0	3	9	71	186	354	470	522	264	94	28	2
	CDD65	269	0	0	0	1	5	43	82	109	28	1	0	0
	CDH74	2303	0	0	0	6	36	333	711	983	228	6	0	0
	CDH80	557	0	0	0	0	3	47	177	280	49	1	0	0
Wind	WSAvg	5.6	5.8	6.1	6.5	6.3	5.8	5.4	5.0	4.6	4.9	5.0	5.3	6.0
Precipitation	PrecAvg	35.5	2.1	2.4	2.7	2.9	3.7	3.8	3.3	2.6	3.6	2.9	2.9	2.8
	PrecMax	52.6	4.8	4.7	7.2	7.8	7.7	7.8	7.8	6.1	7.7	6.1	5.3	6.6
	PrecMin	24.8	0.6	0.7	0.4	0.8	1.7	1.1	0.7	0.1	0.9	0.1	0.3	0.3
	PrecStd	6.4	1.1	1.0	1.6	1.5	1.3	1.5	1.6	1.6	1.9	1.6	1.3	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	60.4	64.6	74.9	78.5	84.3	87.9	91.2	85.8	73.5	64.8	57.0
		MCWB	44.3	47.5	49.0	54.2	61.1	65.3	64.3	61.7	62.0	54.3	51.5	48.0
	2%	DB	49.9	53.8	59.3	69.8	73.5	80.8	84.4	86.3	80.3	69.7	62.3	53.4
		MCWB	43.3	44.1	46.3	53.3	59.6	64.3	64.6	63.2	60.5	54.7	50.7	45.4
	5%	DB	46.6	50.1	55.6	64.7	70.0	78.4	82.0	82.7	75.4	66.0	58.8	49.9
		MCWB	41.4	42.3	45.0	50.4	57.2	64.5	65.1	63.2	59.2	54.3	49.2	43.4
	10%	DB	43.1	46.5	52.1	61.0	67.6	75.0	78.4	79.1	71.4	62.3	55.3	46.1
		MCWB	39.1	40.3	43.0	48.8	56.7	62.9	64.7	62.5	58.7	53.0	47.6	41.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	45.6	47.7	49.9	57.3	64.0	70.1	70.1	69.3	64.8	58.9	54.4	48.6
		MCDB	51.7	57.5	60.5	68.1	72.1	77.4	79.0	79.4	74.5	68.5	62.2	55.2
	2%	WB	43.4	45.4	48.0	54.7	61.3	67.8	68.4	67.3	62.7	56.5	51.9	45.9
		MCDB	48.7	53.1	57.2	65.5	70.0	75.8	77.8	77.8	74.3	64.8	59.4	52.5
	5%	WB	41.6	42.8	46.3	52.5	59.4	66.0	66.5	65.7	61.0	55.1	49.9	43.3
		MCDB	45.8	48.5	53.9	62.3	67.1	74.0	76.0	76.4	71.8	63.0	57.5	48.6
	10%	WB	39.4	40.7	44.0	50.5	57.5	64.1	65.3	64.2	59.5	53.6	47.9	41.0
		MCDB	42.7	45.2	51.0	59.2	64.5	72.8	75.0	75.3	69.6	61.3	53.7	45.0
Mean Daily Temperature Range	5% DB	MDBR	10.6	11.6	13.5	15.5	15.7	16.3	18.1	19.3	16.8	15.1	13.2	11.0
		MCDBR	13.7	17.6	19.6	21.2	19.7	20.6	22.8	23.3	22.5	21.0	17.5	15.4
		MCWBR	8.6	10.1	10.5	10.4	10.3	10.8	10.0	9.6	9.1	10.1	9.3	9.6
	5% WB	MCDBR	13.0	15.4	18.0	18.8	17.7	18.9	19.7	19.4	19.2	18.6	15.9	14.1
		MCWBR	8.5	9.4	10.2	10.3	10.7	11.1	10.3	9.8	9.4	10.6	9.4	9.5
Clear-Sky Solar Irradiance	taub	0.297	0.322	0.358	0.406	0.403	0.396	0.397	0.403	0.383	0.348	0.314	0.296	
	taud	2.423	2.333	2.301	2.195	2.251	2.304	2.296	2.278	2.321	2.424	2.466	2.444	
	Ebn at Noon	264	274	278	272	276	278	275	270	266	262	255	253	
	Edh at Noon	23	31	36	43	43	41	40	40	35	28	23	21	
All-Sky Solar Radiation	RadAvg	444	693	1062	1362	1668	1879	1939	1750	1221	858	536	376	
	RadStd	63	81	127	166	158	182	152	164	133	102	58	60	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+1.12	N/A	N/A	N/A	+0.67	N/A	N/A	-214	+180	N/A

Nomenclature: See separate page