

KRUSEVAC, Serbia

WMO: 133830

Lat: 43.5641N

Lon: 21.3400E

Elev: 548

StdP: 14.41

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 12.0	(c) 17.3	(d) 8.0	(e) 8.4	(f) 14.0	(g) 12.9	(h) 10.8	(i) 18.9	(j) 16.7	(k) 36.4	(l) 14.5	(m) 39.7	(n) 2.7	(o) 160	(p) 0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.3	94.4	69.4	91.0	68.7	87.8	68.0	73.4	84.8	71.8	83.8	70.3	82.5	4.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.2	113.5	77.7	68.3	106.3	75.9	66.7	100.4	74.2	37.3	84.8	35.8	83.7	34.6	82.6	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.2	(b) 11.8	(c) 9.9	(e) 3.4	(f) 99.2	(g) 7.4	(h) 3.9	(i) -1.9	(j) 102.0	(k) -6.3	(l) 104.3	(m) -10.4	(n) 106.5	(o) -15.8	(p) 109.3		
(a) 14.2	(b) 11.8	(c) 9.9	(e) 3.0	(f) 76.5	(g) 7.1	(h) 2.3	(i) -2.1	(j) 78.2	(k) -6.3	(l) 79.6	(m) -10.3	(n) 80.8	(o) -15.4	(p) 82.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.9	33.4	37.3	44.8	54.3	62.3	69.2	72.6	72.4	64.0	53.9	45.4	35.7
	DBStd	15.63	8.71	9.34	8.13	6.86	6.23	6.01	5.24	5.48	6.58	7.65	8.40	8.32
	HDD50	1807	517	363	201	37	1	0	0	0	1	51	187	449
	HDD65	4817	980	776	628	326	126	27	5	8	96	349	588	908
	CDD50	3213	2	7	39	165	384	577	699	695	419	171	49	6
	CDD65	748	0	0	0	4	43	154	239	238	65	5	0	0
	CDH74	8380	0	0	3	98	557	1714	2626	2562	724	94	2	0
	CDH80	3426	0	0	0	18	128	659	1175	1191	242	13	0	0
(14) Wind	WSAvg	3.5	3.2	3.7	4.4	4.1	3.6	3.6	3.4	3.1	3.1	2.9	3.2	3.3
(15) Precipitation	PrecAvg	26.4	1.7	1.7	2.0	2.5	2.8	2.8	2.3	1.8	2.3	2.2	2.0	2.2
	PrecMax	40.1	4.6	4.0	5.0	6.6	6.4	5.2	7.0	5.7	5.4	4.8	5.2	4.5
	PrecMin	16.6	0.4	0.5	0.2	0.2	0.8	0.9	0.4	0.0	0.4	0.1	0.0	0.2
	PrecStd	5.5	1.0	0.8	1.1	1.3	1.5	1.3	1.5	1.3	1.3	1.3	1.2	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.7	66.9	73.5	82.6	87.4	93.9	99.0	100.1	92.6	81.6	71.7	62.1
		MCWB	50.1	52.3	55.6	62.2	65.6	70.4	69.6	69.6	66.9	62.7	57.3	52.3
	2%	DB	54.0	60.9	68.5	76.2	83.4	90.4	94.1	94.9	86.1	76.4	67.3	56.6
		MCWB	47.6	50.1	52.8	58.4	64.9	69.7	69.6	69.2	65.0	61.0	56.2	49.3
	5%	DB	50.0	56.4	63.8	72.0	80.3	87.2	90.5	90.9	81.7	72.0	63.3	52.0
		MCWB	45.3	47.9	50.7	56.1	63.9	68.7	69.1	68.2	63.8	59.7	54.5	47.2
	10%	DB	45.9	51.9	59.4	68.1	76.5	83.8	86.8	87.2	77.4	67.8	59.2	47.2
		MCWB	42.6	45.7	49.1	54.7	62.8	67.7	68.3	67.6	62.5	58.2	52.4	43.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	54.2	56.5	63.6	70.3	75.6	75.1	75.4	69.6	65.5	59.8	53.2
		MCDB	57.6	63.6	70.1	76.7	78.5	86.0	85.7	86.7	82.1	73.4	68.5	59.6
	2%	WB	48.2	50.7	54.1	60.5	67.4	72.9	73.1	73.0	67.4	63.4	57.1	50.1
		MCDB	53.2	59.1	64.8	71.9	78.5	83.8	84.9	85.0	78.7	72.3	64.6	55.4
	5%	WB	45.6	48.4	51.9	58.1	65.6	71.0	71.6	71.2	65.7	61.2	55.3	47.3
		MCDB	49.4	55.5	61.5	68.2	76.8	82.5	83.7	83.7	76.4	69.8	62.3	52.0
	10%	WB	42.8	46.0	49.9	56.2	63.8	69.2	70.1	69.7	64.2	59.0	53.0	44.1
		MCDB	45.8	51.4	58.4	65.2	73.9	80.5	82.5	82.4	74.5	66.3	58.8	47.0
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	15.7	18.5	20.8	21.3	22.1	23.3	24.5	21.7	19.7	17.0	12.2
		MCDBR	19.9	26.0	28.7	30.2	28.9	29.0	31.6	33.1	30.1	28.1	23.2	18.9
		MCWBR	13.8	15.3	14.5	13.4	12.2	11.1	10.5	10.6	11.1	13.9	12.8	12.6
	5% WB	MCDBR	19.2	23.1	24.7	25.1	25.4	26.0	25.3	26.0	24.2	24.9	20.7	17.8
		MCWBR	13.8	14.4	13.2	12.3	12.6	11.7	10.6	10.9	10.6	13.6	12.1	12.2
(40) Clear-Sky Solar Irradiance	taub		0.341	0.369	0.408	0.467	0.456	0.447	0.447	0.461	0.439	0.398	0.362	0.338
	taud		2.321	2.227	2.185	2.043	2.135	2.207	2.206	2.165	2.194	2.300	2.347	2.346
	Ebn at Noon		244	256	261	253	261	263	261	253	248	243	234	233
	Edh at Noon		27	35	41	51	48	45	44	45	40	32	26	24
(44) All-Sky Solar Radiation	RadAvg		434	697	1063	1411	1714	1945	2002	1804	1263	865	542	379
	RadStd		67	94	138	171	174	185	152	169	119	121	63	57

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+1.06	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (44 neighbors)	+1.12	N/A	N/A	N/A	+0.72	+0.74	N/A	-281	+178	N/A

Nomenclature: See separate page