

KRUSEVAC, Serbia

WMO: 133830

Lat: 43.5641N

Lon: 21.3400E

Elev: 167

StdP: 99.33

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.2	-13.3	1.2	-10.0	-10.6	1.5	-7.3	7.5	2.4	6.5	4.3	1.2	160	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	34.7	20.8	32.8	20.4	31.0	20.0	23.0	29.4	22.1	28.8	21.3	28.0	2.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.2	16.2	25.4	20.2	15.2	24.4	19.3	14.3	23.5	68.8	29.3	65.5	28.7	62.5	28.1	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.4	5.3	4.4	-15.9	37.4	4.1	2.2	-18.8	38.9	-21.3	40.2	-23.6	41.4	-26.6	42.9		
			-16.1	24.7	3.9	1.3	-18.9	25.7	-21.3	26.4	-23.5	27.1	-26.3	28.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	0.8	2.9	7.1	12.4	16.9	20.7	22.5	22.5	17.8	12.2	7.5	2.1
	DBStd	8.69	4.84	5.19	4.52	3.81	3.46	3.34	2.91	3.04	3.65	4.25	4.66	4.62
	HDD10.0	1004	287	202	112	21	1	0	0	0	1	28	104	249
	HDD18.3	2676	544	431	349	181	70	15	3	4	53	194	327	504
	CDD10.0	1785	1	4	22	92	213	321	388	386	233	95	27	3
	CDD18.3	416	0	0	0	2	24	86	133	132	36	3	0	0
	CDH23.3	4656	0	0	2	54	309	952	1459	1423	402	52	1	0
	CDH26.7	1903	0	0	0	10	71	366	653	662	134	7	0	0
Wind	WSAvg	1.5	1.4	1.7	2.0	1.9	1.6	1.6	1.5	1.4	1.4	1.3	1.4	1.5
Precipitation	PrecAvg	670	44	44	50	63	71	72	59	46	58	55	51	55
	PrecMax	1019	116	101	126	167	163	133	179	145	138	121	131	114
	PrecMin	422	11	12	5	5	21	24	9	1	11	2	1	5
	PrecStd	139	26	21	29	32	37	34	38	34	32	32	31	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.4	19.4	23.1	28.1	30.8	34.4	37.2	37.8	33.6	27.5	22.0	16.7
		MCWB	10.1	11.3	13.1	16.8	18.6	21.3	20.9	20.9	19.4	17.1	14.0	11.3
	2%	DB	12.2	16.1	20.3	24.5	28.5	32.5	34.5	35.0	30.0	24.7	19.6	13.7
		MCWB	8.7	10.1	11.6	14.7	18.3	20.9	20.9	20.7	18.3	16.1	13.5	9.6
	5%	DB	10.0	13.6	17.7	22.2	26.8	30.7	32.5	32.7	27.6	22.2	17.4	11.1
		MCWB	7.4	8.9	10.4	13.4	17.7	20.4	20.6	20.1	17.7	15.4	12.5	8.4
	10%	DB	7.7	11.0	15.2	20.1	24.7	28.8	30.5	30.6	25.2	19.9	15.1	8.5
		MCWB	5.9	7.6	9.5	12.6	17.1	19.9	20.1	19.8	17.0	14.5	11.3	6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	12.3	13.6	17.6	21.3	24.2	23.9	24.1	20.9	18.6	15.4	11.8
		MCDB	14.2	17.5	21.2	24.9	25.8	30.0	29.8	30.4	27.8	23.0	20.3	15.4
	2%	WB	9.0	10.4	12.3	15.9	19.7	22.7	22.9	22.8	19.7	17.5	14.0	10.1
		MCDB	11.8	15.0	18.2	22.2	25.8	28.8	29.4	29.5	26.0	22.4	18.1	13.0
	5%	WB	7.6	9.1	11.1	14.5	18.7	21.7	22.0	21.8	18.7	16.2	12.9	8.5
		MCDB	9.7	13.1	16.4	20.1	24.9	28.1	28.7	28.7	24.7	21.0	16.8	11.1
	10%	WB	6.0	7.8	10.0	13.4	17.7	20.7	21.2	20.9	17.9	15.0	11.7	6.7
		MCDB	7.6	10.8	14.7	18.4	23.3	26.9	28.1	28.0	23.6	19.1	14.9	8.3
Mean Daily Temperature Range		MDBR	7.3	8.7	10.3	11.5	11.8	12.3	12.9	13.6	12.1	10.9	9.5	6.8
		MCDBR	11.1	14.5	15.9	16.8	16.1	16.1	17.6	18.4	16.7	15.6	12.9	10.5
		MCWBR	7.7	8.5	8.1	7.4	6.8	6.2	5.8	5.9	6.2	7.7	7.1	7.0
	5% WB	MCDBR	10.6	12.9	13.7	13.9	14.1	14.5	14.1	14.5	13.5	13.8	11.5	9.9
		MCWBR	7.7	8.0	7.3	6.9	7.0	6.5	5.9	6.0	5.9	7.6	6.7	6.8
Clear-Sky Solar Irradiance	taub	0.341	0.369	0.408	0.467	0.456	0.447	0.447	0.461	0.439	0.398	0.362	0.338	
	taud	2.321	2.227	2.185	2.043	2.135	2.207	2.206	2.165	2.194	2.300	2.347	2.346	
	Ebn at Noon	769	807	822	799	822	830	824	797	781	767	738	734	
	Edh at Noon	84	109	129	161	151	141	140	141	127	101	82	75	
All-Sky Solar Radiation	RadAvg	1.37	2.20	3.35	4.45	5.40	6.13	6.31	5.69	3.98	2.73	1.71	1.20	
	RadStd	0.21	0.29	0.43	0.54	0.55	0.58	0.48	0.53	0.38	0.38	0.20	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (44 neighbors)	+0.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.62	N/A	N/A	N/A	+0.40	+0.41	N/A	-156	+99	N/A

Nomenclature: See separate page