

NIKSIC, Montenegro

WMO: 134590

Lat: 42.767N

Lon: 18.950E

Elev: 647

StdP: 93.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.3	-5.2	-16.2	1.0	-4.7	-13.5	1.3	-2.7	10.3	2.2	9.1	2.6	3.6	20	0.492

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.8	33.0	20.6	31.3	20.3	29.7	19.8	22.4	29.9	21.5	28.9	20.6	27.6	3.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.4	16.3	25.3	19.1	15.1	24.5	18.1	14.1	23.7	69.2	29.9	65.7	29.5	62.2	28.0	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.5	7.6	6.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			-11.0	23.6	2.0	2.0	-12.4	25.0	-13.6	26.2	-14.7	27.4	-16.2	28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.9	2.4	3.3	6.2	10.8	14.7	19.1	22.1	22.5	17.2	12.8	7.7	3.7
	DBStd	7.74	3.56	3.61	3.48	2.92	3.23	3.48	2.85	2.67	3.23	3.08	3.58	3.38
	HDD10.0	872	237	189	124	26	2	0	0	0	0	13	83	197
	HDD18.3	2684	496	421	377	227	121	32	4	2	59	172	319	455
	CDD10.0	1568	0	1	6	48	147	274	375	387	216	99	14	1
	CDD18.3	339	0	0	0	0	7	56	121	131	24	0	0	0
	CDH23.3	3393	0	0	0	4	65	541	1218	1330	233	3	0	0
	CDH26.7	1251	0	0	0	0	4	147	481	552	67	0	0	0
Wind	WSAvg	2.8	2.6	3.0	3.4	3.1	3.0	2.9	2.8	2.7	2.5	2.5	2.7	2.7
Precipitation	PrecAvg	1921	202	188	162	172	116	86	57	67	140	226	289	251
	PrecMax	2502	452	403	486	370	230	183	169	214	351	559	763	525
	PrecMin	1369	0	0	4	44	43	25	8	4	12	0	69	30
	PrecStd	304	128	104	103	80	53	50	39	52	82	117	135	139
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	16.1	18.8	22.7	27.1	31.7	35.2	35.4	31.4	23.9	19.7	13.5
		MCWB	8.1	8.6	10.2	12.5	18.2	20.6	21.5	20.9	19.2	16.2	12.6	8.8
	2%	DB	10.5	12.2	16.2	20.2	25.1	30.0	33.0	33.4	28.5	22.2	16.6	11.4
		MCWB	7.0	7.3	9.4	11.8	17.0	20.1	20.3	20.7	18.6	15.5	11.4	8.8
	5%	DB	8.7	10.0	14.3	18.4	23.3	28.3	31.3	31.6	25.9	20.7	14.5	10.1
		MCWB	6.7	6.8	8.4	11.3	15.9	19.4	20.2	20.4	17.5	14.8	11.2	8.1
	10%	DB	7.3	8.3	12.2	16.6	21.5	26.5	29.5	29.8	23.6	18.8	13.0	8.7
		MCWB	5.6	5.9	7.7	10.5	15.1	18.5	19.9	19.8	16.5	14.0	10.4	6.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.7	12.3	14.8	19.6	23.0	24.1	24.1	21.2	18.3	14.7	11.6
		MCDB	10.8	12.4	14.8	18.8	24.7	29.0	29.8	31.1	28.9	20.9	16.2	11.7
	2%	WB	8.6	9.0	10.8	13.4	18.2	21.4	22.5	22.4	19.6	16.8	13.4	10.1
		MCDB	9.4	10.9	13.9	17.6	23.2	27.7	29.8	30.5	25.7	19.8	14.9	10.5
	5%	WB	7.3	7.7	9.4	12.3	16.8	20.3	21.5	21.4	18.4	15.7	12.1	8.6
		MCDB	8.2	9.2	12.2	16.5	21.7	26.6	28.8	29.4	23.7	19.0	13.7	9.5
	10%	WB	6.0	6.6	8.5	11.4	15.6	19.3	20.5	20.4	17.3	14.7	11.0	7.2
		MCDB	6.9	7.8	11.2	15.3	20.3	25.2	27.5	27.9	22.3	17.9	12.4	8.2
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.4	8.0	8.6	9.8	10.8	12.1	12.8	10.5	9.6	8.2	7.1
		MCDBR	9.9	10.9	12.2	12.4	12.9	13.5	15.1	15.6	14.3	13.6	12.0	10.7
		MCWBR	7.2	7.1	6.7	6.3	6.4	6.2	6.3	6.6	6.3	7.7	7.6	7.2
	5% WB	MCDBR	7.9	8.4	9.5	10.4	12.1	12.6	13.6	14.4	12.2	11.1	8.7	6.9
		MCWBR	6.6	6.2	6.2	6.3	6.9	6.8	7.3	7.4	6.6	7.3	6.5	5.3
Clear-Sky Solar Irradiance	taub	0.315	0.342	0.392	0.447	0.438	0.422	0.422	0.430	0.405	0.373	0.343	0.314	
	taud	2.381	2.285	2.179	2.067	2.154	2.252	2.250	2.222	2.276	2.349	2.383	2.405	
	Ebn at Noon	816	847	842	820	839	853	848	828	820	802	773	782	
	Edh at Noon	80	103	130	158	148	135	134	133	117	97	80	72	
All-Sky Solar Radiation	RadAvg	1.59	2.31	3.50	4.55	5.65	6.53	6.75	6.04	4.28	2.96	1.84	1.42	
	RadStd	0.20	0.33	0.49	0.53	0.47	0.47	0.42	0.43	0.36	0.31	0.21	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (26 neighbors)	+0.53	N/A	N/A	N/A	N/A	N/A	N/A	-106	+100	N/A

Nomenclature: See separate page