

PEJA, Kosovo

WMO: 134730

Lat: 42.667N

Lon: 20.300E

Elev: 1637

StdP: 13.85

Time Zone: 1.00 (EUC)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.8	17.4	5.8	7.9	22.6	10.2	9.9	21.5	13.6	30.6	10.9	37.2	0.5	N/A	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.0	88.2	67.9	85.3	66.8	82.8	65.8	69.5	84.5	68.3	82.7	67.0	80.3	2.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.2	95.6	76.3	62.9	91.3	75.0	61.8	87.6	73.6	34.5	84.5	33.4	83.0	32.4	80.6	77.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.4	9.6	7.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	WB	8.4	71.9	4.2	3.0	5.3	74.1	2.9	75.8	0.5	77.6	-2.5	79.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.7	32.3	36.4	44.1	52.3	60.1	66.8	71.5	72.4	65.6	54.3	41.2	34.4
	DBStd	15.68	6.92	7.64	8.77	6.76	6.02	5.17	5.73	5.33	5.58	7.17	7.86	8.03
	HDD50	2012	549	381	223	52	4	0	0	0	0	39	277	487
	HDD65	5129	1014	799	648	380	174	37	11	6	61	336	714	949
	CDD50	3002	0	2	40	122	317	505	666	694	468	172	13	3
	CDD65	645	0	0	0	1	22	93	212	235	79	3	0	0
	CDH74	4632	0	0	0	8	118	613	1632	1748	496	17	0	0
	CDH80	1274	0	0	0	0	9	129	513	533	89	1	0	0
Wind	WSAvg	2.3	1.1	1.9	2.7	3.1	3.0	2.8	3.0	3.0	2.4	1.8	1.3	1.1
Precipitation	PrecAvg	35.3	2.9	2.8	3.1	3.1	2.8	2.3	2.2	1.6	3.4	3.4	4.3	3.6
	PrecMax	50.4	7.4	5.6	7.1	5.7	6.7	5.2	5.2	4.6	7.9	7.6	7.0	7.4
	PrecMin	22.8	0.7	0.6	0.3	0.6	1.1	0.4	0.2	0.1	0.7	0.2	0.6	0.4
	PrecStd	6.8	1.6	1.4	1.8	1.3	1.5	1.1	1.3	1.2	2.0	1.9	1.7	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	52.2	60.3	69.6	74.7	81.5	87.5	93.9	92.0	86.4	76.8	63.8	58.0
		MCWB	46.2	47.2	53.3	56.7	62.5	67.1	71.1	68.4	65.8	61.5	54.5	51.6
	2%	DB	48.0	55.9	65.3	70.3	77.5	83.5	88.5	88.4	82.4	71.6	59.2	52.4
		MCWB	43.6	45.3	51.6	54.7	61.7	65.9	69.3	67.6	65.2	58.9	52.4	48.1
	5%	DB	45.2	51.6	60.7	66.8	74.1	80.3	84.9	85.6	79.6	68.6	55.5	48.3
		MCWB	41.4	43.8	49.2	53.0	60.1	64.1	67.2	66.8	63.7	57.5	51.2	45.2
	10%	DB	42.7	47.9	56.8	63.3	70.7	77.3	82.2	83.0	76.3	65.2	52.3	43.8
		MCWB	39.3	42.0	47.1	51.7	58.1	63.6	66.2	65.8	62.1	56.2	48.9	41.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.5	48.7	54.7	58.2	64.3	69.5	72.7	70.5	67.3	63.4	56.6	52.2
		MCDB	50.7	56.8	67.1	70.7	76.5	83.5	90.3	84.4	83.3	73.3	61.1	56.6
	2%	WB	44.4	46.7	52.3	56.0	62.9	67.2	70.2	69.2	65.9	61.1	53.5	48.5
		MCDB	47.6	53.6	63.9	67.0	74.7	80.3	85.9	84.5	80.6	67.8	57.9	51.9
	5%	WB	42.1	44.6	49.9	54.3	61.2	65.7	68.6	68.1	64.4	59.4	51.5	45.4
		MCDB	44.6	50.0	58.8	64.6	71.4	77.6	82.7	83.3	77.1	66.0	55.1	47.9
	10%	WB	39.7	42.8	47.9	52.4	59.7	64.3	67.3	66.8	63.1	57.6	49.5	41.6
		MCDB	42.2	48.0	55.7	61.7	68.9	75.3	80.0	80.6	74.4	62.9	52.2	43.3
Mean Daily Temperature Range	5% DB	MDBR	11.1	13.5	14.6	14.8	15.8	17.2	17.4	18.0	17.9	15.6	11.4	9.3
		MCDBR	15.6	21.1	21.1	20.3	20.1	20.8	20.8	20.9	21.2	19.5	14.7	15.3
		MCWBR	11.0	11.8	10.6	10.3	9.3	9.2	9.4	9.7	9.8	9.3	9.3	11.4
	5% WB	MCDBR	13.8	17.6	19.1	18.3	18.3	19.3	20.1	18.8	20.0	16.7	13.4	14.9
		MCWBR	10.4	10.9	10.1	9.9	9.1	9.7	9.9	9.1	10.0	8.7	9.2	11.5
Clear-Sky Solar Irradiance	taub	0.349	0.386	0.447	0.520	0.508	0.480	0.482	0.499	0.472	0.421	0.379	0.346	
	taud	2.223	2.092	1.985	1.847	1.929	2.060	2.060	2.003	2.040	2.153	2.210	2.241	
	Ebn at Noon	241	250	248	239	247	254	252	242	238	235	226	230	
	Edh at Noon	30	40	50	62	59	52	51	53	47	37	30	27	
All-Sky Solar Radiation	RadAvg	498	745	1092	1405	1715	1968	2043	1848	1301	916	580	421	
	RadStd	69	97	139	174	147	166	147	150	123	114	66	71	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.97	N/A	N/A	N/A	N/A	N/A	N/A	-193	N/A	N/A	N/A

Nomenclature: See separate page