

PEJA, Kosovo

WMO: 134730

Lat: 42.667N

Lon: 20.300E

Elev: 499

StdP: 95.47

Time Zone: 1.00 (EUC)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.1	-8.1	-14.6	1.1	-5.2	-12.1	1.4	-5.8	6.1	-0.8	4.9	2.9	0.2	N/A	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.0	31.2	20.0	29.6	19.3	28.2	18.8	20.8	29.2	20.1	28.2	19.4	26.8	1.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.7	24.6	17.2	13.0	23.9	16.5	12.5	23.1	62.4	29.2	59.9	28.4	57.4	27.0	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 5.5	4.3	3.5	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	-13.1	22.2	2.3	1.7	-14.8	23.4	-16.2	24.4	-17.5	25.3	-19.2	26.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.5	0.2	2.5	6.7	11.3	15.6	19.4	21.9	22.4	18.7	12.4	5.1	1.3
	DBStd	8.71	3.85	4.24	4.87	3.75	3.35	2.87	3.18	2.96	3.10	3.98	4.37	4.46
	HDD10.0	1118	305	212	124	29	2	0	0	0	22	154	271	
	HDD18.3	2849	563	444	360	211	97	21	6	3	34	187	397	527
	CDD10.0	1668	0	1	22	68	176	281	370	386	260	96	7	2
	CDD18.3	358	0	0	0	1	12	52	118	131	44	2	0	0
	CDH23.3	2573	0	0	0	4	66	341	907	971	276	9	0	0
	CDH26.7	708	0	0	0	0	5	72	285	296	49	1	0	0
(14) Wind	WSAvg	1.0	0.5	0.9	1.2	1.4	1.4	1.3	1.3	1.4	1.1	0.8	0.6	0.5
(15) Precipitation	PrecAvg	897	74	72	79	79	71	58	57	41	87	86	109	91
	PrecMax	1281	188	142	180	144	170	132	132	116	200	193	179	189
	PrecMin	578	19	15	8	15	27	10	6	3	17	4	16	10
	PrecStd	172	40	36	45	33	37	27	34	31	51	48	43	49
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	15.7	20.9	23.7	27.5	30.8	34.4	33.3	30.2	24.9	17.7	14.5
		MCWB	7.9	8.4	11.8	13.7	17.0	19.5	21.7	20.2	18.8	16.4	12.5	10.9
	2%	DB	8.9	13.3	18.5	21.3	25.3	28.6	31.4	31.3	28.0	22.0	15.1	11.3
		MCWB	6.4	7.4	10.9	12.6	16.5	18.9	20.7	19.8	18.5	14.9	11.3	9.0
	5%	DB	7.3	10.9	16.0	19.3	23.4	26.8	29.4	29.8	26.4	20.3	13.1	9.1
		MCWB	5.2	6.5	9.6	11.7	15.6	17.9	19.6	19.3	17.6	14.2	10.7	7.3
	10%	DB	5.9	8.9	13.8	17.4	21.5	25.2	27.9	28.3	24.6	18.4	11.3	6.5
		MCWB	4.1	5.6	8.4	11.0	14.5	17.5	19.0	18.8	16.7	13.5	9.4	5.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.6	9.3	12.6	14.6	18.0	20.8	22.6	21.4	19.6	17.5	13.7	11.2
		MCDB	10.4	13.8	19.5	21.5	24.7	28.6	32.4	29.1	28.5	23.0	16.2	13.6
	2%	WB	6.9	8.1	11.3	13.3	17.2	19.6	21.2	20.7	18.8	16.2	12.0	9.2
		MCDB	8.7	12.0	17.7	19.4	23.7	26.8	29.9	29.2	27.0	19.9	14.4	11.0
	5%	WB	5.6	7.0	9.9	12.4	16.2	18.7	20.4	20.1	18.0	15.2	10.8	7.4
		MCDB	7.0	10.0	14.9	18.1	21.9	25.3	28.2	28.5	25.0	18.9	12.8	8.9
	10%	WB	4.3	6.0	8.8	11.4	15.4	17.9	19.6	19.3	17.3	14.2	9.7	5.4
		MCDB	5.7	8.9	13.2	16.5	20.5	24.1	26.7	27.0	23.5	17.2	11.2	6.3
(35) Mean Daily Temperature Range	5% DB	MDBR	6.2	7.5	8.1	8.2	8.8	9.5	9.7	10.0	10.0	8.6	6.4	5.2
		MCDBR	8.7	11.7	11.7	11.3	11.1	11.6	11.6	11.6	11.8	10.8	8.1	8.5
	5% WB	MCWBR	6.1	6.5	5.9	5.7	5.2	5.1	5.2	5.4	5.5	5.2	5.2	6.3
		MCWBR	7.7	9.8	10.6	10.2	10.2	10.7	11.2	10.5	11.1	9.3	7.4	8.3
(40) Clear-Sky Solar Irradiance	taub	taub	0.349	0.386	0.447	0.520	0.508	0.480	0.482	0.499	0.472	0.421	0.379	0.346
		taud	2.223	2.092	1.985	1.847	1.929	2.060	2.060	2.003	2.040	2.153	2.210	2.241
	Ebn at Noon	Ebn at Noon	761	787	782	754	778	802	795	764	750	740	714	724
		Edh at Noon	94	126	159	197	186	164	162	166	149	118	95	85
(44) All-Sky Solar Radiation	RadAvg	1.57	2.35	3.44	4.43	5.41	6.21	6.44	5.83	4.10	2.89	1.83	1.33	
	RadStd	0.22	0.31	0.44	0.55	0.46	0.52	0.46	0.47	0.39	0.36	0.21	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	-107	N/A	N/A

Nomenclature: See separate page