

PRIZREN, Kosovo

WMO: 134770

Lat: 42.217N

Lon: 20.733E

Elev: 403

StdP: 96.58

Time Zone: 1.00 (EUC)

Period: 86-99

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -9.5	(c) -7.4	(d) -12.1	(e) 1.4	(f) -7.9	(g) -10.4	(h) 1.6	(i) -6.0	(j) 8.4	(k) 4.0	(l) 7.0	(m) 8.0	(n) 0.6	(o) 0	(p) 0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	33.6	19.9	31.7	19.4	30.1	19.0	21.0	30.7	20.3	29.6	19.6	28.5	2.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.7	13.3	24.7	17.0	12.8	23.9	16.3	12.2	23.5	62.4	30.8	59.9	29.8	57.7	28.6	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.8	(b) 5.4	(c) 4.4	(e) -12.1	(f) 36.3	(g) 3.3	(h) 1.6	(i) -14.5	(j) 37.4	(k) -16.4	(l) 38.3	(m) -18.3	(n) 39.2	(o) -20.6	(p) 40.3		
(a) 6.8	(b) 5.4	(c) 4.4	(e) -12.3	(f) 22.1	(g) 3.0	(h) 0.9	(i) -14.5	(j) 22.8	(k) -16.3	(l) 23.3	(m) -18.0	(n) 23.9	(o) -20.2	(p) 24.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.5	1.0	3.2	7.8	11.8	16.8	21.2	23.4	23.2	18.6	12.9	7.4	2.0
	DBStd	8.92	4.33	4.73	4.49	3.94	3.71	3.38	3.28	3.24	3.39	4.35	5.01	5.26
	HDD10.0	989	281	195	98	26	2	0	0	0	0	22	109	257
	HDD18.3	2627	538	425	327	197	73	10	2	4	37	174	330	508
	CDD10.0	1893	1	3	29	79	213	336	415	411	259	111	29	8
	CDD18.3	490	0	0	0	1	26	96	159	157	46	5	1	0
	CDH23.3	4227	0	0	0	13	180	799	1509	1354	337	34	1	0
CDH26.7	1535	0	0	0	0	37	261	615	532	86	4	0	0	
Wind	WSAvg	1.4	1.2	1.4	1.8	1.7	1.6	1.6	1.6	1.5	1.4	1.2	1.1	1.3
Precipitation	PrecAvg	770	50	56	64	63	57	55	59	35	76	79	94	79
	PrecMax	1139	118	110	132	108	117	145	176	122	191	166	185	176
	PrecMin	528	6	5	5	13	10	7	4	0	9	4	34	9
	PrecStd	172	28	29	38	28	32	34	44	28	47	48	44	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.8	17.2	22.0	25.1	29.9	33.8	37.3	35.5	31.6	27.0	21.1	17.7
		MCWB	9.3	9.5	11.7	14.0	17.4	20.4	20.7	20.5	19.1	16.6	13.7	11.4
	2%	DB	11.3	14.6	19.7	22.4	27.6	31.5	34.1	33.2	29.0	23.6	18.1	14.9
		MCWB	7.5	8.6	11.0	12.8	16.9	19.6	20.0	19.8	18.1	15.8	12.4	10.7
	5%	DB	9.3	12.7	17.3	20.3	25.3	29.5	31.9	31.5	26.9	21.4	15.7	12.6
		MCWB	6.4	7.7	9.6	12.2	16.1	18.9	19.6	19.3	17.4	15.0	11.4	9.2
	10%	DB	7.7	10.5	14.9	18.1	23.2	27.8	30.0	29.8	25.0	19.5	14.0	9.9
		MCWB	5.4	6.4	8.7	11.2	14.9	18.2	19.2	18.8	16.6	14.2	10.6	7.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	10.1	12.4	14.6	18.5	21.3	22.0	22.0	19.8	17.7	14.3	12.3
		MCDB	13.8	15.9	20.6	22.0	27.0	31.3	33.0	32.5	27.8	24.6	19.1	16.4
	2%	WB	8.0	8.8	11.3	13.6	17.3	20.3	21.1	20.8	18.9	16.4	12.9	10.7
		MCDB	10.8	14.1	18.6	20.8	25.8	30.0	31.0	30.1	27.2	22.0	17.1	14.5
	5%	WB	6.6	7.7	10.2	12.7	16.5	19.4	20.5	20.0	18.1	15.5	11.8	9.2
		MCDB	9.2	12.2	16.4	19.1	24.4	28.5	29.9	29.3	25.4	20.5	15.3	12.7
	10%	WB	5.4	6.6	9.0	11.7	15.5	18.5	19.7	19.4	17.2	14.6	10.8	7.3
		MCDB	7.4	10.2	14.3	17.5	22.2	26.8	28.6	28.1	23.8	18.9	13.7	9.7
Mean Daily Temperature Range	5% DB	MDBR	6.1	8.0	8.7	8.7	9.5	10.6	11.7	11.4	10.5	9.0	6.6	5.1
		MCDBR	8.9	11.4	12.6	12.1	12.5	12.8	14.0	13.9	13.4	11.4	9.1	8.1
		MCWBR	5.9	6.7	6.2	5.6	5.6	5.3	5.2	5.2	5.4	5.6	5.2	4.9
	5% WB	MCDBR	8.1	10.6	10.9	10.7	11.6	12.3	12.5	12.4	11.8	10.3	8.4	8.0
		MCWBR	5.5	6.4	5.5	5.3	5.4	5.5	5.1	5.1	5.1	5.5	4.8	4.9
Clear-Sky Solar Irradiance	taub	0.316	0.342	0.385	0.436	0.433	0.412	0.416	0.432	0.410	0.374	0.344	0.317	
	taud	2.379	2.300	2.236	2.113	2.189	2.289	2.271	2.225	2.271	2.360	2.400	2.397	
	Ebn at Noon	821	852	853	832	845	862	854	828	817	805	780	785	
	Edh at Noon	81	103	124	151	144	130	131	133	119	96	80	74	
All-Sky Solar Radiation	RadAvg	1.62	2.42	3.48	4.51	5.48	6.32	6.58	5.91	4.21	2.96	1.88	1.36	
	RadStd	0.24	0.31	0.45	0.55	0.45	0.51	0.45	0.45	0.38	0.36	0.21	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+0.55	N/A	N/A	N/A	N/A	N/A	N/A	-113	N/A	N/A

Nomenclature: See separate page