

PRISTINA INTL, Kosovo

WMO: 134811

Lat: 42.570N

Lon: 21.030E

Elev: 1834

StdP: 13.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.2	14.0	2.9	6.8	9.6	8.5	9.1	15.8	26.1	37.4	23.1	35.1	3.3	350	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	24.9	92.8	65.4	89.4	65.1	86.1	64.3	68.3	84.1	67.0	83.0	65.7	81.5	7.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.9	91.9	73.5	61.2	86.5	71.7	60.6	84.5	71.1	33.6	84.2	32.4	83.0	31.5	82.0	75.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.5	19.2	16.5	0.9	96.4	8.8	4.0	-5.5	99.3	-10.6	101.6	-15.6	103.8	-22.0	106.7		
(5)			0.2	71.4	8.7	1.9	-6.0	72.8	-11.1	73.9	-16.0	75.0	-22.3	76.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	52.0	31.4	35.9	42.7	52.0	59.8	67.0	70.7	71.0	62.5	53.0	43.3	34.0		
	DBStd	15.56	9.27	9.19	7.91	6.54	5.93	5.74	4.95	5.23	6.61	7.04	8.23	8.50		
	HDD50	2053	577	398	243	52	3	0	0	0	1	54	226	499		
	HDD65	5289	1041	816	690	391	177	44	10	13	121	374	650	962		
	CDD50	2797	1	2	19	112	309	510	641	650	377	147	26	3		
	CDD65	553	0	0	0	0	17	104	186	197	47	2	0	0		
	CDH74	6667	0	0	0	44	286	1230	2207	2247	609	44	0	0		
	CDH80	2545	0	0	0	3	44	412	922	968	190	6	0	0		
	WSAvg	5.7	5.2	6.6	7.5	6.6	6.0	5.2	5.2	5.0	5.1	4.8	5.2	5.5		
	PrecAvg	24.9	1.7	1.6	1.7	2.3	2.4	2.1	1.9	1.6	2.3	2.5	2.3	2.3		
(15) Precipitation	PrecMax	36.0	3.7	3.2	3.6	6.6	4.7	4.2	4.2	4.3	6.4	5.1	4.7	5.3		
	PrecMin	15.2	0.3	0.2	0.2	0.7	0.9	0.5	0.2	0.1	0.5	0.0	0.1	0.2		
	PrecStd	5.2	0.9	0.7	0.9	1.3	0.9	0.9	1.1	1.1	1.3	1.5	1.3	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	63.2	69.7	79.0	84.4	91.8	96.8	96.8	91.1	78.8	69.5	59.3		
		MCWB	47.7	48.5	51.0	56.6	62.7	66.8	65.1	65.1	63.3	59.8	56.5	52.0		
	2%	DB	51.4	57.0	64.8	73.6	80.4	88.0	92.8	92.9	85.7	73.7	62.8	53.8		
		MCWB	45.0	46.3	49.2	55.0	61.4	66.2	65.4	65.3	62.3	58.0	52.4	47.7		
	5%	DB	47.8	53.2	60.8	69.6	77.1	84.7	89.2	89.4	80.7	70.0	59.0	49.9		
		MCWB	42.8	44.8	47.4	52.5	60.3	65.1	65.5	64.6	61.5	56.8	51.1	45.4		
	10%	DB	44.2	49.3	56.9	65.8	73.6	80.9	85.6	85.8	76.8	66.2	55.5	46.2		
		MCWB	40.6	42.8	46.0	51.6	58.9	63.8	64.6	63.8	60.1	55.6	49.5	43.2		
	0.4%	WB	48.5	50.1	53.4	58.4	65.5	70.6	70.0	69.5	65.7	61.9	57.5	52.5		
		MCDB	54.8	60.2	65.3	73.3	79.1	85.2	86.7	85.6	81.7	74.0	65.7	58.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	45.7	47.7	50.6	56.2	63.2	68.1	68.1	67.7	63.8	59.7	54.1	48.6		
		MCDB	51.2	56.3	61.6	70.2	76.2	82.8	84.3	84.3	79.0	70.0	60.7	53.3		
	5%	WB	42.7	45.4	48.7	54.2	61.5	66.5	66.7	66.4	62.5	58.0	52.1	45.9		
		MCDB	46.4	52.0	58.9	66.2	74.5	81.3	83.1	83.1	77.2	67.2	58.2	49.4		
	10%	WB	40.2	43.0	46.8	52.6	59.6	64.9	65.5	65.2	61.1	56.3	50.0	42.8		
		MCDB	43.4	48.2	56.1	63.2	71.4	79.2	81.5	81.3	73.6	64.7	55.1	45.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	16.4	18.8	21.0	21.4	22.9	24.9	25.5	22.3	21.1	17.0	12.1		
		MCDBR	18.8	24.2	27.9	30.1	28.4	29.1	32.0	32.1	30.5	28.6	23.4	17.3		
		MCWBR	13.4	14.9	15.2	14.9	13.2	11.7	11.0	10.9	12.0	15.1	14.8	12.3		
		MCDBR	17.7	21.3	23.8	25.2	25.5	26.7	27.7	27.3	24.9	24.2	20.2	15.2		
	5% WB	MCWBR	13.0	13.5	13.6	12.9	12.5	11.4	10.6	10.2	10.7	13.3	12.8	11.1		
(40) Clear-Sky Solar Irradiance	taub		0.319	0.344	0.386	0.439	0.432	0.414	0.416	0.431	0.410	0.374	0.344	0.319		
	taud		2.364	2.288	2.226	2.092	2.173	2.266	2.255	2.212	2.252	2.343	2.381	2.382		
	Ebn at Noon		258	268	270	263	268	273	271	262	259	254	246	246		
	Edh at Noon		26	33	40	49	46	42	42	43	38	31	25	23		
(44) All-Sky Solar Radiation	RadAvg		488	755	1097	1424	1735	1987	2063	1861	1318	922	581	410		
	RadStd		74	98	136	176	143	167	149	150	115	119	66	69		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	-409	N/A	N/A
(47) Regional (38 neighbors)		+1.03	N/A	N/A	N/A	+0.58	N/A	N/A	-243	+162	N/A

Nomenclature: See separate page