

PRISTINA INTL, Kosovo

WMO: 134811

Lat: 42.570N

Lon: 21.030E

Elev: 559

StdP: 94.79

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.2	-10.0	-16.2	1.0	-12.4	-13.1	1.3	-9.0	11.7	3.0	10.3	1.7	1.5	350	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	33.8	18.6	31.9	18.4	30.0	17.9	20.2	28.9	19.4	28.3	18.7	27.5	3.2	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.2	13.1	23.1	16.2	12.4	22.1	15.9	12.1	21.7	60.2	29.0	57.6	28.3	55.3	27.8	24.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
10.1	8.6	7.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-17.3	35.8	4.9	2.2	-20.8	37.4	-23.7	38.7	-26.4	39.9	-30.0	41.5		
			-17.7	21.9	4.8	1.1	-21.1	22.7	-24.0	23.3	-26.7	23.9	-30.2	24.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	-0.3	2.1	6.0	11.1	15.5	19.4	21.5	21.6	17.0	11.7	6.3	1.1
	DBStd	8.65	5.15	5.11	4.40	3.64	3.30	3.19	2.75	2.90	3.67	3.91	4.57	4.72
	HDD10.0	1141	321	221	135	29	2	0	0	0	1	30	126	277
	HDD18.3	2938	578	453	383	217	98	24	6	7	67	208	361	534
	CDD10.0	1554	1	1	11	62	172	283	356	361	209	82	14	2
	CDD18.3	307	0	0	0	0	9	58	103	109	26	1	0	0
	CDH23.3	3704	0	0	0	24	159	683	1226	1248	338	24	0	0
	CDH26.7	1414	0	0	0	2	24	229	512	538	106	3	0	0
Wind	WSAvg	2.5	2.3	2.9	3.3	2.9	2.7	2.3	2.3	2.2	2.3	2.1	2.3	2.4
Precipitation	PrecAvg	632	43	40	44	59	62	54	49	40	58	64	59	59
	PrecMax	914	93	82	92	168	119	106	106	110	163	129	120	134
	PrecMin	386	7	6	6	18	22	12	4	3	12	1	3	4
	PrecStd	131	24	19	23	33	24	24	29	28	34	37	32	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.8	17.3	20.9	26.1	29.1	33.2	36.0	36.0	32.8	26.0	20.8	15.1
		MCWB	8.7	9.2	10.6	13.7	17.0	19.3	18.4	18.4	17.4	15.4	13.6	11.1
	2%	DB	10.8	13.9	18.2	23.1	26.9	31.1	33.8	33.8	29.9	23.2	17.1	12.1
		MCWB	7.2	8.0	9.6	12.8	16.3	19.0	18.5	18.5	16.8	14.4	11.4	8.7
	5%	DB	8.8	11.8	16.0	20.9	25.1	29.3	31.8	31.9	27.0	21.1	15.0	9.9
		MCWB	6.0	7.1	8.6	11.4	15.7	18.4	18.6	18.1	16.4	13.8	10.6	7.5
	10%	DB	6.8	9.6	13.8	18.8	23.1	27.2	29.8	29.9	24.9	19.0	13.1	7.9
		MCWB	4.8	6.0	7.8	10.9	14.9	17.6	18.1	17.7	15.6	13.1	9.7	6.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.2	10.1	11.9	14.7	18.6	21.5	21.1	20.9	18.7	16.6	14.2	11.4
		MCDB	12.7	15.7	18.5	22.9	26.2	29.5	30.4	29.8	27.6	23.3	18.7	14.7
	2%	WB	7.6	8.7	10.3	13.4	17.3	20.1	20.0	19.9	17.7	15.4	12.3	9.2
		MCDB	10.6	13.5	16.4	21.2	24.6	28.2	29.0	29.1	26.1	21.1	16.0	11.8
	5%	WB	5.9	7.4	9.3	12.3	16.4	19.1	19.3	19.1	16.9	14.4	11.2	7.7
		MCDB	8.0	11.1	14.9	19.0	23.6	27.4	28.4	28.4	25.1	19.6	14.5	9.7
	10%	WB	4.5	6.1	8.2	11.4	15.3	18.3	18.6	18.4	16.2	13.5	10.0	6.0
		MCDB	6.3	9.0	13.4	17.3	21.9	26.2	27.5	27.4	23.1	18.2	12.8	7.5
Mean Daily Temperature Range	5% DB	MDBR	7.8	9.1	10.4	11.7	11.9	12.7	13.9	14.1	12.4	11.7	9.5	6.7
		MCDBR	10.5	13.4	15.5	16.7	15.8	16.1	17.8	17.8	17.0	15.9	13.0	9.6
		MCWBR	7.4	8.3	8.4	8.3	7.3	6.5	6.1	6.0	6.7	8.4	8.2	6.8
	5% WB	MCDBR	9.9	11.8	13.2	14.0	14.2	14.9	15.4	15.2	13.9	13.5	11.2	8.4
		MCWBR	7.2	7.5	7.5	7.2	7.0	6.3	5.9	5.7	5.9	7.4	7.1	6.2
Clear-Sky Solar Irradiance	taub	0.319	0.344	0.386	0.439	0.432	0.414	0.416	0.431	0.410	0.374	0.344	0.319	
	taud	2.364	2.288	2.226	2.092	2.173	2.266	2.255	2.212	2.252	2.343	2.381	2.382	
	Ebn at Noon	812	846	851	829	845	860	853	827	816	802	774	776	
	Edh at Noon	82	104	125	154	146	133	133	135	120	97	80	74	
All-Sky Solar Radiation	RadAvg	1.54	2.38	3.46	4.49	5.47	6.26	6.50	5.87	4.15	2.91	1.83	1.29	
	RadStd	0.23	0.31	0.43	0.55	0.45	0.53	0.47	0.47	0.36	0.38	0.21	0.22	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-227	N/A	N/A
(47)	Regional (38 neighbors)	+0.57	N/A	N/A	N/A	+0.32	N/A	N/A	-135	+90	N/A

Nomenclature: See separate page