

OHRID, North Macedonia

WMO: 135790

Lat: 41.100N

Lon: 20.817E

Elev: 700

StdP: 93.19

Time Zone: 1.00 (EUC)

Period: 97-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.1	-6.8	-13.3	1.3	-6.7	-11.0	1.6	-5.2	9.3	4.8	8.4	2.3	3.3	350	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.2	30.3	19.2	28.7	19.1	27.4	18.9	21.4	27.0	20.5	26.3	19.8	25.6	2.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	15.5	25.0	18.5	14.6	24.0	17.6	13.8	23.2	65.5	26.9	62.3	26.4	59.6	25.7	24.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.8	6.7	5.8	-12.7	32.9	1.5	1.5	-13.9	34.0	-14.8	34.9	-15.6	35.8	-16.8	36.9		
			-13.1	22.8	1.6	1.1	-14.3	23.6	-15.2	24.2	-16.0	24.8	-17.2	25.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	1.2	2.0	5.6	9.7	14.3	17.8	20.4	20.7	16.4	11.8	6.7	2.9
	DBStd	7.53	3.66	3.66	3.37	2.87	2.57	2.90	2.27	2.25	2.73	3.18	3.48	4.12
	HDD10.0	1026	274	223	139	37	2	0	0	0	1	20	109	221
	HDD18.3	2923	532	457	393	259	127	43	8	5	69	202	350	478
	CDD10.0	1337	0	0	4	28	134	235	324	332	193	77	9	2
	CDD18.3	193	0	0	0	0	1	28	73	79	12	0	0	0
	CDH23.3	1913	0	0	0	1	24	294	750	734	108	1	0	0
	CDH26.7	430	0	0	0	0	1	50	180	188	11	0	0	0
(14) Wind	WSAvg	2.2	2.4	2.6	2.5	2.2	1.9	2.0	2.2	2.0	2.1	2.1	2.2	2.7
(15) Precipitation	PrecAvg	703	61	56	52	70	52	32	33	26	66	84	96	81
	PrecMax	858	139	146	94	112	109	74	95	75	143	170	180	163
	PrecMin	483	0	16	5	16	6	2	1	2	9	5	27	0
	PrecStd	120	41	32	26	24	27	19	25	17	37	44	36	45
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	12.1	17.8	21.0	25.5	30.3	31.8	32.1	28.3	22.7	17.9	14.3
		MCWB	8.4	7.6	11.3	12.8	17.5	19.7	19.0	19.1	17.3	16.2	14.0	11.2
	2%	DB	9.4	10.5	14.7	18.6	23.8	27.9	30.2	30.4	26.2	20.9	15.8	12.1
		MCWB	7.5	7.3	9.5	12.3	16.8	19.5	19.3	19.2	17.4	15.9	12.7	9.7
	5%	DB	8.0	9.1	13.1	17.1	22.2	26.5	28.8	28.8	24.5	19.2	14.1	10.7
		MCWB	6.4	6.6	8.8	11.6	16.1	19.2	19.2	19.1	17.1	15.0	11.6	8.9
	10%	DB	6.8	7.9	11.6	15.2	20.7	25.0	27.4	27.3	22.6	17.7	12.7	9.3
		MCWB	5.5	6.0	8.1	10.7	15.4	18.6	19.0	18.7	16.4	14.2	10.6	7.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.9	8.8	12.1	14.2	18.7	22.2	22.4	22.4	19.6	18.0	14.6	11.6
		MCDB	10.3	11.0	16.5	19.0	23.8	26.7	27.6	28.6	24.5	21.4	16.9	13.2
	2%	WB	7.9	7.6	10.5	13.1	17.5	20.9	21.4	21.2	18.5	16.5	13.1	10.0
		MCDB	9.2	9.5	13.7	17.2	22.3	25.8	27.1	27.1	23.7	19.7	15.1	11.8
	5%	WB	6.7	7.0	9.4	12.2	16.7	19.9	20.6	20.3	17.6	15.5	11.9	9.0
		MCDB	7.8	8.8	12.2	16.1	21.1	25.1	26.5	26.4	22.8	18.4	14.0	10.6
	10%	WB	5.6	6.1	8.5	11.3	15.9	19.0	19.8	19.5	16.9	14.6	10.7	7.9
		MCDB	6.7	7.9	11.0	14.5	20.0	24.3	25.7	25.7	21.8	17.3	12.6	9.2
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	8.0	8.8	9.5	11.2	12.4	13.2	13.3	11.1	9.8	8.3	6.6
		MCDBR	8.0	9.8	11.9	12.8	14.2	14.6	15.7	15.1	14.0	11.9	9.7	7.7
		MCWBR	6.1	6.8	7.4	7.1	7.7	7.1	7.1	6.8	6.7	7.3	6.9	5.8
	5% WB	MCDBR	7.4	8.9	10.3	11.3	13.2	13.6	13.8	13.8	12.6	10.7	8.9	7.4
		MCWBR	5.9	6.5	6.7	6.8	7.7	7.4	7.3	7.2	6.7	7.2	6.5	5.8
(40) Clear-Sky Solar Irradiance	taub		0.309	0.334	0.379	0.431	0.427	0.404	0.409	0.422	0.406	0.370	0.336	0.310
	taud		2.427	2.346	2.253	2.115	2.190	2.297	2.278	2.237	2.266	2.356	2.421	2.432
	Ebn at Noon		845	871	865	841	853	872	863	840	826	817	802	811
	Edh at Noon		79	100	123	152	144	130	131	133	120	98	80	73
(44) All-Sky Solar Radiation	RadAvg		1.77	2.56	3.57	4.61	5.62	6.56	6.86	6.08	4.45	3.15	2.04	1.55
	RadStd		0.25	0.34	0.47	0.52	0.43	0.49	0.39	0.40	0.38	0.34	0.20	0.28

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (22 neighbors)	+0.48	N/A	N/A	N/A	N/A	N/A	N/A	-118	+101	N/A

Nomenclature: See separate page