

KUCOVE, Albania

WMO: 136240

Lat: 40.800N

Lon: 19.900E

Elev: 33

StdP: 100.93

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	-1.0	-9.2	1.7	3.0	-6.8	2.1	5.0	9.6	12.6	8.1	11.8	1.5	140	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	36.0	22.4	34.5	22.1	33.2	21.8	24.2	32.3	23.5	31.6	22.8	30.8	2.6	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.8	16.6	28.4	21.0	15.7	27.2	20.2	14.9	26.6	73.2	32.2	70.0	31.7	67.3	31.0	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.3	6.7	5.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.8	7.5	9.5	12.1	15.2	18.6	23.3	26.3	25.9	22.7	17.8	13.3	8.8		
	DBStd	7.01	3.34	2.99	2.49	2.64	2.81	3.08	2.05	2.20	2.77	2.78	3.18	3.02		
	HDD10.0	207	90	39	8	2	0	0	0	0	0	0	9	59		
	HDD18.3	1399	336	247	194	99	31	2	0	3	42	152	294			
	CDD10.0	2689	12	26	73	158	267	398	504	494	381	243	109	23		
	CDD18.3	839	0	1	1	6	40	150	246	236	133	27	1	0		
	CDH23.3	8729	0	1	8	69	352	1540	2776	2525	1212	241	6	0		
	CDH26.7	4088	0	0	1	12	77	674	1466	1328	499	32	0	0		
(14) Wind	WSAvg	2.2	2.4	2.9	2.8	1.9	1.8	1.9	1.8	1.8	2.2	1.8	2.5	2.3		
(15) Precipitation	PrecAvg	1013	91	103	92	88	57	30	22	28	84	113	146	140		
	PrecMax	1480	189	246	190	155	146	73	72	95	281	238	241	357		
	PrecMin	723	15	3	8	40	17	8	0	1	6	15	34	4		
	PrecStd	210	51	64	53	31	31	18	19	26	65	61	58	90		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.0	21.8	24.2	28.6	30.7	35.7	37.9	38.0	35.1	29.1	24.1	19.0		
		MCWB	11.3	12.4	13.0	17.5	19.8	22.4	23.5	22.4	21.5	17.6	16.1	12.9		
	2%	DB	16.2	19.2	21.9	25.5	28.9	34.1	36.3	35.9	33.1	27.4	21.9	17.2		
		MCWB	10.7	11.7	12.7	16.2	19.1	22.2	23.0	22.0	20.6	17.9	14.9	11.8		
	5%	DB	14.7	17.0	20.1	23.5	27.0	32.3	34.6	34.3	31.4	26.0	20.6	15.7		
		MCWB	9.8	10.6	12.5	15.2	18.4	21.6	22.5	21.7	19.9	17.7	14.3	11.0		
	10%	DB	13.1	15.4	18.3	21.8	25.2	30.6	33.1	32.9	29.7	24.4	19.2	14.3		
		MCWB	9.1	9.8	11.7	14.6	17.7	21.0	22.1	21.8	19.5	17.1	13.7	10.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.5	13.6	15.5	18.8	21.5	24.5	26.2	24.9	23.1	20.7	17.5	14.1		
		MCDB	16.2	19.8	21.2	26.4	27.4	32.1	34.6	32.6	30.5	26.0	21.3	17.4		
	2%	WB	11.3	12.3	14.0	17.2	20.3	23.4	24.6	24.0	21.8	19.5	16.2	12.8		
		MCDB	15.1	17.0	19.6	23.6	26.7	31.2	32.8	31.9	29.8	25.0	20.5	15.8		
	5%	WB	10.5	11.4	13.1	16.3	19.2	22.5	23.6	23.3	21.1	18.5	15.2	11.8		
		MCDB	14.0	15.9	18.5	22.0	25.6	30.0	31.9	31.3	28.4	23.9	19.4	14.7		
	10%	WB	9.5	10.5	12.3	15.3	18.3	21.6	22.8	22.6	20.4	17.6	14.2	10.8		
		MCDB	12.5	14.7	17.4	20.5	23.9	29.1	31.2	30.6	27.5	22.7	18.0	13.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.6	11.4	11.7	11.4	12.5	13.5	14.1	13.6	12.7	10.7	10.5		
		MCDBR	11.9	13.1	14.9	14.7	13.9	14.5	15.5	15.3	15.5	14.8	12.5	11.8		
	5% WB	MCWBR	7.0	6.8	7.2	6.8	5.9	5.2	5.3	4.9	5.3	6.8	6.5	7.1		
		MCWBR	10.2	11.5	12.4	12.6	12.5	13.1	14.0	13.8	13.4	12.8	10.5	9.6		
(40) Clear-Sky Solar Irradiance	taub		0.340	0.367	0.413	0.466	0.456	0.433	0.438	0.454	0.434	0.401	0.367	0.342		
	taud		2.426	2.328	2.194	2.060	2.152	2.266	2.250	2.199	2.246	2.319	2.375	2.423		
	Ebn at Noon		809	835	830	810	827	846	838	811	801	785	764	772		
	Edh at Noon		81	103	131	161	150	134	135	138	124	103	85	76		
(44) All-Sky Solar Radiation	RadAvg		1.83	2.60	3.84	4.96	6.16	7.11	7.33	6.45	4.73	3.30	2.10	1.63		
	RadStd		0.20	0.36	0.48	0.49	0.42	0.41	0.31	0.33	0.33	0.32	0.19	0.28		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (18 neighbors)	+0.36	N/A	N/A	N/A	N/A	N/A	N/A	-83	N/A	N/A

Nomenclature: See separate page