

KORCA, Albania

WMO: 136290

Lat: 40.600N

Lon: 20.767E

Elev: 899

StdP: 90.98

Time Zone: 1.00 (EUC)

Period: 86-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.4	-5.2	-11.8	1.5	-3.6	-9.5	1.9	-3.4	14.3	6.3	11.8	3.6	1.1	40	0.438

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	31.4	18.8	29.9	18.5	28.4	18.1	20.8	26.8	20.0	25.8	19.4	25.2	2.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	15.6	23.0	18.4	14.8	22.1	17.6	14.0	21.6	64.6	26.8	61.6	25.8	59.2	25.2	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
9.6	6.9	5.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			-10.8	23.9	2.5	2.0	-12.7	25.4	-14.1	26.5	-15.6	27.6	-17.4	29.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.2	1.4	4.3	7.5	11.6	15.1	19.1	22.3	22.1	18.0	12.6	8.0	3.5
	DBStd	7.73	4.07	3.75	3.25	3.71	3.02	3.48	2.71	2.44	3.10	3.25	3.27	3.53
	HDD10.0	839	266	162	93	24	2	0	0	0	0	14	76	202
	HDD18.3	2591	523	392	337	205	106	32	3	2	42	178	310	461
	CDD10.0	1629	0	3	14	71	161	274	380	373	241	96	16	1
	CDD18.3	341	0	0	0	2	7	56	125	117	32	1	0	0
	CDH23.3	2782	0	0	0	19	44	424	1059	1004	226	6	0	0
	CDH26.7	797	0	0	0	2	5	100	343	307	38	1	0	0
Wind	WSAvg	2.1	1.9	2.4	2.4	2.5	2.3	2.0	1.9	1.9	2.1	1.8	2.0	1.7
Precipitation	PrecAvg	815	66	72	66	80	69	43	32	79	85	109	96	
	PrecMax	1312	170	150	138	186	170	105	78	248	224	234	203	
	PrecMin	547	4	16	14	20	14	9	3	5	4	4	25	10
	PrecStd	225	46	39	33	37	41	26	20	19	64	54	48	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	16.7	19.7	25.2	26.7	31.4	34.0	33.0	30.4	24.0	18.1	12.5
		MCWB	8.3	8.7	10.4	13.5	15.4	18.9	19.2	20.2	17.4	14.8	11.9	8.8
	2%	DB	9.6	14.0	17.8	22.7	24.6	29.0	31.6	31.4	27.6	21.6	15.8	10.9
		MCWB	7.1	7.7	9.6	12.6	15.0	18.1	18.5	19.3	17.7	13.8	11.2	8.4
	5%	DB	8.3	11.6	15.7	20.2	22.8	27.6	30.1	29.6	26.0	19.9	14.0	9.8
		MCWB	6.2	7.3	8.7	11.6	14.3	17.9	18.3	18.7	17.0	13.4	11.0	7.7
	10%	DB	7.0	9.7	13.6	18.4	21.2	25.7	28.5	28.2	24.5	18.3	12.7	8.4
		MCWB	5.2	6.8	8.1	11.1	14.0	17.1	18.0	18.1	16.7	13.0	10.3	6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.3	10.1	11.4	15.0	17.4	21.2	21.6	22.8	20.3	16.6	13.5	10.3
		MCDB	10.8	13.4	17.2	20.7	22.4	26.4	27.6	29.6	24.9	20.8	15.4	11.1
	2%	WB	7.5	8.9	10.2	13.7	16.2	20.0	20.6	21.0	19.0	15.5	12.5	9.1
		MCDB	9.1	11.7	16.0	19.7	21.5	25.5	26.6	27.4	24.7	18.9	14.3	10.3
	5%	WB	6.4	8.0	9.3	12.9	15.6	19.1	19.8	20.0	18.2	14.6	11.3	8.2
		MCDB	8.0	11.1	14.2	18.8	20.6	24.9	25.4	26.3	23.5	17.8	13.3	9.4
	10%	WB	5.4	6.9	8.6	11.8	14.9	18.1	19.2	19.3	17.4	13.8	10.5	6.9
		MCDB	6.8	9.8	12.6	16.8	19.6	23.9	25.1	25.3	22.3	16.9	12.4	7.9
Mean Daily Temperature Range	5% DB	MDBR	6.0	6.7	7.7	9.3	9.0	9.7	10.4	10.9	9.5	8.9	6.8	6.2
		MCDBR	7.3	10.4	12.1	12.8	11.4	11.7	12.4	12.6	12.4	11.9	9.0	8.0
		MCWBR	4.9	5.0	5.2	4.8	4.2	4.0	3.9	4.2	3.9	5.1	4.8	5.0
	5% WB	MCDBR	6.3	7.6	10.4	11.3	9.6	10.7	10.8	11.1	10.4	9.5	6.7	6.1
		MCWBR	4.6	4.5	5.2	4.6	4.1	4.1	3.8	4.3	4.3	4.9	4.4	4.6
Clear-Sky Solar Irradiance	taub	0.304	0.330	0.375	0.426	0.422	0.401	0.408	0.420	0.402	0.366	0.331	0.306	
	taud	2.448	2.353	2.256	2.114	2.184	2.285	2.262	2.226	2.263	2.359	2.428	2.448	
	Ebn at Noon	857	879	872	847	857	874	864	843	833	826	813	823	
	Edh at Noon	79	100	123	152	145	131	133	134	121	98	80	73	
All-Sky Solar Radiation	RadAvg	1.82	2.59	3.67	4.67	5.72	6.68	6.97	6.15	4.54	3.23	2.11	1.62	
	RadStd	0.24	0.37	0.45	0.52	0.43	0.48	0.38	0.39	0.36	0.33	0.20	0.29	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (16 neighbors)	+0.40	N/A	N/A	+0.71	N/A	N/A	N/A	-100	+100	N/A

Nomenclature: See separate page