

KREDARICA, Slovenia

WMO: 140080

Lat: 46.3789N

Lon: 13.8489E

Elev: 2515

StdP: 74.54

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-19.2	-17.4	-29.6	0.3	-7.6	-26.7	0.4	-9.3	22.5	-7.7	19.5	-9.0	10.0	320	0.924

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	14.6	9.1	13.3	8.6	12.1	8.0	10.7	13.1	9.7	12.1	8.9	11.1	3.3	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.6	10.2	11.9	8.6	9.5	10.8	7.8	8.9	10.0	38.3	13.2	35.6	12.3	33.3	11.2	15.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.4	13.2	DB	-21.9	16.8	3.0	1.6	-24.1	17.9	-25.8	18.9	-27.5	19.8	-29.7	20.9	(4)
(5)			WB	-22.1	12.3	2.7	1.4	-24.0	13.2	-25.6	14.0	-27.1	14.8	-29.1	15.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	-0.5	-7.2	-7.6	-5.6	-3.3	1.1	5.3	7.3	7.6	3.3	1.3	-3.2	-5.6	(6)	
	DBStd	6.86	5.11	5.21	4.74	4.00	3.52	3.85	3.21	3.35	3.77	4.29	4.89	5.15	(7)	
	HDD10.0	3867	534	493	483	398	276	148	95	88	202	271	396	484	(8)	
	HDD18.3	6878	792	726	742	648	534	392	343	333	452	529	646	742	(9)	
	CDD10.0	31	0	0	0	0	0	6	10	14	1	1	0	0	(10)	
	CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)	
	CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	5.6	7.2	6.8	6.5	5.4	5.0	4.2	4.1	4.1	4.9	5.6	6.6	6.8	(14)	
(15) Precipitation	PrecAvg	1965	103	93	116	142	145	171	171	159	214	245	257	150	(15)	
	PrecMax	2623	440	435	369	277	290	293	289	292	388	601	874	452	(16)	
	PrecMin	1473	4	2	0	22	58	36	58	54	84	0	46	0	(17)	
	PrecStd	315	92	96	82	71	59	64	56	61	93	131	178	110	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	5.3	5.5	4.6	6.6	11.0	15.0	16.0	16.7	12.6	11.7	8.9	6.0	(19)	
		MCWB	-1.8	-2.1	-1.7	1.6	4.6	8.7	10.4	10.2	6.5	3.6	1.6	-1.6	(20)	
	2%	DB	3.2	3.4	3.0	4.9	9.0	13.2	14.2	15.0	11.0	9.7	7.3	4.1	(21)	
		MCWB	-2.4	-2.6	-2.0	0.9	4.7	8.2	9.7	8.8	6.1	2.1	1.1	-2.4	(22)	
	5%	DB	1.5	1.6	1.7	3.4	7.3	11.9	12.9	13.6	9.6	8.1	5.1	2.6	(23)	
		MCWB	-3.4	-3.4	-2.3	0.2	4.0	7.6	9.2	8.4	5.0	2.2	-0.2	-2.9	(24)	
	10%	DB	-0.3	-0.4	0.6	2.0	5.9	10.7	11.7	12.1	8.4	6.7	2.6	1.2	(25)	
		MCWB	-4.4	-4.1	-2.8	-0.6	3.1	7.0	8.2	8.4	4.7	1.6	-0.7	-3.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-0.6	-0.2	0.1	3.1	7.2	11.0	12.3	12.0	8.8	5.8	4.0	0.0	(27)	
		MCDB	2.8	3.0	2.3	4.7	8.8	13.3	14.4	14.5	10.6	8.1	7.5	2.9	(28)	
	2%	WB	-1.7	-1.9	-0.8	2.2	5.6	9.7	10.9	10.6	7.5	4.9	2.2	-0.9	(29)	
		MCDB	1.6	1.5	1.5	4.1	7.5	12.1	13.2	13.1	9.2	6.1	4.8	1.5	(30)	
	5%	WB	-2.6	-2.8	-1.5	1.0	4.4	8.5	9.8	9.7	6.6	4.2	1.0	-1.8	(31)	
		MCDB	0.2	0.2	0.6	2.6	6.2	10.8	12.0	12.2	8.4	5.6	2.6	0.8	(32)	
	10%	WB	-3.5	-3.7	-2.4	-0.1	3.6	7.5	8.8	8.9	5.7	3.4	0.1	-2.7	(33)	
		MCDB	-1.1	-1.0	-0.3	1.2	5.3	9.9	11.0	11.2	7.5	5.1	1.7	-0.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	4.8	4.5	4.0	3.7	4.1	4.3	4.1	4.0	4.0	4.2	4.7	(35)	
		MCDBR	6.1	5.9	5.0	4.4	4.7	5.0	5.4	5.3	5.2	4.9	5.8	6.0	(36)	
	5% WB	MCWBR	3.9	3.5	3.4	3.4	4.2	5.2	5.1	4.7	4.7	4.2	3.5	3.6	(37)	
		MCWBR	5.5	5.5	4.4	3.7	4.1	4.6	4.9	4.6	4.6	3.9	4.0	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.225	0.244	0.275	0.305	0.311	0.318	0.315	0.311	0.295	0.281	0.255	0.227	(40)	
		taud	2.519	2.503	2.489	2.452	2.458	2.453	2.459	2.486	2.527	2.571	2.597	2.574	(41)	
	Edn at Noon	Edn at Noon	919	959	965	955	954	945	943	937	929	899	872	883	(42)	
		Edh at Noon	61	76	91	104	107	109	107	99	87	71	57	52	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.40	2.24	3.40	4.29	5.12	5.76	5.85	5.10	3.75	2.45	1.40	1.19	(44)	
	RadStd	RadStd	0.17	0.33	0.43	0.54	0.57	0.41	0.40	0.50	0.44	0.29	0.24	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.59	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (78 neighbors)		+0.48	N/A	N/A	+0.75	+0.44	+0.34	N/A	-126	+93	+58

Nomenclature: See separate page