

LISCA, Slovenia

WMO: 140240

Lat: 46.0678N

Lon: 15.2850E

Elev: 3087

StdP: 13.13

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.9	14.7	0.6	6.3	18.0	5.7	8.2	23.9	29.5	35.5	26.5	36.0	6.6	70	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	79.7	65.7	76.6	64.8	73.9	63.4	68.0	76.6	66.1	74.4	64.5	72.5	4.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.9	103.4	73.3	63.0	96.7	71.2	61.4	91.1	69.4	34.2	76.5	32.7	74.6	31.4	72.6	76.6

Extreme Annual Design Conditions

Extreme Annual WS							Extreme Annual Temperature										n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years										
Min	Max				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max										
(a)	(b)	(c)			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)										
23.2	20.4	18.0			7.2	83.7	4.6	4.4	3.9	86.9	1.3	89.4	-1.3	91.9	-4.6	95.1										
			DB		6.5	70.8	4.4	2.9	3.3	72.9	0.8	74.6	-1.7	76.2	-4.9	78.3										
			WB																							

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	46.9	29.8	31.6	37.6	46.1	53.9	60.6	64.5	63.7	55.1	47.8	39.2	31.7
	DBStd	14.48	8.69	8.86	8.86	7.82	7.04	7.27	6.42	6.86	6.25	7.70	7.83	8.33
	HDD50	2798	627	516	391	162	40	7	0	2	21	135	329	568
	HDD65	6799	1091	935	849	568	348	170	89	108	300	535	774	1032
	CDD50	1660	0	2	7	44	161	323	451	427	175	65	5	0
	CDD65	189	0	0	0	0	5	37	74	69	4	0	0	0
	CDH74	625	0	0	0	0	6	99	249	269	2	0	0	0
	CDH80	84	0	0	0	0	0	5	31	48	0	0	0	0
Wind	WSAvg	7.9	9.3	8.6	8.5	7.9	7.4	6.4	6.2	6.3	6.9	8.4	9.3	9.4
Precipitation	PrecAvg	43.0	1.9	2.1	2.5	3.0	3.9	4.6	4.3	4.5	5.0	4.7	4.0	3.0
	PrecMax	56.1	3.9	5.9	5.4	5.4	7.0	8.3	7.7	10.0	11.1	11.5	9.1	5.5
	PrecMin	28.9	0.3	0.1	0.2	0.3	1.4	1.6	1.5	0.7	1.8	0.2	0.1	0.6
	PrecStd	5.7	1.2	1.5	1.5	1.3	1.5	1.5	1.7	2.3	2.5	2.6	2.0	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.9	57.1	61.3	68.5	74.2	80.2	83.5	84.5	72.9	66.2	57.4	51.2
		MCWB	38.9	41.6	47.7	53.4	61.6	66.1	66.7	66.4	63.5	57.1	50.2	39.9
	2%	DB	47.2	51.2	56.1	63.3	70.2	76.8	79.6	80.0	69.5	62.3	53.5	47.3
		MCWB	39.5	39.8	44.6	50.5	58.7	65.3	66.3	65.1	61.3	55.2	49.0	41.9
	5%	DB	43.9	45.9	52.1	59.7	67.3	73.9	76.4	76.4	66.5	59.5	51.2	44.4
		MCWB	39.7	37.9	42.9	48.7	57.1	64.0	65.0	64.1	59.7	54.1	48.0	40.9
	10%	DB	41.2	42.3	48.4	56.4	64.1	71.1	73.5	73.4	63.7	57.1	49.1	42.0
		MCWB	38.1	37.4	41.4	47.1	55.3	62.1	63.5	62.9	57.8	53.0	46.8	38.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.5	43.6	48.8	54.9	63.8	69.3	71.1	70.2	65.1	59.6	52.7	46.3
		MCDB	46.1	51.0	57.8	64.3	71.8	77.0	78.3	78.4	71.0	64.3	54.7	48.2
	2%	WB	42.2	41.4	46.1	51.5	60.6	66.6	68.2	67.4	62.5	57.1	50.4	43.8
		MCDB	44.1	46.8	53.3	60.3	68.4	74.6	76.9	76.4	67.8	60.3	52.2	45.3
	5%	WB	40.2	40.0	44.4	49.7	58.3	64.8	66.2	65.5	60.4	55.5	48.6	41.8
		MCDB	42.5	44.2	49.5	57.5	65.2	72.7	74.5	74.0	65.4	58.2	50.4	43.3
	10%	WB	38.4	38.3	42.9	48.1	56.1	62.7	64.4	63.9	58.6	54.0	47.1	39.7
		MCDB	41.1	41.9	47.5	54.9	62.8	70.3	72.6	71.6	63.0	56.5	49.0	41.3
Mean Daily Temperature Range	5% DB	MDBR	7.3	8.2	10.5	11.6	11.7	12.2	12.4	11.8	9.9	8.7	7.1	7.1
		MCDBR	9.4	11.8	15.0	15.6	14.7	14.5	14.7	14.7	12.2	10.9	8.4	9.4
		MCWBR	5.8	7.0	8.9	8.7	9.3	9.9	9.4	9.0	8.4	7.1	5.7	6.5
	5% WB	MCDBR	7.4	9.9	12.9	14.0	13.9	13.9	14.0	13.7	11.6	9.7	7.4	7.3
		MCWBR	5.6	6.8	8.3	8.2	9.6	10.0	9.8	9.3	8.4	6.9	5.8	6.2
Clear-Sky Solar Irradiance	taub	0.288	0.309	0.341	0.380	0.376	0.382	0.382	0.380	0.364	0.344	0.316	0.288	
	taud	2.450	2.406	2.370	2.285	2.327	2.340	2.338	2.355	2.381	2.437	2.478	2.501	
	Ebn at Noon	261	276	281	278	282	280	279	275	269	259	247	249	
	Edh at Noon	22	28	33	39	39	39	38	36	32	27	21	19	
All-Sky Solar Radiation	RadAvg	398	652	1020	1350	1662	1883	1896	1660	1163	751	415	333	
	RadStd	59	109	144	163	165	126	125	183	153	88	63	50	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (62 neighbors)	+0.85	N/A	N/A	+1.58	+0.88	+0.68	N/A	-221	+166	+108

Nomenclature: See separate page