

MARIBOR SLIVNICA, Slovenia

WMO: 140260

Lat: 46.4797N

Lon: 15.6819E

Elev: 267

StdP: 98.16

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.5	-8.9	-14.8	1.1	-9.8	-11.8	1.4	-6.8	9.6	7.6	8.5	6.8	1.1	0	0.474

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.6	31.8	21.0	30.1	20.5	28.4	19.7	22.1	29.1	21.2	28.1	20.4	27.0	3.5	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.9	15.0	25.6	18.9	14.1	24.3	18.0	13.4	23.4	65.9	29.1	62.4	28.3	59.7	27.2	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.2	7.0	6.0	-15.4	33.9	3.6	2.0	-18.0	35.4	-20.1	36.6	-22.1	37.8	-24.7	39.2		
(5)			-15.8	23.8	3.5	1.3	-18.3	24.7	-20.4	25.5	-22.3	26.3	-24.9	27.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	0.1	1.9	6.1	11.0	15.5	19.3	20.9	20.4	15.8	11.1	6.2	1.0		
	DBStd	8.28	4.56	4.73	4.27	3.66	3.30	3.38	2.90	3.04	3.23	3.91	4.36	4.30		
	HDD10.0	1142	307	227	131	32	0	0	0	1	34	128	281			
	HDD18.3	2994	565	459	379	221	98	29	11	14	90	224	364	539		
	CDD10.0	1439	1	1	10	62	173	278	337	321	173	69	13	1		
	CDD18.3	249	0	0	0	1	11	58	89	77	13	1	0	0		
	CDH23.3	2538	0	0	0	16	147	578	906	779	107	6	0	0		
	CDH26.7	791	0	0	0	1	22	174	306	276	14	0	0	0		
(14) Wind	WSAvg	2.2	2.0	2.4	2.6	2.6	2.5	2.2	2.0	1.8	1.9	2.0	2.1	2.0		
(15) Precipitation	PrecAvg	1078	47	52	63	77	104	119	112	117	120	104	97	69		
	PrecMax	1410	113	155	132	168	177	197	205	210	253	266	223	134		
	PrecMin	791	7	2	15	6	43	48	46	18	61	1	12	11		
	PrecStd	123	26	37	34	33	41	38	41	53	53	59	50	36		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.7	16.8	20.7	25.8	29.0	32.8	33.9	34.2	28.2	24.1	19.0	14.1		
		MCWB	9.2	9.7	11.7	15.5	18.2	21.0	21.9	21.1	19.6	17.1	13.7	10.9		
	2%	DB	11.1	13.2	18.1	22.7	26.8	30.8	31.7	31.8	26.1	21.8	16.8	11.8		
		MCWB	7.9	8.0	10.7	13.4	17.5	20.5	21.2	20.8	18.9	16.2	12.6	8.8		
	5%	DB	9.1	11.3	16.0	20.7	24.9	28.8	30.0	29.8	24.2	19.9	14.5	9.4		
		MCWB	6.4	7.2	9.9	12.9	16.6	20.0	20.6	20.4	17.9	15.2	11.5	7.0		
	10%	DB	7.0	9.2	13.8	18.6	23.0	26.8	28.2	27.8	22.2	17.9	12.9	7.1		
		MCWB	4.8	5.9	8.8	11.8	15.7	18.9	19.7	19.7	16.7	14.1	10.5	5.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.1	12.5	16.0	19.6	22.9	23.6	23.1	20.7	17.9	14.2	11.2		
		MCDB	12.6	15.6	18.7	24.1	26.4	29.8	30.8	29.9	26.6	23.1	17.7	13.9		
	2%	WB	8.1	8.6	11.2	14.4	18.3	21.4	22.2	21.8	19.4	16.6	13.0	9.2		
		MCDB	10.7	12.6	16.8	20.8	24.9	28.3	29.0	29.2	25.1	20.7	15.9	11.5		
	5%	WB	6.6	7.5	10.2	13.4	17.2	20.4	21.2	21.0	18.4	15.5	11.8	7.2		
		MCDB	8.7	10.8	15.1	19.0	23.3	27.4	28.0	27.9	23.4	19.1	14.3	8.9		
	10%	WB	5.0	6.2	9.2	12.4	16.2	19.5	20.3	20.1	17.3	14.4	10.6	5.4		
		MCDB	6.9	8.9	13.4	17.6	21.9	25.9	26.9	26.5	21.4	17.4	12.6	6.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	9.1	10.5	11.0	11.0	11.1	11.6	11.6	10.1	9.6	7.4	7.0		
		MCDBR	10.8	12.9	14.7	15.5	14.6	14.5	14.8	15.2	12.8	12.5	10.5	10.3		
	5% WB	MCWBR	7.4	8.2	8.4	7.6	6.7	6.1	6.0	6.0	6.4	7.3	7.0	7.6		
		MCWBR	9.8	12.0	13.4	13.1	13.2	13.3	13.4	13.6	12.0	11.1	9.4	9.4		
(40) Clear-Sky Solar Irradiance	taub	0.320	0.346	0.385	0.433	0.428	0.434	0.436	0.436	0.436	0.413	0.386	0.352	0.319		
	taud	2.386	2.322	2.257	2.148	2.213	2.241	2.236	2.245	2.279	2.330	2.378	2.429			
	Ebn at Noon	767	816	832	822	840	836	828	811	794	757	716	726			
	Edh at Noon	73	94	116	142	138	135	134	128	113	93	74	63			
(44) All-Sky Solar Radiation	RadAvg	1.26	2.08	3.25	4.29	5.23	5.83	5.83	5.13	3.64	2.40	1.31	1.02			
	RadStd	0.18	0.32	0.42	0.48	0.49	0.40	0.40	0.55	0.47	0.27	0.20	0.15			

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	N/A	+0.72	+0.65	-108	-172	+119	+62
(47) Regional (76 neighbors)		+0.51	N/A	N/A	+0.92	+0.51	+0.42	-91	-136	+95	+61

Nomenclature: See separate page