

MURSKA SOBOTA, Slovenia

WMO: 140310

Lat: **46.6521N**Lon: **16.1913E**Elev: **613**StdP: **14.37**Time Zone: **1.00 (EUC)**Period: **95-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.0	16.4	5.3	7.4	15.1	11.1	9.9	19.2	19.7	37.6	16.7	37.6	2.1	330	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.0	89.6	70.4	86.5	69.6	83.7	68.3	72.6	85.0	71.0	83.4	69.4	81.1	5.0	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.4	106.9	78.6	66.8	100.9	76.6	65.4	95.8	74.5	36.6	84.8	35.1	83.9	33.8	81.3	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 16.1	13.0	10.6		4.7	93.9	8.1	4.4	-1.1	97.1	-5.8	99.7	-10.3	102.2	-16.2	105.5	
(5)			DB	4.2	75.3	7.9	2.2	-1.5	76.9	-6.2	78.2	-10.6	79.5	-16.4	81.1	(p)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	31.6	36.1	43.0	52.6	60.5	67.1	70.1	69.4	60.3	52.5	42.7	33.5	(6)
	DBStd	15.11	7.91	7.96	7.61	6.82	5.96	6.14	5.26	5.44	5.97	7.12	7.94	7.10	(7)
	HDD50	2066	570	392	235	51	3	0	0	0	1	57	244	513	(8)
	HDD65	5347	1035	810	682	374	163	49	16	19	164	388	670	977	(9)
	CDD50	2685	0	2	18	129	329	512	622	601	311	136	24	1	(10)
	CDD65	489	0	0	0	1	24	111	172	155	24	2	0	0	(11)
	CDH74	4923	0	0	0	29	290	1137	1742	1507	207	11	0	0	(12)
	CDH80	1600	0	0	0	2	46	355	609	556	32	0	0	0	(13)
(14) Wind	WSAvg	4.0	3.7	4.4	4.9	5.0	4.6	4.0	3.9	3.5	3.5	3.5	3.6	3.4	(14)
(15) Precipitation	PrecAvg	33.6	1.4	1.7	1.9	2.3	3.2	3.8	3.7	3.9	3.9	3.0	2.9	2.1	(15)
	PrecMax	43.4	4.0	5.1	4.4	5.4	5.6	6.9	6.3	8.0	7.7	8.2	7.6	4.3	(16)
	PrecMin	22.0	0.3	0.1	0.2	0.3	1.1	1.5	1.1	0.3	1.4	0.0	0.3	0.2	(17)
	PrecStd	5.2	0.9	1.4	1.1	1.2	1.4	1.2	1.5	2.1	2.0	1.8	1.7	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	61.4	68.8	77.6	84.6	90.9	93.7	94.7	83.9	75.5	67.1	57.2	(19)
		MCWB	48.7	49.6	53.8	60.6	66.2	71.2	71.6	71.3	68.1	63.9	57.7	50.7	(20)
	2%	DB	51.0	55.8	64.0	72.9	80.9	87.4	89.1	89.7	79.3	71.0	62.0	51.5	(21)
		MCWB	45.6	47.4	51.6	57.4	64.9	70.0	70.7	70.2	66.3	61.3	55.2	46.6	(22)
	5%	DB	46.9	52.4	59.8	69.3	77.5	84.2	86.0	86.1	75.9	67.7	58.2	46.7	(23)
		MCWB	42.7	45.4	49.6	55.9	63.1	68.7	69.3	69.5	64.6	59.5	53.2	43.3	(24)
	10%	DB	42.6	48.6	55.9	65.8	73.9	80.8	83.2	82.3	72.1	64.5	54.7	42.9	(25)
		MCWB	39.7	42.8	47.7	54.0	61.3	66.9	68.1	67.9	62.3	58.0	50.9	40.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.2	50.6	55.1	62.4	68.6	73.7	75.1	74.6	69.9	65.0	58.3	51.0	(27)
		MCDB	53.9	59.5	66.5	74.3	81.1	85.7	88.2	88.3	80.6	73.9	64.5	57.1	(28)
	2%	WB	46.1	48.1	52.2	59.1	66.2	71.5	72.5	72.4	67.5	62.3	55.7	46.9	(29)
		MCDB	50.4	55.1	62.1	69.9	78.6	83.9	84.8	85.4	77.4	69.3	60.9	51.2	(30)
	5%	WB	43.0	45.8	50.3	57.1	64.3	69.7	70.7	70.7	65.7	60.3	53.5	43.6	(31)
		MCDB	46.3	51.9	58.3	66.9	74.8	82.2	82.9	83.3	74.2	66.2	57.9	46.2	(32)
	10%	WB	40.1	43.3	48.4	55.0	62.3	68.1	69.2	68.9	63.6	58.5	51.1	41.0	(33)
		MCDB	42.5	47.8	55.5	63.9	71.8	79.2	80.5	80.1	70.2	63.8	54.6	42.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	15.9	18.5	19.6	19.5	20.3	21.0	20.7	18.3	17.4	12.9	10.7	(35)
		MCDBR	19.0	22.8	26.1	26.8	26.2	25.9	26.4	27.1	23.8	22.2	18.5	17.0	(36)
	5% WB	MCWBR	13.7	14.9	15.4	13.4	12.1	10.7	10.2	10.3	11.8	13.5	12.7	12.8	(37)
		MCWBR	17.9	21.3	23.2	23.4	23.2	24.3	23.7	25.2	22.1	20.5	16.9	15.8	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.326	0.352	0.390	0.438	0.431	0.437	0.439	0.442	0.418	0.390	0.357	0.326	(40)
		taud	2.376	2.319	2.243	2.128	2.200	2.229	2.222	2.223	2.261	2.311	2.356	2.408	(41)
	Ebn at Noon	Ebn at Noon	239	256	262	259	266	264	262	255	250	238	224	226	(42)
		Edn at Noon	23	30	37	46	44	43	43	41	36	30	24	20	(43)
(44) All-Sky Solar Radiation	RadAvg		383	639	1014	1405	1708	1877	1863	1648	1164	768	415	298	(44)
	RadStd		50	93	125	144	155	134	131	172	146	83	54	44	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) +1.40	(i) +1.60	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (73 neighbors)	+0.97	N/A	N/A	+1.64	+0.90	+0.79	-194	-272	+171	+108