

MURSKA SOBOTA, Slovenia

WMO: 140310

Lat: 46.6521N

Lon: 16.1913E

Elev: 187

StdP: 99.10

Time Zone: 1.00 (EUC)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.7	-8.7	-14.8	1.1	-9.4	-11.6	1.4	-7.1	8.8	3.1	7.5	3.1	0.9	330	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.7	32.0	21.4	30.3	20.9	28.7	20.1	22.5	29.5	21.6	28.6	20.8	27.3	2.2	190

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	15.3	25.9	19.3	14.4	24.8	18.5	13.7	23.6	67.2	29.3	63.8	28.8	60.8	27.4	26.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.2	5.8	4.7	-15.2	34.4	4.5	2.5	-18.4	36.2	-21.0	37.6	-23.5	39.0	-26.8	40.8		
(5)			-15.4	24.1	4.4	1.2	-18.6	25.0	-21.2	25.7	-23.7	26.4	-26.9	27.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	-0.2	2.3	6.1	11.4	15.8	19.5	21.1	20.8	15.7	11.4	5.9	0.8
	DBStd	8.39	4.40	4.42	4.23	3.79	3.31	3.41	2.92	3.02	3.32	3.96	4.41	3.95
	HDD10.0	1148	317	218	131	28	2	0	0	0	1	32	136	285
	HDD18.3	2971	575	450	379	208	91	27	9	11	91	216	372	543
	CDD10.0	1492	0	1	10	72	183	284	346	334	173	76	13	1
	CDD18.3	272	0	0	0	1	13	62	96	86	13	1	0	0
	CDH23.3	2735	0	0	0	16	161	632	968	837	115	6	0	0
	CDH26.7	889	0	0	0	1	26	197	338	309	18	0	0	0
Wind	WSAvg	1.8	1.6	1.9	2.2	2.2	2.1	1.8	1.8	1.6	1.6	1.6	1.6	1.5
Precipitation	PrecAvg	853	35	42	48	58	82	96	95	98	98	75	73	53
	PrecMax	1103	102	130	111	136	142	176	159	203	196	209	192	110
	PrecMin	558	8	3	6	8	28	37	27	7	36	0	8	6
	PrecStd	132	23	35	29	31	35	31	37	53	51	46	42	28
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	16.3	20.4	25.3	29.2	32.7	34.3	34.8	28.8	24.2	19.5	14.0
		MCWB	9.3	9.8	12.1	15.9	19.0	21.8	22.0	21.8	20.0	17.7	14.3	10.4
	2%	DB	10.6	13.2	17.8	22.7	27.2	30.8	31.7	32.1	26.3	21.7	16.6	10.9
		MCWB	7.6	8.6	10.9	14.1	18.3	21.1	21.5	21.2	19.1	16.3	12.9	8.1
	5%	DB	8.3	11.3	15.5	20.7	25.3	29.0	30.0	30.1	24.4	19.8	14.5	8.2
		MCWB	5.9	7.4	9.8	13.3	17.3	20.4	20.7	20.9	18.1	15.3	11.8	6.3
	10%	DB	5.9	9.2	13.3	18.8	23.3	27.1	28.4	27.9	22.3	18.1	12.6	6.1
		MCWB	4.3	6.0	8.7	12.2	16.3	19.4	20.1	19.9	16.9	14.4	10.5	4.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.6	10.3	12.8	16.9	20.3	23.2	23.9	23.7	21.0	18.4	14.6	10.6
		MCDB	12.2	15.3	19.1	23.5	27.3	29.8	31.2	31.3	27.0	23.3	18.0	13.9
	2%	WB	7.8	8.9	11.2	15.1	19.0	21.9	22.5	22.4	19.7	16.8	13.2	8.3
		MCDB	10.2	12.8	16.7	21.0	25.9	28.9	29.4	29.7	25.2	20.7	16.0	10.7
	5%	WB	6.1	7.7	10.2	13.9	17.9	20.9	21.5	21.5	18.7	15.7	11.9	6.5
		MCDB	8.0	11.1	14.6	19.4	23.8	27.9	28.3	28.5	23.4	19.0	14.4	7.9
	10%	WB	4.5	6.3	9.1	12.8	16.8	20.0	20.7	20.5	17.5	14.7	10.6	5.0
		MCDB	5.9	8.8	13.0	17.7	22.1	26.2	27.0	26.7	21.2	17.7	12.5	6.0
Mean Daily Temperature Range	5% DB	MDBR	6.8	8.8	10.3	10.9	10.8	11.3	11.7	11.5	10.2	9.7	7.1	6.0
		MCDBR	10.6	12.6	14.5	14.9	14.6	14.4	14.7	15.0	13.2	12.4	10.3	9.4
		MCWBR	7.6	8.3	8.5	7.4	6.7	6.0	5.7	5.7	6.6	7.5	7.1	7.1
	5% WB	MCDBR	9.9	11.8	12.9	13.0	12.9	13.5	13.2	14.0	12.3	11.4	9.4	8.8
		MCWBR	7.3	8.0	7.9	6.7	6.5	6.0	5.8	6.1	6.4	7.1	6.5	6.8
Clear-Sky Solar Irradiance	taub	0.326	0.352	0.390	0.438	0.431	0.437	0.439	0.442	0.418	0.390	0.357	0.326	
	taud	2.376	2.319	2.243	2.128	2.200	2.229	2.222	2.223	2.261	2.311	2.356	2.408	
	Ebn at Noon	755	807	826	816	837	833	825	804	788	750	705	711	
	Edh at Noon	73	94	118	145	139	136	135	130	115	95	75	64	
All-Sky Solar Radiation	RadAvg	1.21	2.01	3.20	4.43	5.38	5.92	5.87	5.20	3.67	2.42	1.31	0.94	
	RadStd	0.16	0.29	0.39	0.46	0.49	0.42	0.41	0.54	0.46	0.26	0.17	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	+0.78	+0.89	N/A	N/A	N/A	N/A
Regional (73 neighbors)	+0.54	N/A	N/A	+0.91	+0.50	+0.44	-108	-151	+95	+60

Nomenclature: See separate page