

NOVA GORICA, Slovenia

WMO: 141060

Lat: 45.8954N

Lon: 13.6241E

Elev: 184

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.2	24.8	7.2	8.0	33.1	12.9	10.7	35.7	19.5	39.0	16.9	39.6	3.5	90	0.420

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.2	92.3	71.1	89.4	70.2	86.8	69.2	73.4	87.1	71.9	85.2	70.6	83.3	6.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.3	108.4	78.0	67.8	102.9	76.7	66.5	98.2	75.4	37.0	87.3	35.7	85.1	34.5	83.5	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.7	14.4	12.4	DB	18.0	96.7	3.8	3.0	15.2	98.8	13.0	100.6	10.9	102.3	8.1	104.5	(4)
(5)			WB	16.7	76.1	3.8	1.8	14.0	77.4	11.8	78.4	9.6	79.4	6.9	80.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.2	39.1	41.3	47.5	54.8	62.6	70.3	73.9	73.1	64.6	57.1	48.3	40.5		
	DBStd	13.44	5.61	5.25	5.25	5.04	4.97	5.34	4.53	5.06	5.06	5.96	7.00	5.93		
	HDD50	1133	340	246	107	15	0	0	0	0	0	12	114	299		
	HDD65	4020	802	664	542	307	106	14	2	4	69	249	502	759		
	CDD50	3389	3	2	30	159	390	610	740	716	439	233	62	5		
	CDD65	799	0	0	0	1	31	174	277	255	57	4	0	0		
	CDH74	8121	0	0	1	25	369	1817	2864	2578	457	10	0	0		
	CDH80	3082	0	0	0	0	64	649	1187	1082	100	0	0	0		
(14) Wind	WSAvg	4.6	4.3	5.3	5.3	4.8	4.5	4.5	4.5	4.5	4.4	4.5	4.5	4.2		
(15) Precipitation	PrecAvg	58.0	3.8	3.4	3.7	4.3	4.7	4.6	4.3	4.3	6.1	6.7	7.2	5.0		
	PrecMax	81.1	12.9	10.8	10.8	10.4	10.9	9.6	8.5	10.6	14.1	15.1	21.3	12.2		
	PrecMin	41.5	0.3	0.2	0.2	0.4	0.9	0.9	1.5	0.6	2.0	1.0	1.1	0.2		
	PrecStd	10.5	2.8	2.9	2.8	2.4	2.5	1.7	2.0	2.4	3.3	3.8	4.5	3.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.9	62.1	70.0	77.2	85.4	93.6	95.4	96.9	86.2	75.5	67.5	58.8		
		MCWB	52.7	49.3	53.3	57.9	66.8	71.7	71.7	71.9	68.9	62.2	58.6	54.0		
	2%	DB	53.2	57.2	65.1	72.9	81.2	89.5	92.0	92.9	83.0	72.6	63.8	54.8		
		MCWB	48.8	47.4	51.5	57.2	64.4	70.0	71.4	70.8	67.0	62.8	57.8	50.1		
	5%	DB	50.3	54.0	61.4	69.8	78.0	86.8	89.2	89.3	79.2	69.7	61.2	52.0		
		MCWB	45.8	46.0	49.9	56.0	62.6	69.1	70.3	70.4	65.2	61.8	56.4	47.2		
	10%	DB	47.9	51.1	58.3	66.6	74.8	83.8	86.6	86.1	75.7	67.3	58.6	49.6		
		MCWB	44.6	45.2	48.6	54.6	61.2	67.9	69.1	69.1	63.7	60.5	54.5	45.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.9	52.1	56.3	61.6	69.0	74.5	75.7	75.4	70.9	67.0	61.1	55.3		
		MCDB	55.8	56.7	65.1	71.3	81.2	88.1	88.2	89.4	81.3	70.9	63.9	57.7		
	2%	WB	50.3	49.8	53.7	59.3	66.1	71.9	73.6	73.2	69.0	65.3	59.3	52.1		
		MCDB	52.0	54.0	60.0	67.9	78.0	85.7	87.4	86.9	78.8	69.3	62.4	54.4		
	5%	WB	47.6	48.0	52.3	57.5	64.3	70.2	72.0	71.8	67.4	63.9	57.5	49.0		
		MCDB	49.0	51.9	58.0	66.2	74.6	83.5	85.2	85.1	76.0	67.8	60.4	50.4		
	10%	WB	45.6	46.4	50.7	55.9	62.7	68.9	70.6	70.4	65.6	62.0	55.5	46.9		
		MCDB	47.0	50.1	56.1	64.1	71.6	81.2	83.1	82.9	72.7	65.6	57.9	48.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.1	16.7	18.1	18.4	19.4	21.6	22.2	21.9	19.7	16.5	14.5	14.7		
		MCDBR	17.9	23.2	25.9	25.9	26.0	26.1	26.4	27.4	24.6	19.7	16.2	18.1		
	5% WB	MCWBR	12.3	14.2	14.1	12.0	10.9	9.5	9.0	9.0	10.3	10.9	10.2	12.2		
		MCWBR	10.8	17.2	19.1	20.9	22.0	24.1	24.4	24.1	20.4	13.6	12.0	11.7		
(40) Clear-Sky Solar Irradiance	taub		0.342	0.371	0.422	0.470	0.476	0.488	0.477	0.467	0.446	0.423	0.377	0.339		
	taud		2.383	2.295	2.160	2.058	2.090	2.108	2.151	2.192	2.210	2.235	2.313	2.416		
	Ebn at Noon		237	251	252	250	253	251	252	249	242	227	218	225		
	Edh at Noon		24	31	41	49	49	49	46	43	39	33	25	21		
(44) All-Sky Solar Radiation	RadAvg		430	702	1090	1427	1737	1964	1995	1721	1250	790	451	373		
	RadStd		63	115	142	168	181	122	116	151	121	89	70	51		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (58 neighbors)	+0.83	N/A	N/A	+1.35	+0.79	N/A	-144	-227	+171	+112

Nomenclature: See separate page