

NOVO MESTO, Slovenia

WMO: 141210

Lat: 45.8018N

Lon: 15.1773E

Elev: 722

StdP: 14.32

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.0	18.3	7.6	8.3	18.8	12.3	10.6	23.1	14.5	48.0	12.2	42.1	2.9	190	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	89.3	69.8	86.1	69.3	83.3	68.2	72.5	84.1	70.8	82.5	69.3	80.7	5.0	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
68.6	108.0	78.8	66.8	101.3	76.2	65.3	96.1	74.1	36.5	84.0	35.0	82.4	33.7	81.0	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.9	10.7	8.8	7.3	94.4	4.9	3.7	3.7	97.1	0.9	99.2	-1.9	101.3	-5.5	104.0		
(5)			6.8	75.4	4.9	1.9	3.3	76.7	0.4	77.8	-2.3	78.8	-5.8	80.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.2	33.4	36.5	44.2	52.5	60.3	67.1	69.9	69.5	60.7	52.7	43.6	34.8	(6)
(7)		DBStd	14.68	7.87	7.89	7.58	6.66	5.89	6.07	5.32	5.53	5.79	7.10	8.17	7.86	(7)
(8)		HDD50	1905	515	381	206	50	3	0	0	1	55	220	474		(8)
(9)		HDD65	5165	979	799	646	375	167	47	17	20	153	384	641	937	(9)
(10)		CDD50	2704	1	2	25	126	324	513	618	604	322	138	29	2	(10)
(11)		CDD65	487	0	0	0	1	22	110	170	159	24	1	0	0	(11)
(12)		CDH74	4650	0	0	0	35	265	1093	1638	1425	182	12	0	0	(12)
(13)		CDH80	1459	0	0	0	2	39	326	565	504	23	0	0	0	(13)
(14)	Wind	WSAvg	3.3	3.1	3.5	4.1	4.0	3.7	3.4	3.2	3.1	2.9	3.1	3.1	3.0	(14)
(15)	Precipitation	PrecAvg	48.3	2.4	2.8	3.0	3.6	4.3	4.8	4.1	4.7	5.3	5.3	4.8	3.3	(15)
(16)		PrecMax	62.5	5.0	8.1	6.1	7.5	7.8	6.9	7.8	10.7	11.1	13.2	9.8	6.5	(16)
(17)		PrecMin	35.0	0.3	0.1	0.5	0.3	1.5	1.2	1.1	0.8	1.3	0.5	0.4	0.0	(17)
(18)		PrecStd	6.0	1.4	1.9	1.6	1.5	1.7	1.4	1.6	2.5	2.8	2.9	2.2	1.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.4	60.8	70.4	78.6	84.1	90.6	93.1	94.3	82.9	75.7	67.4	59.3	(19)
(20)		0.4%	MCWB	49.3	47.1	53.3	59.0	65.8	69.8	69.4	70.3	67.9	63.3	56.2	52.2	(20)
(21)		2%	DB	53.2	56.3	65.2	73.3	80.2	87.0	89.4	89.3	79.0	71.6	62.8	54.3	(21)
(22)		2%	MCWB	47.1	47.2	50.6	56.2	63.8	69.6	70.1	69.8	66.7	61.6	54.7	48.7	(22)
(23)		5%	DB	49.2	52.8	61.2	69.6	76.9	84.3	85.9	85.3	75.4	68.0	59.2	49.8	(23)
(24)		5%	MCWB	44.9	45.3	49.4	54.6	62.3	68.8	69.2	69.3	64.5	59.6	53.5	46.3	(24)
(25)		10%	DB	45.0	49.1	57.7	65.8	73.5	80.9	82.9	81.6	71.8	64.3	55.6	45.0	(25)
(26)		10%	MCWB	42.1	42.9	48.3	53.3	60.5	66.9	68.2	68.2	62.6	57.6	52.1	42.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.4	50.4	54.4	61.1	68.5	73.9	74.6	75.3	69.7	64.5	57.8	52.9	(27)
(28)		0.4%	MCDWB	55.8	58.0	65.9	73.0	80.3	85.6	86.6	86.8	79.8	73.2	63.0	58.5	(28)
(29)		2%	WB	47.8	48.1	52.3	58.1	65.5	71.5	72.3	72.2	67.4	62.4	55.8	49.2	(29)
(30)		2%	MCDWB	52.4	55.0	61.9	70.5	76.4	83.8	84.1	83.6	76.9	70.2	60.4	53.7	(30)
(31)		5%	WB	45.0	45.8	50.7	56.1	63.4	69.5	70.5	70.4	65.7	60.4	54.0	46.3	(31)
(32)		5%	MCDWB	48.7	51.7	59.2	66.2	74.0	81.3	82.6	81.6	73.6	66.3	58.8	50.0	(32)
(33)		10%	WB	42.4	43.5	49.0	54.5	61.5	67.8	69.1	68.8	63.8	58.6	51.9	43.0	(33)
(34)		10%	MCDWB	45.1	48.4	56.6	63.4	71.3	79.1	80.7	79.7	70.1	63.4	55.8	44.8	(34)
(35)	Mean Daily Temperature Range		MDBR	11.3	14.7	18.4	18.7	19.4	19.8	20.3	19.8	17.2	15.7	11.6	10.6	(35)
(36)		5% DB	MCDBR	18.1	23.2	26.5	27.3	25.8	25.5	26.0	26.4	22.9	21.6	18.3	18.1	(36)
(37)		5% DB	MCWBR	12.1	14.0	13.7	12.4	11.2	10.3	10.0	9.7	11.1	12.1	11.1	12.6	(37)
(38)		5% WB	MCDBR	16.2	20.2	22.4	22.9	23.0	23.3	23.4	22.9	20.7	18.9	15.1	16.1	(38)
(39)		5% WB	MCWBR	11.1	12.8	12.1	10.9	10.9	10.5	10.3	10.1	10.6	11.1	9.6	11.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.359	0.401	0.450	0.442	0.448	0.445	0.442	0.427	0.400	0.363	0.331	(40)	
(41)		taud	2.358	2.281	2.208	2.101	2.172	2.205	2.216	2.238	2.245	2.297	2.348	2.405	(41)	
(42)		Ebn at Noon	240	255	259	256	263	261	260	256	248	237	225	228	(42)	
(43)		Edh at Noon	24	31	39	48	46	44	43	41	37	31	24	21	(43)	
(44)	All-Sky Solar Radiation	RadAvg	394	641	1011	1352	1677	1913	1934	1689	1171	747	416	333	(44)	
(45)		RadStd	60	114	149	169	170	128	125	189	154	88	61	50	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	+1.49	+1.46	N/A	N/A	N/A	N/A	(46)
(47)	Regional (52 neighbors)	+0.79	N/A	N/A	+1.48	+0.81	+0.63	N/A	N/A	+151	+103	(47)

Nomenclature: See separate page