

NOVO MESTO, Slovenia

WMO: 141210

Lat: 45.8018N

Lon: 15.1773E

Elev: 220

StdP: 98.71

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.0	-7.6	-13.5	1.2	-7.3	-10.9	1.5	-4.9	6.5	8.9	5.4	5.6	1.3	190	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	31.9	21.0	30.1	20.7	28.5	20.1	22.5	29.0	21.5	28.0	20.7	27.1	2.2	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.4	26.0	19.3	14.5	24.6	18.5	13.7	23.4	67.1	28.9	63.6	28.0	60.6	27.2	26.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	4.8	3.9	-13.7	34.7	2.7	2.0	-15.7	36.2	-17.3	37.4	-18.8	38.5	-20.8	40.0		
(5)			-14.0	24.1	2.7	1.0	-16.0	24.8	-17.5	25.4	-19.1	26.0	-21.0	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	0.8	2.5	6.8	11.4	15.7	19.5	21.1	20.8	15.9	11.5	6.5	1.5
	DBStd	8.15	4.37	4.38	4.21	3.70	3.27	3.37	2.95	3.07	3.22	3.94	4.54	4.36
	HDD10.0	1058	286	212	114	28	2	0	0	0	1	31	122	263
	HDD18.3	2869	544	444	359	208	93	26	9	11	85	213	356	521
	CDD10.0	1502	1	1	14	70	180	285	343	336	179	77	16	1
	CDD18.3	271	0	0	0	1	12	61	94	88	13	1	0	0
	CDH23.3	2583	0	0	0	19	147	607	910	792	101	7	0	0
	CDH26.7	811	0	0	0	1	22	181	314	280	13	0	0	0
Wind	WSAvg	1.5	1.4	1.6	1.8	1.8	1.6	1.5	1.4	1.4	1.3	1.4	1.4	1.3
Precipitation	PrecAvg	1226	60	72	75	92	108	121	105	119	135	134	122	83
	PrecMax	1587	127	206	155	191	198	175	199	273	283	336	249	164
	PrecMin	890	8	2	13	7	38	31	27	21	34	13	10	1
	PrecStd	153	35	49	40	38	43	35	41	64	71	73	55	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	16.0	21.3	25.9	29.0	32.5	33.9	34.6	28.3	24.3	19.7	15.2
		MCWB	9.6	8.4	11.8	15.0	18.8	21.0	20.8	21.3	20.0	17.4	13.4	11.2
	2%	DB	11.8	13.5	18.5	23.0	26.8	30.6	31.9	31.8	26.1	22.0	17.1	12.4
		MCWB	8.4	8.4	10.3	13.4	17.7	20.9	21.2	21.0	19.3	16.4	12.6	9.3
	5%	DB	9.6	11.6	16.2	20.9	24.9	29.0	30.0	29.6	24.1	20.0	15.1	9.9
		MCWB	7.1	7.4	9.6	12.5	16.8	20.4	20.7	20.7	18.1	15.3	11.9	7.9
	10%	DB	7.2	9.5	14.3	18.8	23.0	27.2	28.3	27.6	22.1	17.9	13.1	7.2
		MCWB	5.6	6.1	9.1	11.8	15.8	19.4	20.1	20.1	17.0	14.2	11.2	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	10.2	12.4	16.2	20.3	23.3	23.7	24.1	20.9	18.0	14.3	11.6
		MCDB	13.2	14.5	18.8	22.8	26.8	29.8	30.4	30.4	26.5	22.9	17.2	14.7
	2%	WB	8.8	9.0	11.3	14.5	18.6	21.9	22.4	22.4	19.7	16.9	13.2	9.6
		MCDB	11.3	12.8	16.6	21.4	24.6	28.8	28.9	28.7	25.0	21.2	15.8	12.1
	5%	WB	7.2	7.7	10.4	13.4	17.4	20.8	21.4	21.3	18.7	15.8	12.2	8.0
		MCDB	9.3	11.0	15.1	19.0	23.3	27.4	28.1	27.5	23.1	19.1	14.9	10.0
	10%	WB	5.8	6.4	9.5	12.5	16.4	19.9	20.6	20.5	17.7	14.8	11.1	6.1
		MCDB	7.3	9.1	13.6	17.4	21.8	26.1	27.1	26.5	21.2	17.4	13.2	7.1
Mean Daily Temperature Range	5% DB	MDBR	6.3	8.2	10.2	10.4	10.8	11.0	11.3	11.0	9.5	8.7	6.4	5.9
		MCDBR	10.1	12.9	14.7	15.2	14.3	14.2	14.5	14.6	12.7	12.0	10.2	10.1
		MCWBR	6.7	7.8	7.6	6.9	6.2	5.7	5.6	5.4	6.2	6.7	6.2	7.0
	5% WB	MCDBR	9.0	11.2	12.4	12.7	12.8	12.9	13.0	12.7	11.5	10.5	8.4	9.0
MCWBR		6.2	7.1	6.7	6.0	6.0	5.8	5.7	5.6	5.9	6.2	5.3	6.4	
Clear-Sky Solar Irradiance	taub	0.332	0.359	0.401	0.450	0.442	0.448	0.445	0.442	0.427	0.400	0.363	0.331	
	taud	2.358	2.281	2.208	2.101	2.172	2.205	2.216	2.238	2.245	2.297	2.348	2.405	
	Ebn at Noon	757	804	818	808	829	824	821	807	783	746	709	718	
	Edh at Noon	76	99	123	150	144	140	137	129	118	97	77	67	
All-Sky Solar Radiation	RadAvg	1.24	2.02	3.19	4.26	5.29	6.03	6.10	5.33	3.69	2.36	1.31	1.05	
	RadStd	0.19	0.36	0.47	0.53	0.54	0.40	0.40	0.60	0.49	0.28	0.19	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	+0.83	+0.81	N/A	N/A	N/A	N/A
(47)	Regional (52 neighbors)	+0.44	N/A	N/A	+0.82	+0.45	+0.35	N/A	N/A	+84	+57

Nomenclature: See separate page