

BILOGORA, Croatia

WMO: 142560

Lat: 45.8836N

Lon: 17.2003E

Elev: 864

StdP: 14.24

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	18.5	7.8	8.5	16.8	12.3	10.6	22.3	25.0	33.6	22.4	36.5	8.1	120	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	91.5	72.3	88.4	70.9	85.4	69.6	74.1	88.0	72.4	85.7	70.7	83.2	4.6	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.4	111.5	82.2	67.7	105.0	80.2	66.1	99.5	77.9	38.2	88.4	36.5	85.7	35.0	83.4	81.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
20.7	17.7	15.4	DB	11.9	96.2	4.8	3.4	8.4	98.7	5.6	100.7	2.9	102.6	-0.6	105.1	
			WB	11.0	78.1	4.6	1.7	7.7	79.3	5.0	80.3	2.3	81.2	-1.0	82.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.8	33.8	36.1	45.2	55.2	62.0	69.4	72.6	72.0	62.7	54.0	45.2	36.1	(6)
	DBStd	15.77	9.27	9.42	9.23	7.31	7.23	6.95	6.40	6.31	7.10	7.79	8.13	8.05	(7)
	HDD50	1820	505	395	204	35	5	0	0	0	2	50	188	436	(8)
	HDD65	4854	967	809	615	299	144	37	12	12	124	344	596	895	(9)
	CDD50	3201	3	6	54	192	376	581	700	682	384	175	42	6	(10)
	CDD65	762	0	0	0	6	51	168	247	229	56	5	0	0	(11)
	CDH74	6437	0	0	0	62	392	1370	2230	1992	369	22	0	0	(12)
	CDH80	2281	0	0	0	7	80	448	882	777	87	0	0	0	(13)
(14) Wind	WSAvg	7.3	7.5	8.1	8.8	8.2	7.7	6.6	6.4	6.2	6.6	6.9	7.1	7.1	(14)
(15) Precipitation	PrecAvg	33.1	2.0	2.0	2.0	2.4	3.3	3.2	3.1	3.0	4.0	2.8	3.0	2.4	(15)
	PrecMax	50.0	4.1	4.6	5.4	5.5	7.1	6.9	5.5	6.1	8.8	6.1	6.0	4.8	(16)
	PrecMin	17.3	0.3	0.1	0.2	0.5	1.0	1.4	0.8	0.2	0.6	0.2	0.2	0.2	(17)
	PrecStd	7.2	1.1	1.3	1.3	1.2	1.7	1.5	1.3	1.5	2.3	1.7	1.1	1.3	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.5	61.8	71.7	80.5	86.4	92.1	95.5	96.6	87.2	77.0	67.7	60.8	(19)
		MCWB	48.9	49.3	54.6	62.6	67.4	73.9	73.5	72.0	67.4	62.9	56.7	53.0	(20)
	2%	DB	53.3	56.5	66.9	75.0	82.2	88.5	91.7	91.6	82.0	72.3	63.4	54.9	(21)
		MCWB	46.7	47.1	51.9	57.7	66.1	71.9	72.8	71.1	66.8	61.6	54.8	48.7	(22)
	5%	DB	50.2	52.6	62.6	71.3	78.4	85.3	88.5	87.6	78.1	68.9	59.5	51.5	(23)
		MCWB	44.8	45.3	50.2	56.7	64.0	70.4	71.4	69.9	65.0	59.8	52.7	46.6	(24)
	10%	DB	46.6	49.0	58.3	67.6	74.9	82.0	85.1	84.1	74.4	65.2	56.4	47.7	(25)
		MCWB	42.4	43.1	48.2	54.7	62.0	68.6	69.9	68.7	63.4	57.9	51.5	43.9	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.6	50.6	55.6	63.1	69.3	76.0	76.6	75.4	70.2	64.7	58.0	52.9	(27)
		MCDB	56.1	59.4	68.3	78.5	83.5	89.0	90.4	89.9	82.8	74.2	65.2	60.2	(28)
	2%	WB	47.2	48.1	52.9	59.6	67.1	73.2	74.5	73.2	68.0	62.4	55.8	49.3	(29)
		MCDB	52.4	55.3	64.5	71.3	80.1	86.2	88.7	87.3	79.5	70.7	60.9	54.2	(30)
	5%	WB	45.2	45.9	51.1	57.5	65.0	71.2	72.5	71.5	66.1	60.5	54.0	47.0	(31)
		MCDB	49.7	51.8	60.7	68.5	76.5	83.6	85.9	84.8	75.5	67.5	59.3	51.3	(32)
	10%	WB	42.5	43.6	49.1	55.7	62.8	69.3	70.7	69.8	64.2	58.6	51.5	44.2	(33)
		MCDB	46.2	48.4	57.1	66.2	73.2	80.4	83.2	81.9	72.6	64.1	56.0	47.4	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.9	15.1	18.1	18.4	18.3	19.0	19.2	16.5	14.9	10.7	8.6	(35)
		MCDBR	13.7	17.2	21.4	23.3	22.8	22.1	23.3	24.0	21.8	19.3	15.9	14.0	(36)
		MCWBR	8.9	10.5	11.4	11.7	11.2	10.6	10.5	9.9	9.8	10.3	9.5	9.7	(37)
	5% WB	MCDBR	12.9	15.8	19.5	21.0	21.8	21.1	22.0	22.1	19.9	18.1	14.4	13.6	(38)
		MCWBR	8.6	10.0	10.8	11.0	11.2	10.7	10.5	10.3	9.7	10.0	9.0	9.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.328	0.353	0.386	0.435	0.423	0.424	0.427	0.429	0.414	0.384	0.351	0.328	(40)
	taud		2.382	2.316	2.258	2.131	2.219	2.254	2.242	2.247	2.259	2.334	2.380	2.393	(41)
	Ebn at Noon		242	258	265	261	269	268	266	260	252	243	230	228	(42)
	Edh at Noon		23	30	37	46	43	42	42	41	37	30	24	21	(43)
(44) All-Sky Solar Radiation	RadAvg		386	624	1010	1416	1748	1937	1937	1715	1184	790	434	302	(44)
	RadStd		58	99	128	147	148	147	129	181	150	89	55	49	(45)

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days			
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (42 neighbors)	+0.97	N/A	N/A	N/A	+0.86	+0.86	-169	-254	+149	+95	(47)

Nomenclature: See separate page