

BILOGORA, Croatia

WMO: 142560

Lat: 45.8836N

Lon: 17.2003E

Elev: 263

StdP: 98.20

Time Zone: 1.00 (EUC)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.8	-7.5	-13.4	1.2	-8.5	-10.9	1.5	-5.4	11.2	0.9	10.0	2.5	3.6	120	0.486

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	33.1	22.4	31.3	21.6	29.7	20.9	23.4	31.1	22.4	29.8	21.5	28.4	2.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.8	15.9	27.9	19.8	15.0	26.8	19.0	14.2	25.5	70.9	31.3	67.1	29.8	63.6	28.6	27.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.2	7.9	6.9	DB	-11.2	35.7	2.7	1.9	-13.1	37.0	-14.7	38.2	-16.2	39.2	-18.1	40.6	(4)
(5)			WB	-11.7	25.6	2.6	0.9	-13.5	26.3	-15.0	26.8	-16.5	27.4	-18.3	28.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	12.1	1.0	2.3	7.3	12.9	16.7	20.8	22.5	22.2	17.1	12.2	7.3	2.3	(6)
(7)		DBStd	8.76	5.15	5.23	5.13	4.06	4.02	3.86	3.56	3.51	3.95	4.33	4.52	4.47	(7)
(8)		HDD10.0	1011	281	219	113	19	3	0	0	0	1	28	104	242	(8)
(9)		HDD18.3	2697	537	449	342	166	80	21	7	7	69	191	331	497	(9)
(10)		CDD10.0	1778	2	3	30	107	209	323	389	379	213	97	23	3	(10)
(11)		CDD18.3	423	0	0	0	3	28	93	137	127	31	3	0	0	(11)
(12)		CDH23.3	3576	0	0	0	34	218	761	1239	1107	205	12	0	0	(12)
(13)		CDH26.7	1267	0	0	0	4	44	249	490	432	48	0	0	0	(13)
(14)	Wind	WSAvg	3.2	3.3	3.6	3.9	3.7	3.4	3.0	2.9	2.8	3.0	3.1	3.2	3.2	(14)
(15)	Precipitation	PrecAvg	841	51	51	51	61	84	81	78	76	101	72	75	62	(15)
(16)		PrecMax	1270	103	118	137	140	180	174	139	154	224	154	153	121	(16)
(17)		PrecMin	439	8	3	6	13	26	35	21	6	16	4	4	4	(17)
(18)		PrecStd	184	29	32	34	30	42	39	33	39	59	43	29	33	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.2	16.5	22.0	27.0	30.2	33.4	35.3	30.7	25.0	19.8	16.0	(19)	
(20)			MCWB	9.4	9.6	12.6	17.0	19.6	23.3	23.0	22.2	19.7	17.2	13.7	11.6	(20)
(21)		2%	DB	11.8	13.6	19.4	23.9	27.9	31.4	33.1	33.1	27.8	22.4	17.4	12.7	(21)
(22)			MCWB	8.2	8.4	11.1	14.3	18.9	22.2	22.7	21.7	19.3	16.5	12.7	9.3	(22)
(23)		5%	DB	10.1	11.4	17.0	21.9	25.8	29.6	31.4	30.9	25.6	20.5	15.3	10.9	(23)
(24)			MCWB	7.1	7.4	10.1	13.7	17.8	21.3	21.9	21.1	18.4	15.4	11.5	8.1	(24)
(25)		10%	DB	8.1	9.4	14.6	19.8	23.8	27.8	29.5	28.9	23.6	18.4	13.6	8.7	(25)
(26)			MCWB	5.8	6.2	9.0	12.6	16.6	20.3	21.1	20.4	17.4	14.4	10.9	6.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.8	10.3	13.1	17.3	20.7	24.4	24.8	24.1	21.2	18.1	14.4	11.6	(27)
(28)			MCD B	13.4	15.2	20.2	25.9	28.6	31.6	32.4	32.2	28.2	23.4	18.4	15.6	(28)
(29)		2%	WB	8.5	8.9	11.6	15.3	19.5	22.9	23.6	22.9	20.0	16.9	13.2	9.6	(29)
(30)			MCD B	11.3	12.9	18.1	21.8	26.7	30.1	31.5	30.7	26.4	21.5	16.1	12.3	(30)
(31)		5%	WB	7.3	7.7	10.6	14.2	18.3	21.8	22.5	22.0	18.9	15.8	12.2	8.3	(31)
(32)			MCD B	9.8	11.0	15.9	20.3	24.7	28.7	30.0	29.3	24.2	19.7	15.1	10.7	(32)
(33)		10%	WB	5.9	6.4	9.5	13.2	17.1	20.7	21.5	21.0	17.9	14.8	10.9	6.8	(33)
(34)			MCD B	7.9	9.1	13.9	19.0	22.9	26.9	28.5	27.7	22.6	17.8	13.3	8.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.2	6.1	8.4	10.1	10.2	10.6	10.7	9.2	8.3	5.9	4.8	(35)	
(36)			MCD BR	7.6	9.5	11.9	13.0	12.7	12.3	12.9	13.3	12.1	10.7	8.8	7.8	(36)
(37)			MCWBR	4.9	5.8	6.3	6.5	6.2	5.9	5.8	5.5	5.5	5.7	5.3	5.4	(37)
(38)		5% WB	MCD BR	7.1	8.8	10.8	11.7	12.1	11.7	12.2	12.3	11.0	10.0	8.0	7.5	(38)
(39)			MCWBR	4.8	5.6	6.0	6.1	6.2	5.9	5.8	5.7	5.4	5.5	5.0	5.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.328	0.353	0.386	0.435	0.423	0.424	0.427	0.429	0.414	0.384	0.351	0.328	(40)	
(41)		taud	2.382	2.316	2.258	2.131	2.219	2.254	2.242	2.247	2.259	2.334	2.380	2.393	(41)	
(42)		Ebn at Noon	764	812	834	822	847	845	837	819	795	765	725	719	(42)	
(43)		Edh at Noon	74	96	117	145	137	133	133	128	116	94	75	67	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.22	1.97	3.18	4.46	5.51	6.11	6.11	5.41	3.73	2.49	1.37	0.95	(44)	
(45)		RadStd	0.18	0.31	0.40	0.46	0.47	0.46	0.41	0.57	0.47	0.28	0.17	0.15	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+0.54	N/A	N/A	N/A	+0.48	+0.48	-94	-141	+83	+53

Nomenclature: See separate page