

DARUVAR, Croatia

WMO: 142580

Lat: 45.5914N

Lon: 17.2100E

Elev: 155

StdP: 99.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.1	-8.1	-13.2	1.2	-8.9	-10.5	1.6	-6.2	6.6	4.6	5.9	5.1	0.9	10	0.434

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.5	32.7	21.7	31.2	21.3	29.8	20.8	23.5	29.6	22.4	28.9	21.6	27.9	2.1	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.6	16.5	26.6	20.4	15.4	25.4	19.5	14.5	24.2	70.7	29.6	66.7	29.0	63.4	28.0	27.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	6.1	5.1	4.3	DB	-15.3	35.3	4.1	1.9	-18.2	36.7	-20.6	37.8	-22.9	38.9	-25.9	40.3
(5)				WB	-15.4	25.6	4.1	1.4	-18.4	26.6	-20.8	27.4	-23.0	28.1	-26.0	29.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.6	0.9	2.7	6.8	11.6	16.3	20.1	21.6	21.4	16.4	11.9	7.0	2.0
(7)		DBStd	8.45	4.87	5.19	4.47	3.82	3.56	3.64	3.12	2.95	3.58	4.49	4.90	5.15
(8)		HDD10.0	1039	284	206	118	28	2	0	0	1	33	116	253	
(9)		HDD18.3	2787	541	437	359	203	82	24	8	77	202	341	507	
(10)		CDD10.0	1623	2	2	17	75	196	303	359	353	194	93	25	4
(11)		CDD18.3	331	0	0	0	1	18	77	109	102	21	3	1	0
(12)		CDH23.3	3605	0	0	0	24	243	832	1175	1071	235	26	0	0
(13)		CDH26.7	1292	0	0	0	3	46	288	473	424	57	1	0	0
(14)	Wind	WSAvg	1.6	1.5	1.7	2.0	1.8	1.6	1.5	1.5	1.4	1.3	1.3	1.5	1.5
(15)	Precipitation	PrecAvg	890	55	49	57	75	84	97	84	88	76	70	88	68
(16)		PrecMax	1186	155	148	130	181	206	197	285	279	252	239	158	159
(17)		PrecMin	634	2	8	11	13	8	30	3	14	8	0	12	7
(18)		PrecStd	136	31	31	26	35	44	39	54	60	52	52	45	40
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.6	17.8	21.8	26.0	30.2	33.2	35.1	35.6	31.2	25.9	21.3	17.5
(20)		MCWB	10.5	9.8	12.2	15.7	19.7	22.2	21.9	22.0	19.6	17.7	14.4	12.1	
(21)		2%	DB	13.0	15.1	19.3	23.4	27.9	31.6	32.7	32.8	28.1	23.6	19.0	14.1
(22)		MCWB	8.9	9.3	11.5	14.4	19.0	21.8	21.9	21.5	19.3	17.0	13.4	10.0	
(23)		5%	DB	10.6	13.0	17.1	21.4	26.2	30.0	31.1	30.9	26.0	21.6	16.9	12.0
(24)		MCWB	7.5	8.1	10.5	13.4	17.9	21.3	21.4	21.1	18.3	16.0	12.3	8.7	
(25)		10%	DB	8.2	10.7	14.9	19.4	24.3	28.2	29.5	29.1	24.0	19.4	14.7	9.6
(26)		MCWB	6.0	7.0	9.6	12.4	16.9	20.2	20.9	20.5	17.6	15.1	11.5	7.5	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	11.0	13.3	16.9	21.2	24.2	25.0	24.8	21.5	18.7	15.4	12.3
(28)		MCDWB	14.8	15.9	19.5	23.4	27.4	29.9	30.7	30.3	26.7	23.7	19.0	16.7	
(29)		2%	WB	9.1	9.7	12.2	15.3	19.8	23.0	23.6	23.1	20.1	17.6	14.0	10.5
(30)		MCDWB	12.2	14.2	17.5	21.5	26.2	29.6	29.7	29.4	26.0	22.2	17.4	13.7	
(31)		5%	WB	7.7	8.5	11.2	14.1	18.7	22.0	22.4	22.0	19.2	16.6	12.9	9.1
(32)		MCDWB	10.3	12.3	15.9	19.4	24.5	28.4	28.7	28.8	24.4	20.6	16.6	11.6	
(33)		10%	WB	6.1	7.4	10.0	13.2	17.6	20.9	21.5	21.2	18.2	15.5	11.5	7.6
(34)		MCDWB	8.1	10.4	14.5	18.2	22.9	26.8	27.8	27.5	22.6	18.9	14.5	9.6	
(35)	Mean Daily Temperature Range	MDBR	7.0	9.3	10.7	11.7	12.2	12.1	12.5	13.0	11.7	10.9	8.2	6.6	
(36)		5% DB	MCDBR	10.7	13.3	15.0	16.1	15.6	14.7	15.7	16.6	15.6	13.4	11.3	9.8
(37)		MCWBR	6.9	7.8	8.1	7.7	7.2	6.7	6.7	6.7	7.2	7.3	6.6	6.3	
(38)		5% WB	MCDBR	10.1	12.1	13.0	13.5	13.9	14.1	14.4	14.5	13.7	12.4	10.4	9.2
(39)		MCWBR	6.7	7.4	7.2	6.8	6.9	6.9	6.9	6.7	6.9	7.0	6.4	6.3	
(40)		Clear-Sky Solar Irradiance	taub	0.335	0.361	0.395	0.446	0.433	0.434	0.436	0.437	0.423	0.392	0.358	0.335
(41)	taud		2.371	2.298	2.242	2.110	2.200	2.241	2.231	2.237	2.246	2.323	2.373	2.383	
(42)	Ebn at Noon		758	804	826	812	838	838	830	813	788	758	721	714	
(43)	Edh at Noon		76	98	119	148	140	135	135	129	118	95	76	69	
(44)	All-Sky Solar Radiation	RadAvg	1.22	1.95	3.18	4.44	5.50	6.14	6.16	5.45	3.74	2.50	1.39	0.97	
(45)		RadStd	0.20	0.32	0.41	0.47	0.46	0.48	0.40	0.58	0.48	0.29	0.18	0.16	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) +1.39	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (39 neighbors)	+0.58	N/A	N/A	N/A	+0.51	+0.50	-105	-156	+97	+57	(47)

Nomenclature: See separate page