

OSIJEK CEPIN, Croatia

WMO: 142800

Lat: 45.5022N

Lon: 18.5617E

Elev: 293

StdP: 14.54

Time Zone: 1.00 (EUC)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	18.1	8.7	8.7	15.1	13.9	11.2	19.3	15.6	41.0	13.6	38.6	3.5	90	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	22.1	93.0	71.8	90.2	70.8	87.3	69.7	73.9	87.7	72.6	85.8	71.2	83.6	5.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.0	111.5	78.3	68.5	105.9	77.3	67.2	101.0	76.2	37.6	88.3	36.3	86.0	35.2	84.0	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.0	10.2	5.1	97.1	9.1	4.0	-1.5	100.0	-6.8	102.3	-11.9	104.5	-18.5	107.4
			4.8	76.3	9.0	1.3	-1.7	77.2	-7.0	77.9	-12.1	78.6	-18.6	79.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	54.1	33.9	36.7	45.2	55.1	62.7	69.6	72.7	72.5	63.6	54.6	45.1	36.0	(6)
(7)		DBStd	15.60	8.65	9.15	8.44	6.59	6.63	6.42	5.69	5.60	6.56	7.40	7.40	7.79	(7)
(8)		HDD50	1752	501	374	190	28	3	0	0	0	40	181	435	(8)	
(9)		HDD65	4765	966	791	614	300	123	29	8	103	329	597	898	(9)	
(10)		CDD50	3237	1	3	41	182	396	589	703	697	407	182	33	3	(10)
(11)		CDD65	772	0	0	0	5	51	168	246	238	59	5	0	0	(11)
(12)		CDH74	8253	0	0	1	90	573	1731	2694	2501	598	65	0	0	(12)
(13)		CDH80	3237	0	0	0	12	139	635	1182	1093	172	4	0	0	(13)
(14)	Wind	WSAvg	4.7	4.9	5.3	5.8	5.2	4.9	4.4	4.3	4.0	4.1	4.4	4.7	4.8	(14)
(15)	Precipitation	PrecAvg	27.5	1.9	1.8	1.8	1.9	3.1	3.4	2.4	2.5	2.5	2.2	2.1	1.8	(15)
(16)		PrecMax	37.8	3.2	3.2	3.6	4.9	7.2	8.7	6.0	8.3	7.0	5.2	4.5	4.4	(16)
(17)		PrecMin	15.4	0.9	0.1	0.1	0.2	0.9	1.1	0.8	0.1	0.3	0.1	0.1	0.1	(17)
(18)		PrecStd	6.1	0.7	0.9	1.0	1.3	1.7	1.9	1.4	1.9	1.7	1.5	1.0	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	57.6	63.6	72.0	81.7	88.2	93.2	97.9	97.6	90.2	80.0	69.3	58.9	(19)
(20)		0.4%	MCWB	50.5	52.0	56.1	62.4	67.6	72.8	72.8	72.8	68.9	63.9	58.5	52.6	(20)
(21)		2%	DB	52.7	56.9	67.7	76.2	83.7	90.1	93.1	93.2	84.9	75.1	63.8	54.0	(21)
(22)		2%	MCWB	47.7	49.2	54.2	59.5	66.5	71.8	72.0	71.2	66.1	61.6	56.0	49.8	(22)
(23)		5%	DB	48.1	52.4	63.1	72.2	80.4	86.9	90.2	89.8	80.7	71.7	59.6	49.7	(23)
(24)		5%	MCWB	45.2	47.1	51.8	57.5	65.0	70.3	71.3	70.0	64.8	60.1	54.4	46.6	(24)
(25)		10%	DB	44.9	48.5	58.7	68.6	76.6	83.6	86.8	86.3	76.9	67.3	56.4	46.2	(25)
(26)		10%	MCWB	42.7	45.0	49.9	56.0	63.1	68.7	70.0	68.8	63.4	58.4	52.1	43.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.6	53.0	57.3	63.6	70.3	74.8	76.0	75.3	71.0	66.0	59.9	53.5	(27)
(28)		0.4%	MCDWB	56.9	61.1	69.4	78.9	82.2	87.6	89.0	89.6	85.2	76.5	66.3	57.4	(28)
(29)		2%	WB	48.2	50.3	55.1	60.8	67.9	73.3	74.3	73.2	68.4	63.4	57.2	49.9	(29)
(30)		2%	MCDWB	51.5	55.7	64.8	72.4	80.5	86.2	88.4	87.2	80.2	72.3	61.9	53.0	(30)
(31)		5%	WB	45.3	47.7	53.0	58.8	66.0	71.9	72.7	71.7	66.5	61.3	55.0	46.9	(31)
(32)		5%	MCDWB	47.8	51.4	61.5	69.3	77.8	83.9	86.3	85.2	76.8	69.1	59.7	49.5	(32)
(33)		10%	WB	42.8	45.3	50.9	57.2	64.3	70.3	71.2	70.3	64.8	59.4	52.3	44.0	(33)
(34)		10%	MCDWB	44.9	48.3	58.0	66.3	74.6	81.1	83.5	82.6	73.6	66.1	55.9	45.9	(34)
(35)	Mean Daily Temperature Range		MDBR	11.0	13.3	17.7	20.7	20.3	20.5	22.1	22.7	20.0	18.7	14.0	10.2	(35)
(36)		5% DB	MCDBR	16.8	20.9	26.0	27.7	26.4	25.4	27.9	28.4	26.9	24.9	20.3	15.8	(36)
(37)			MCWBR	12.3	13.7	13.8	12.6	10.8	9.3	9.2	9.2	10.5	12.7	13.0	11.6	(37)
(38)			MCDBR	16.1	18.8	23.5	24.3	24.5	23.3	25.4	25.1	22.8	22.6	18.8	15.2	(38)
(39)		5% WB	MCWBR	12.1	13.0	13.2	11.9	10.7	9.5	9.4	9.4	10.0	12.3	12.4	11.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.340	0.366	0.399	0.454	0.440	0.438	0.443	0.446	0.429	0.395	0.361	0.340	(40)	
(41)		taud	2.364	2.286	2.230	2.083	2.180	2.226	2.210	2.208	2.222	2.313	2.364	2.369	(41)	
(42)		Ebn at Noon	239	253	261	255	264	264	261	255	248	239	227	224	(42)	
(43)		Edh at Noon	24	32	38	49	45	43	44	42	38	30	24	22	(43)	
(44)	All-Sky Solar Radiation	RadAvg	384	643	1044	1464	1784	1957	1973	1757	1220	835	483	310	(44)	
(45)		RadStd	60	91	130	135	152	159	146	174	137	86	44	46	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (39 neighbors)	+1.17	N/A	N/A	N/A	+0.77	+0.77	-207	-310	+182	+108

Nomenclature: See separate page